210

Initial Notification of Applicability[b]

National Emission Standards for Hazardous Air Pollutants:

Stationary Reciprocating Internal Combustion Engines

40 CFR Part 63 Subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221112 – Electric Power Generation, Fossil Fuel

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: Midwest Energy

Facility name (if different): Bird City Plant

Facility (physical location) address: North Main Street, Bird City, KS 67642

My facility is a (please choose one): ☐ Major source ☒ Area source

☐ Synthetic minor

Owner name/title: William Dowling, Vice President of Energy Management and Supply

[a] This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

[b] Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Owner/company address: 1330 Canterbury Road, P.O. Box 898, Hays, KS 67601

Owner telephone number: 785-625-1432

Owner email address (if available): bdowling@mwenergy.com

If the Operator information is different from the Owner, please provide the following:

Owner: NAES Corp.

Operator name/title: Michael Prindle, Plant Manager

Operator telephone number: 785-625-1713

Operator email address (if available): mprindle@mwenergy.com

I hereby certify that the information presented herein is correct to the best of my knowledge.

William Dowling
(Signature)

Aug. 27, 2010
(Date)

William Dowling
Vice Pres. Energy Mgmt & Supply
(Name/title)

(785) 625-1432
(Telephone No.)

Appendix 1

Stationary RICE Site Inventory

40 CFR Part 63 Subpart ZZZZ

Company name: Midwest Energy

Facility name (if different): Bird City Plant

Facility (physical location) address: North Main Street, Bird City, KS 67642

Unit 1
Man./Model: General Motors – Model 16-567-D4
Rated: 2875 hp – 2000 kW Generator
Fuel: Diesel Fuel

Unit 2
Man./Model: General Motors – Model 16-645-E4
Rated: 2875 hp – 2000 kW Generator
Fuel: Diesel Fuel