TELEPHONE CALLS, INCOMING OR OUTGOING,
AND ANY LOCAL CALLS MERITING RECORDING

PREPARE IMMEDIATELY - SUBMIT DAILY

~~D. JOHNSON~~
M. JOHNSTON
FILE: ~~[illegible]~~ PBU
Prudhoe Bay AK

CALL FROM: Charlie Fahl

TITLE: Meteorologist - Dames + Moore

LOCATION & PHONE NO.: Anchorage 279-0673

DATE: 7/24/78

CALL TO: Rob Wilson

TIME: 3:00 PM

TITLE:

LOCATION & PHONE NO.:

SUMMARY OF CALL:

We discussed four items concerning ~~their~~ ARCO's PSD application

1) Information that will be submitted for modified guideline model (CRSTER) - sounds like it will be O.K.

2) They have developed their own method for computing mixing heights from RAOB data - Holzworth method gave "bad" results - I said we would be open to looking at it.

3) They want to omit "emergency sources" (diesel power generators) from the modeling analysis. I said that probably would be O.K. [IS THIS O.K. MIKE?]

4) They have problems with AP-42 NO_x emission factors for the large turbines (300 ppm). They have support for less. I said they must be willing to take whatever they use as a permit emission limit.

Application expected by Aug 1st

Rob
(Signature)

USEPA REG
0000188