4-260115 — Eagle S+S
NOV Response

(May 22, 1995)

NOV items	Response	Problem
1. ATG records for May – July 95	1. ATG records for Feb. – April 95	X
2. install. for line LD by tech.	2. interstitial method	—
3. tests of ALLD	3. cell tested good	—
4. FR proof	4. ϕ	X
+ reply by 7/31/95	+ Contractor letter of 7/13, but O/O mailed it 9/15/95!	X
+ compliance by 7/15/95	+ unsure	X

Draft letter Response (:)
A. intro.
B. recognize partial compliance
C. id. items of NC
D. direct full C.

10/17/95 – Call to Dustin R. (509/452-4530)
– told him missing #1 & #4 items in May 22 '95 ltr.
– will resend by middle of next week (!) ATG records for 4/95 – 7/95 Received 11/16/95

10/19/95 Call from David LaRiviere 509/965-2090
Conover Ins. / Yakima
2:09 pm
will fax me copy of conversation confirmation ✓ + then get the insurance policy in place ASAP

11/27/95 Call to David LaR. — ~~spoke~~ left VM (m) ✓.

Leaks detected for 5/95 + 7/95 + inflow for 4/95 — all TANK #1

11/30/95 VM for David LaR. — FR cut. coming this week