UST SITE DATA-EXISTING
U.S. Environmental Protection Agency
Region 10

Facility ID: 4260087 **Current Site Inspection Appointment:** _____
Contact Name(s): Susan Smith, Env. Eng. 509-882-3377
Facility Name: Smitty's Conoco
Address: 102 E Toppenish Ave.
City: Toppenish **State:** WA **ZIP:** 98948 **Phone:** 8
Owner Name: R.H. Smith Dist. Co. **Operator Name:** _____
Owner Address: 315 E. Wine Country Rd.
City: Grandview **State:** ____ **ZIP:** _____ **Phone:** 882-3377
Comments: Ordering ATG.

Tank #	1	2	3	4	5	6
Product	G	G	G			
Capacity	8,000	6,000	4,000			
Installed	1/74	1/74	1/76			
Closed						
T- Material	BS	—	—			
T- CP						
T- RD	MTG/IC/III	—	—			
P- Type	P	—	—			
P- Material	GS	—	—			
P- CP						
P- RD	ALLD/LTT	—	—			
Spill Dev.	✓	—	—			
Ovrfl Dev.	✓	—	—			
Fin. Resp.	✓					

PREVIOUS INSPECTIONS

Insp. Date	Inspector	Non-Compliance Items	FC #	Penalty	FNNC #
9/21/95	Koo/Or	No IC records Tank Calibration Tables - ⅛"			010
		Drop Tube for #3 is 4' from tank bottom			

Questions to ask: _____