MONTHLY INVENTORY RECORD

TANK IDENTIFICATION & TYPE OF FUEL: SNL - 4000 GAL

MONTH/YEAR: 11/98

FACILITY NAME: Smitty's - Toppenish

DATE OF WATER CHECK: 11-1 LEVEL OF WATER INCHES: 0

[illegible]	2835	(+)	400	(-) 492	(=) 3743	69	3833	90	
[illegible]	3659	(+)		(-) 121	(=) 3538	62	3510	-28	
[illegible]	3510	(+)		(-) 103	(=) 3407	60	3402	-5	
[illegible]	3402	(+)		(-) 201	(=) 3201	56 3/4	3218	17	
[illegible]	[illegible]	(+)		(-) [illegible]	(=) [illegible]	[illegible]	[illegible]	[illegible]	
[illegible]	[illegible]	(+)		(-) 25	(=) 2768	52 1/2	2761	-7	
[illegible]	2761	(+)		(-) 215	(=) 2746	50	2803	57	
10	2803	(+)		(-) 358	(=) 2445	43	2345	-100	
11	2345	(+)		(-) 510	(=) 1835	40	2144	309	
12	2144	(+)		(-) 126	(=) 2018	33 3/4	1724	-294	
13	1724	(+)		(-) 126	(=) 1598	31 1/2	1574	-24	
14	1574	(+)		(-) 104	(=) 1470	29 3/4	1433	-37	
15	1433	(+)	2001	(-) 128	(=) 3306	59	3347	41	
16	3347	(+)		(-) 100	(=) 3247	58 1/2	3319	72	
17	3319	(+)		(-) 85	(=) 3234	56	3174	-60	
18	3174	(+)		(-) 95	(=) 3079	55	3114	35	
19	3114	(+)		(-) 143	(=) 2971	52 1/4	2945	-26	
20	2945	(+)		(-) 152	(=) 2793	49 3/4	2787	-6	
21	2787	(+)		(-) 140	(=) 2647	47 1/2	2642	-5	
22	2642	(+)		(-) 136	(=) 2506	45	2478	-28	
23	2478	(+)		(-) 155	(=) 2323	43	2345	-22	
24	2345	(+)		(-) 78	(=) 2267	42	2278	11	
25	2278	(+)		(-) 111	(=) 2167	40	2144	-23	
26	2144	(+)		(-) 124	(=) 2020	38 1/4	2026	6	
27	2026	(+)		(-) 128	(=) 1898	36 1/4	1891	-7	
28	1891	(+)	2002	(-) 149	(=) 3744	67 1/2	3772	28	
29	3772	(+)		(-) 114	(=) 3658	65 1/4	3671	13	
30	3671	(+)		(-) 156	(=) 3515	62 1/2	3535	20	
31	3535	(+)		(-) 101	(=) 3434	60	3402	-32	

TOTAL GALLONS PUMPED > 5320 TOTAL GALLONS OVER OR SHORT > -72

DROP THE LAST 2 DIGITS from the TOTAL GALLONS PUMPED number and enter on the line below

Compare these numbers

LEAK CHECK: 53 + 130 = 183 gallons

Is "TOTAL GALLONS OVER OR SHORT" LARGER than "LEAK CHECK" result? YES NO (circle one)

If answer is "YES" for 2 MONTHS IN A ROW, notify regulatory agency as soon as possible.

KEEP THIS PIECE OF PAPER ON FILE FOR AT LEAST 1 YEAR

x12

MONTHLY INVENTORY RECORD

TANK IDENTIFICATION & TYPE OF FUEL: REG - 6000 GAL

MONTH/YEAR: 11 / 95

FACILITY NAME: Shirley's - Toppenish

DATE OF WATER CHECK: Hot LEVEL OF WATER (INCHES): 0

[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	
27	6195	(+)	265	(-) 251	(=) 6199	88	6052	-147	
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	81	5686	-63	
29	5686	(+)		(-) 224	(=) 5462	76	5368	-94	
30	5368	(+)		(-) 327	(=) 5041	74 1/2	5266	225	
31	5266	(+)		(-) 290	(=) 4976	70	4944	-32	
[illegible]	[illegible]	(+)		[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	
2	4642	(+)		(-) 240	(=) 4402	62 1/4	4347	-55	
3	4347	(+)		(-) 341	(=) 4006	57	3922	-84	
4	3922	(+)		(-) 185	(=) 3737	55 3/4	3819	82	
5	3819	(+)		(-) 247	(=) 3572	52 3/4	3569	-233	
6	3569	(+)		(-) 244	(=) 3325	50	3340	15	
7	3340	(+)		(-) 267	(=) 3073	48	3172	99	
8	3172	(+)		(-) 218	(=) 2954	44 1/4	2857	-97	
9	2857	(+)	1999	(-) 207	(=) 4649	65 1/2	4603	-46	
10	4603	(+)		(-) 273	(=) 4330	62 1/2	4367	37	
11	4367	(+)		(-) 209	(=) 4158	60 1/2	4207	49	
12	4207	(+)		(-) 155	(=) 4052	58	4004	-48	
13	4004	(+)		(-) 276	(=) 3728	55 1/8	3767	39	
14	3767	(+)		(-) 194	(=) 3573	52 1/4	3528	-45	
15	3528	(+)		(-) 291	(=) 3237	48 3/4	3235	-2	
16	3235	(+)		(-) 276	(=) 2959	45 1/4	2941	-18	
17	2941	(+)		(-) 270	(=) 2671	43	2753	82	
18	2753	(+)		(-) 239	(=) 2514	39	2421	-93	
19	2421	(+)	2000	(-) 147	(=) 4274	63	4407	133	
20	4407	(+)		(-) 253	(=) 4154	59	4085	69	
21	4085	(+)		(-) 195	(=) 3890	57	3922	32	
22	3922	(+)		(-) 351	(=) 3571	52 1/2	3549	-22	
23	3549	(+)		(-) 168	(=) 3381	50 1/2	3381	0	
24	3381	(+)		(-) 196	(=) 3185	49	3256	71	
25	3256	(+)	503	(-) 268	(=) 3491	51 1/2	3465	-26	

TOTAL GALLONS PUMPED > 7545 **TOTAL GALLONS OVER OR SHORT >** -18

DROP THE LAST 2 DIGITS from the TOTAL GALLONS PUMPED number and enter on the line below

Compare these numbers

LEAK CHECK: 75 + 130 = 205 gallons

Is "TOTAL GALLONS OVER OR SHORT" LARGER than "LEAK CHECK" result? YES NO (circle one)

If answer is "YES" for 2 MONTHS IN A ROW, notify regulatory agency as soon as possible.

KEEP THIS PIECE OF PAPER ON FILE FOR AT LEAST 1 YEAR

x12

MONTHLY INVENTORY RECORD

TANK IDENTIFICATION & TYPE OF FUEL: NL - 8000 GAL

MONTH/YEAR: 11 95

FACILITY NAME: Smitty's Toppenish

DATE OF WATER CHECK: 11-7 WATER GAUGE ON TANK: 0

[illegible]	[illegible]	(+) 4000	(-) [illegible]	(=) [illegible]	[illegible]	[illegible]	[illegible]		
28	3996	(+) 3806	(-) 928	(=) 6874	75 1/2	6904	[illegible]		
[illegible]	[illegible]	(+)	(-) [illegible]	(=) 5555	61 1/2	5548	-7		
29	5548	(+)	(-) 1264	(=) 4284	54	4754	470		
30	4754	(+)	(-) 1426	(=) 3328	37	2920	-408		
31	2920	(+) 4000	(-) 1396	(=) 5524	61 1/2	5548	24		
[illegible]	[illegible]	(+)	(-) [illegible]	(=) [illegible]	[illegible]	[illegible]	[illegible]		
2	4168	(+)	(-) 1356	(=) 2812	35 1/2	2762	50		
3	2762	(+)	(-) 1444	(=) 1318	23	1514	196		
4	1514	(+) 5699	(-) 555	(=) 6658	71	6494	-164		
5	6494	(+)	(-) 13	(=) 6481	71	6494	13		
6	6494	(+)	(-) 1193	(=) 5301	59 1/8	5300	1		
7	5300	(+)	(-) 1165	(=) 4135	46 1/4	3915	-220		
8	3915	(+)	(-) 1178	(=) 2737	37 1/4	2946	209		
9	2946	(+) 4000	(-) 1069	(=) 5877	65 1/8	5919	42		
10	5919	(+) 2100	(-) 1250	(=) 6769	75	6860	91		
11	6860	(+)	(-) 1137	(=) 5723	63	5703	-20		
12	5703	(+)	(-) 1122	(=) 4581	52	4538	-43		
13	4538	(+)	(-) 1076	(=) 3462	41	3347	-115		
14	3347	(+)	(-) 1176	(=) 2171	30 1/2	2245	74		
15	2245	(+) 4300	(-) 1017	(=) 5528	61	5496	-32		
16	5496	(+)	(-) 1178	(=) 4318	49 3/4	4295	-23		
17	4295	(+)	(-) 1262	(=) 3033	36	2814	-219		
18	2814	(+)	(-) 1214	(=) 1600	26	1798	198		
19	1798	(+) 4999	(-) 1105	(=) 5692	62	5600	-92		
20	5600	(+)	(-) 1101	(=) 4499	52 1/2	4592	93		
21	4592	(+)	(-) 928	(=) 3664	44 1/2	3725	61		
22	3725	(+) 4000	(-) 1297	(=) 6428	71 3/4	6564	136		
23	6564	(+)	(-) 853	(=) 5711	61 1/2	5548	-163		
24	5548	(+)	(-) 1041	(=) 4507	51	4430	-77		
25	4430	(+) 3498	(-) 998	(=) 6930	75 3/4	6926	-4		

TOTAL GALLONS PUMPED > 34067 **TOTAL GALLONS OVER OR SHORT >** 223

DROP THE LAST 2 DIGITS from the PUMPED number and enter on the TOTAL GALLONS line below

Compare these numbers

LEAK CHECK: 340 + / 130 = 470 gallons

Is "TOTAL GALLONS OVER OR SHORT" LARGER than "LEAK CHECK" result? YES NO (circle one)

If answer is "YES" for 2 MONTHS IN A ROW, notify regulatory agency as soon as possible.

KEEP THIS PIECE OF PAPER ON FILE FOR AT LEAST 1 YEAR

x12