NORTHWEST TANK & ENVIRONMENTAL SERVICES
CATHODIC PROTECTION TEST DATA SHEET

Location: EAGLE STOP & SAVE
50 W. WAPATO RD.
WAPATO, WA

ss# _____

Test Number: 000 —

Test Date: 8-6-97

Operator: D. Reeves

	UNLEADED	MIDGRADE	SUPER	DIESEL	REGULAR
Backfill Material (Pea gravel, Sand, etc.)	SAND →				
Cathodic Protection (Stip-3, impressed, sacrificial)	STIP-3 →				
Potential Reading (>-.85 volts)	-1.201	-1.215	-1.132		
Test Time	AM →				
Conclusion Pass / Fail	PASS				

Comments:

2/96 WP\C:\Misc\cath.test

NORTHWEST TANK & ENVIRONMENTAL SERVICES
CATHODIC PROTECTION TEST DATA SHEET

Location: EAGLE STOP & SAVE
50 W. WAPATO RD.
WAPATO, WA

SS# _____

Test Number: 000

Test Date: 8-6-97

Operator: D. Reeves

	UNLEADED	MIDGRADE	SUPER	DIESEL	REGULAR
Backfill Material (Pea gravel, Sand, etc.)	SAND	→	→		
Cathodic Protection (Skip-3, impressed, sacrificial)	STEP-3	→	→		
Potential Reading (>-.85 volts)	-1.201	-1.215	-1.152		
Test Time	AM	→	→		
Conclusion Pass / Fail	PASS				

Comments:

2/96 WPC:\Miscksth.xcel