UNITED STATES GOVERNMENT

File

2-Way Memo

Subject : CATERPILLAR TRACTOR CO.
CATERPILLAR DRIVE & McDONOUGH ST.
JOLIET, ILL. 60434

To : ERIC COHEN EC

THRU: G. CZERNIAK / ~~M. TRANKINA~~ 4/18/80 Kathy M

INSTRUCTIONS

Use routing symbols whenever possible.

SENDER:
Use brief, informal language.
Conserve space.
Forward original and one copy.

RECEIVER:
Reply below the message, keep one copy, return one copy.

DATE OF MESSAGE	Routing Symbol
4/18/80	

SIGNATURE OF ORIGINATOR: John J. Standard

TITLE OF ORIGINATOR: Environmental Engr.

FOLD — FOLD

INITIAL MESSAGE

Particulate emissions from Boilers #2 and #3 exceed the limits of Illinois Rule 203(g)(1)(A). Actual emissions are 34.7 T/yr vs. 20.2 T/yr allowed. Since this is a minor source and the company is on a compliance program with the State, I recommend this case be referred to file and no further action be taken at this time.

REPLY MESSAGE

From :

DATE OF REPLY	Routing Symbol

SIGNATURE OF REPLIER

TITLE OF REPLIER

5027-104

1. TO BE RETAINED BY ADDRESSEE

OPTIONAL FORM 27
JULY 1973
GSA FPMR (41 CFR) 101-11.6

UNITED STATES GOVE MENT

2-Way Memo

Subject : CATERPILLAR TRACTOR CO.
CATERPILLAR DRIVE AND McDONOUGH ST.
JOLIET, ILLINOIS 60434

To : ERIC COHEN EC 4/3 see below

THRU: G. CZERNIAK / L. KERTCHER / S. ETO

INSTRUCTIONS

Use routing symbols whenever possible.

SENDER:
Use brief, informal language.
Conserve space.
Forward original and one copy.

RECEIVER:
Reply below the message, keep one copy, return one copy.

DATE OF MESSAGE	Routing Symbol
3/28/79	

SIGNATURE OF ORIGINATOR: John J Standard

TITLE OF ORIGINATOR: ENVIRONMENTAL ENGR.

FOLD — FOLD

INITIAL MESSAGE

Particulate emissions from Boilers #2 and #3 exceed the limits of Illinois Rule 203(g)(1)(A). Enforcement by State of Illinois is pending until further regulations are adopted as a result of Ashland Chemical company case. I have prepared a Checklist for legal section. However, since there are currently no applicable regulations, I recommend that the CDS system be updated to show these sources in violation and no further action be taken at this time.

REPLY MESSAGE

I respectfully dissent and believe CDS should show no applicable reg until its approved.
EC

From : JOHN STANDARD
AIR ENFORCEMENT BRANCH

DATE OF REPLY	Routing Symbol

SIGNATURE OF REPLIER

TITLE OF REPLIER

1. TO BE RETAINED BY ADDRESSEE

OPTIO

5027-104

☆ U. S. GOVERNMENT PRINTING OFFICE: 1975 — 563-446

UNITED STATES GOVERNMENT

2-Way Memo

Subject : Stack Test Evaluation

To : Gerry Regan
Air Surveillance Branch

thru: ~~G. Germain~~ J.C. / S. Etope

INSTRUCTIONS

Use routing symbols whenever possible.

SENDER:
Use brief, informal language.
Conserve space.
Forward original and one copy.

RECEIVER:
Reply below the message, keep one copy, return one copy.

DATE OF MESSAGE	Routing Symbol
3/2/79	

SIGNATURE OF ORIGINATOR: John Standard

TITLE OF ORIGINATOR: Env. Engr.

FOLD

INITIAL MESSAGE

Please evaluate the validity of the enclosed stack test of Boilers #2 and 3 at the Caterpillar Tractor Co. Joliet Plant. I would appreciate your reply by 3/9/79.
(also pls. check to see if the results are accurate!)

REPLY MESSAGE

From : John Standard
Air Enforcement Branch

DATE OF REPLY	Routing Symbol

SIGNATURE OF REPLIER

TITLE OF REPLIER

5027-104

1. TO BE RETAINED BY ADDRESSEE

OPTIONAL FORM 27
JULY 1973
GSA FPMR (41 CFR) 101-11.6