OVERFLOW REPORT

PERIOD: August 2014

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	309826	562172	8/20/2014	PAINTER WAY	6903	100	Debris	CLEANED MAIN	1.22	GROUND	Area Cleaned and Disinfected, Flushed Area with H2O
	309837	562823	8/20/2014	LES HARRISON DR	6050	4,500	Vandalism	CLEANED MAIN	1.50	GROUND	Area Cleaned and Disinfected, - Follow Up To Bolt Down Manholes
TOTAL EVENTS	2			TOTAL GALLONS:	4,600			TOTAL DURATION:	2.72		

Monday, September 08, 2014

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED:MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	DATE	ADDRESS	GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
TOTAL EVENTS		TOTAL GALLONS:					TOTAL DURATION:			

Monday, September 08, 2014

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: August 2014

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	310794	575556	8/31/2014	EUREKA DR	114	50	Grease	CLEANED MAIN	0.87	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
	310400	570161	8/26/2014	WAVERLY	2502	50	Grease	CLEANED MAIN	0.65	ALLEY	Area Cleaned and Disinfected, Flushed Area with H2O
	310095	565879	8/22/2014	ANSLEY BLVD W	1402	12,000	Debris	CLEANED MAIN	2.00	DRAINAGE CULVERT	Area Cleaned and Disinfected, Flushed Area with H2O
	310083	565277	8/22/2014	NEW BRAUNFELS AVE S	7000	580	Grease	CLEANED MAIN	0.97	STORMDRAIN	Area Cleaned and Disinfected, Flushed Area with H2O
1021659		559328	8/19/2014	GLENN AVE E	423	300	Structural	ORDER TO REPAIR FORCE MAIN	0.32	STREET	Area Cleaned and Disinfected, Work Order Made To Repair Sewer Force Main @ L/s 269
	309578	557207	8/17/2014	BARBARA	118	300	Roots	CLEANED MAIN	0.87	DRAINAGE CULVERT	Area Cleaned and Disinfected, Flushed Area with H2O
		552463	8/13/2014	MEDICAL DR	4212	50	Contractor	CLEANED LATERAL	0.82	STREET	Sewer Lateral - Unstopped Sewer Lateral,
	309099	551270	8/13/2014	ST MARY'S N	3900	5	Debris	CLEANED MAIN	2.68	STREET	Area Cleaned and Disinfected,
	308726	544663	8/7/2014	NEER AVE	3714	200	Grease	CLEANED MAIN	1.23	DRAINAGE CULVERT	Area Cleaned and Disinfected, Flushed Area with H2O
	308395	540404	8/5/2014	35TH ST SW	934	50	Grease	CLEANED MAIN	0.85	STORMDRAIN	Area Cleaned and Disinfected, Flushed Area with H2O
	308089	535664	8/1/2014	MEDICAL DR	3838	350	Debris	CLEANED MAIN	2.18	STORMDRAIN	Area Cleaned and Disinfected, Flushed Area with H2O
TOTAL EVENTS	11			TOTAL GALLONS:	13,935			TOTAL DURATION:	13.44		

Monday, September 08, 2014

Note: Comments reflect status reported on the 5-Day report

Received
SEP 18 2014
6EN-W

OVERFLOW REPORT

PERIOD: August 2014

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	308846	545685	8/8/2014	BINZ-ENGLEMAN RD	5897	370	Debris	CLEANED MAIN	1.23	EASEMENT	Area-Cleaned and Disinfected, Flushed Area with H2O
		544214	8/6/2014	LONGVALE	4155	50	Contractor	CLEANED MAIN	0.25	STREET	Area Cleaned and Disinfected, Flushed Area with H2O Contractor Unstopped Main
1017131			8/6/2014	LOOP 410 NE	3003	1,870	Structural	REPAIRED COLLAPSED MAIN	2.00	CREEK BED	Repaired Sewer Main - Spilled Into Dry Creek Bed Of Beitel Creek.
TOTAL EVENTS	3			TOTAL GALLONS:	2,290			TOTAL DURATION:	3.48		

Monday, September 08, 2014

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: September 2014

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
1037171	313118	610553	9/28/2014	WOODLAWN W	116	50	Contractor	CLEANED MAIN	1.37	GROUND	Area Cleaned and Disinfected, Flushed Area with H2O - Work Order Has Been Created To Repair Sewer Main
1036685	313022	610480	9/27/2014	ARAPAHOE	202	100	Structural	CLEANED AREA	0.25	STREET	Work Order To Repair Sewer Main
1030842	311545	588654	9/10/2014	OLD HICKORY	2511	20	Roots	CLEANED LATERAL	2.88	STREET	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Relay Lateral
TOTAL EVENTS	3			TOTAL GALLONS:	170			TOTAL DURATION:	4.50		

Wednesday, October 01, 2014

Note: Comments reflect status reported on the 5-Day report

Received
OCT 20 2014
6EN-W

OVERFLOW REPORT

PERIOD: September 2014

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
		593557	9/15/2014	BANDERA RD	10402	30	Debris	CLEANED LATERAL	1.55	GROUND	Area Cleaned and Disinfected, Unstopped Lateral
TOTAL EVENTS	1			TOTAL GALLONS:	30			TOTAL DURATION:	1.55		

Wednesday, October 01, 2014

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: September 2014

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	311277	583083	9/7/2014	CASTLE KNIGHT DR	5642	130	Grease	CLEANED MAIN	0.75	DRAINAGE CULVERT	Area Cleaned and Disinfected, Flushed Area with H2O
TOTAL EVENTS	1			TOTAL GALLONS:	130			TOTAL DURATION:	0.75		

Wednesday, October 01, 2014

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED:MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	DATE	ADDRESS	GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
TOTAL EVENTS		TOTAL GALLONS:					TOTAL DURATION:			

Wednesday, October 01, 2014

Note: Comments reflect status reported on the 5-Day report

Received
OCT 20 2014
6EN-W

OVERFLOW REPORT

PERIOD: October 2014

WATERSHED:MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
1049237			10/31/2014	US HWY 90 WEST	10102	250	Lift Station	CLEANED AREA	0.42	GROUND	- Reprimed Pumps #1 & #2 And Replaced Flapper Cup On Gasket On Pump #3. Work Order #1050649 Made To Replace Manhole Ring And Cover.
	315613	645808	10/27/2014	JARBO PASS	11322	150	Contractor	CLEANED AREA	0.37	STREET	Area Cleaned and Disinfected, Flushed Area with H2O - Bexar County Was Contacted About The Debris In The Sewer Line Due To Road Resurfacing
TOTAL EVENTS	2			TOTAL GALLONS:		400		TOTAL DURATION:	0.79		

Thursday, November 06, 2014

Note: Comments reflect status reported on the 5-Day report

Received
NOV 19 2014
6EN-W

OVERFLOW REPORT

PERIOD: October 2014

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	315108	638411	10/21/2014	CRYSTAL HILL	4707	20,000	Contractor	CLEANED AREA	5.20	GROUND	Area Cleaned and Disinfected, - Contractor Repaired Main. Contractor Was Counselled To Be Careful When Excavating Around Our Utilities
	314537	631917	10/15/2014	HARBOR VW	9127	400	Grease	CLEANED MAIN	3.10	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
	314495	631152	10/15/2014	YOLANDA	103	60	Debris	CLEANED MAIN	0.63	STORMDRAIN	Area Cleaned and Disinfected, Flushed Area with H2O
	314389	630591	10/14/2014	CAMINO REAL	3400	22,500	Roots	CLEANED MAIN	3.65	DRAINAGE CULVERT	Flushed Area with H2O
	314221	627459	10/12/2014	MEADOW STAR	7903	450	Grease	CLEANED MAIN	0.95	DRAINAGE CULVERT	Area Cleaned and Disinfected,
		627415	10/11/2014	QUINTANA RD	7703	88,600	I/I	DILUTED BY HEAVY RAIN WATER	11.07	CREEK BED	Monitored Area. 54" Siphon
	313470	617984	10/2/2014	BEARTRAP LN	7331	1,800	Debris	CLEANED MAIN	2.38	DRAINAGE CULVERT	Area Cleaned and Disinfected, Flushed Area with H2O
TOTAL EVENTS	7			TOTAL GALLONS:	133,810			TOTAL DURATION: 26.98			

Thursday, November 06, 2014

Note: Comments reflect status reported on the 5-Day report

Received
NOV 19 2014
6EN-W

OVERFLOW REPORT

PERIOD: October 2014

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	315538	643869	10/26/2014	DESERT VIEW DR	4410	50	Debris	CLEANED MAIN	4.40	ALLEY	Area Cleaned and Disinfected,
	315526	643838	10/25/2014	MESA LOOP	534	1,500	Contractor	CLEANED AREA	7.17	GROUND	- Contractor Has Repaired The Manhole.
	314889	635429	10/19/2014	SALISBURY DR	9831	100	Grease	CLEANED MAIN	2.43	GROUND	Area Cleaned and Disinfected,
	314521	632364	10/15/2014	MORGANS CIR	103	54,000	Contractor	CLEANED AREA	3.00	CREEK BED	Contractor Pulled Plug Out Of Main, Contractor Advised To Correct Their Pump Malfunction So The Capacity Of The Bypass Pumping System Is Sufficient.
	313556	619075	10/3/2014	ANTRIM	139	30	Debris	CLEANED MAIN	2.83	ALLEY	Area Cleaned and Disinfected, Flushed Area with H2O
TOTAL EVENTS	5			TOTAL GALLONS:	55,680			TOTAL DURATION:	19.83		

Thursday, November 06, 2014

Note: Comments reflect status reported on the 5-Day report

Received
NOV 10 2014
6EN-W

OVERFLOW REPORT

PERIOD: October 2014

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	315851	649525	10/29/2014	BRAZOS ST S	806	15	Debris	CLEANED MAIN	1.45	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
1047044	315393	643835	10/25/2014	SCHLEY AVE	1300	150	Structural	CLEANED MAIN	3.68	STREET	Area Cleaned and Disinfected, Flushed Area with H2O - Work Order Made To Repair Main.
	315197	640508	10/22/2014	SAN ANGELO	1825	10	Grease	CLEANED MAIN	0.25	GROUND	Area Cleaned and Disinfected, Flushed Area with H2O
	315161	636253	10/20/2014	GUS GARCIA	3	37	Roots	CLEANED MAIN	1.90	GROUND	Work Orders Made To Repair Laterals
	314787	634244	10/17/2014	FENFIELD AVE	1323	200	Debris	CLEANED MAIN	0.97	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
	314943	637046	10/20/2014	DELLWOOD	100	100	Debris	CLEANED MAIN	1.07	STORMDRAIN	Area Cleaned and Disinfected, Flushed Area with H2O
		638278	10/17/2014	ALAMO ST N	1500	100	Contractor	CLEANED AREA	0.02	STREET	Contractor Advised To Ensure Proper Connections On Pumps And Hoses
1043260	314305	628956	10/13/2014	EL MONTE BLVD	1330	100	Structural	CLEANED MAIN	1.93	EASEMENT	Area Cleaned and Disinfected, Work Order To Repair Broken Main.
1041737	314128	625242	10/9/2014	STRATFORD CT	416	40	Structural	REPAIRED MAIN	1.13	GROUND	Area Cleaned and Disinfected, Repaired Main, Flushed Area with H2O
1040810	313821	622575	10/7/2014	BOSWELL ST	400	350	Structural	CLEANED MAIN	1.78	CREEK BED	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
TOTAL EVENTS	10			TOTAL GALLONS:	1,102			TOTAL DURATION:	14.18		

Friday, November 07, 2014

Note: Comments reflect status reported on the 5-Day report

Received
NOV 19 2014
6EN-W

OVERFLOW REPORT

PERIOD: November 2014

WATERSHED:MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	317985	678075	11/23/2014	HUMMINGBIRD	1303	2,620	Debris	CLEANED MAIN	3.13	GROUND	Area Cleaned and Disinfected, Flushed Area with H2O
1054097		665653	11/12/2014	MOSS VALLEY DR	158	400	Structural	REPAIRED LATERAL	1.60	GROUND	Work Order Created To Repair Lateral
TOTAL EVENTS	2			TOTAL GALLONS:	3,020			TOTAL DURATION:	4.73		

Thursday, December 04, 2014

Note: Comments reflect status reported on the 5-Day report

Received
DEC 17 2014
6EN-W

OVERFLOW REPORT

PERIOD: November 2014

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	318573	682756	11/30/2014	SANTA CATALINA CV	4919	450	Debris	CLEANED MAIN	2.25	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
	318430	682481	11/27/2014	STARCREST DR	11400	300	Other	CLEANED MAIN	3.02	CREEK BED - DRY MUDD	Area Cleaned and Disinfected, Flushed Area with H2O
1057140	317806	675592	11/20/2014	SNELL DR	5666	188,500	Structural	INSTALLED BY-PASS PUMP	16.50	CREEK BED - ROSSILLO CREEK	Work Order Created To Repair Sewer Main
	316914	664348	11/11/2014	MARYMONT PARK	9255	2,475	Debris	CLEANED MAIN	3.07	GROUND	Area Cleaned and Disinfected,
1051755	316522	658731	11/6/2014	HIGHCLIFF DR	3930	53,500	Structural	CLEANED MAIN	2.80	DRAINAGE CULVERT	Made Work Order To Repair Main
		656325	11/4/2014	HOLBROOK	902	201,350	I/I	DILUTED BY HEAVY RAIN WATER	0.00	CREEK BED - SALADO CREEK	Monitored Area
		656308	11/4/2014	STARCREST DR	11400	59,700	I/I	DILUTED BY HEAVY RAIN WATER	0.00	CREEK BED - SALADO CREEK	Monitored Area
		656306	11/4/2014	ARION CIR	1074	137,000	I/I	DILUTED BY HEAVY RAIN WATER	0.00	CREEK BED - SALADO CREEK	Monitored Area
TOTAL EVENTS	8			TOTAL GALLONS:	643,275			TOTAL DURATION:	27.64		

Thursday, December 04, 2014

Note: Comments reflect status reported on the 5-Day report

Received
DEC 17 2014
GEN-W

OVERFLOW REPORT

PERIOD: November 2014

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	317188	668460	11/13/2014	OAK DR	7080	10	Debris	CLEANED MAIN	7.43	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
		659697	11/6/2014	QUINTANA RD	7707	170	I/I	DILUTED BY HEAVY RAIN WATER	2.70	GROUND	Monitored Area
TOTAL EVENTS	2			TOTAL GALLONS:	180			TOTAL DURATION:	10.13		

Thursday, December 04, 2014

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: November 2014

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	318486	682652	11/29/2014	YUCCA ST	216	25	Grease	CLEANED MAIN	0.95	STORMDRAIN	Area Cleaned and Disinfected,
1057976	317966	677968	11/22/2014	LEMING DR	310	150	Vandalism	CLEANED MAIN	1.63	STORMDRAIN	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Has Been Created To Install Mh Ring And Lock Cover
1055550	317330	669813	11/16/2014	NORMA ST	200	150	Structural	CLEANED MAIN	0.80	DRAINAGE CULVERT	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Has Been Created For Repairs
	316886	664304	11/11/2014	AGANIER AVE	402	844	Debris	CLEANED MAIN	6.20	GROUND	Area Cleaned and Disinfected, Flushed Area with H2O
TOTAL EVENTS	4			TOTAL GALLONS:	1,169			TOTAL DURATION:	9.58		

Thursday, December 04, 2014

Note: Comments reflect status reported on the 5-Day report

Received
DEC 17 2014
6EN-W

OVERFLOW REPORT

PERIOD: December 2014

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	327009	708722	12/26/2014	GOLIAD RD	3033	30	Grease	CLEANED MAIN	1.12	STORMDRAIN	Area Cleaned and Disinfected, Flushed Area with H2O
	326814	708648	12/24/2014	BURR RD	877	20	Debris	CLEANED MAIN	0.53	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
	319202	691554	12/8/2014	WOODLAWN RDG	23102	30	Debris	CLEANED MAIN	0.85	GROUND	Area Cleaned and Disinfected, Flushed Area with H2O
TOTAL EVENTS	3			TOTAL GALLONS:	80			TOTAL DURATION:	2.50		

Wednesday, January 07, 2015

Note: Comments reflect status reported on the 5-Day report

Received
JAN 18 2015
GEN-W

OVERFLOW REPORT

PERIOD: December 2014

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	327701	711235	12/30/2014	NEW BRAUNFELS AVE S	5717	640	Grease	CLEANED MAIN	1.07	STREET	Area Cleaned and Disinfected,
	327055	708707	12/26/2014	COUNTRY VILLAGE	8446	500	Grease	CLEANED MAIN	2.30	DRAINAGE CULVERT	Area Cleaned and Disinfected, Flushed Area with H2O
1067167	326239	707417	12/22/2014	DAHLGREEN AVE	1510	15	Structural	CLEANED AREA	0.70	STREET	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Made To Repair Main.
	326026	705921	12/19/2014	CHICAGO BLVD	903	50	Debris	CLEANED MAIN	2.47	GROUND	Spill Contained. Outside Contractor Cleaned Area
	319363	693418	12/9/2014	BLANCO RD	7208	2,200	Grease	CLEANED MAIN	1.40	DRAINAGE CULVERT	Area Cleaned and Disinfected,
	319373	692164	12/8/2014	LAKE BLVD	1322	10	Debris	CLEANED MAIN	1.85	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
	319186	690383	12/6/2014	AMIRES PLACE	445	15	Debris	CLEANED LATERAL	0.42	STREET	Area Cleaned and Disinfected, Flushed Area with H2O Unstopped Lateral
	318967	687506	12/3/2014	LOOP 410 NW	4257	15	Grease	CLEANED MAIN	0.30	STREET	Area Cleaned and Disinfected, Flushed Area with H2O
TOTAL EVENTS	8			TOTAL GALLONS:	3,445			TOTAL DURATION:	10.51		

Wednesday, January 07, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED:MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	DATE	ADDRESS	GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
TOTAL EVENTS				TOTAL GALLONS:			TOTAL DURATION:			

Wednesday, January 07, 2015

Note: Comments reflect status reported on the 5-Day report

Received

JAN 18 2015

6EN-W

OVERFLOW REPORT

PERIOD: December 2014

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	DATE	ADDRESS		GALLON	CAUSE	ACTION	HRS	DISCHARGED TO	COMMENTS
	327211	709080	12/29/2014	FAIRSHIRE	5900	32,750	Grease	CLEANED MAIN	4.07	CREEK BED - INDIAN CREEK	Area Cleaned and Disinfected,
	326374	707505	12/22/2014	ALI AVE	4902	4,000	Debris	CLEANED MAIN	1.18	DRAINAGE CULVERT	Area Cleaned and Disinfected,
TOTAL EVENTS	2			TOTAL GALLONS:	36,750			TOTAL DURATION:	5.25		

Wednesday, January 07, 2015

Note: Comments reflect status reported on the 5-Day report

Received
JAN 18 2015
6EN-W

Received

FEB 20 2015

6EN-W

OVERFLOW REPORT

PERIOD: JANUARY 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	331447	744036	1/30/2015	Sunbend Falls	1526	2	Grease	Cleaned Main	3.23	0.23	Street	Area Cleaned and Disinfected, Flushed Area with H2O
1076687	330920	736877	1/26/2015	Geneseo Rd	260	300	Structural	Repaired Main	8.10	3.35	Alley	Area Cleaned and Disinfected, Flushed Area with H2O - Work Order Created To Repair Sewer Main
	330691	734795	1/24/2015	Hays St	421	40	Debris	Cleaned Main	0.68	0.18	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
		732898	1/22/2015	Donaldson Ave	1710	46,690	I / I	Diluted By Heavy Rain Water	11.57	0.07	Street	Monitored Area
	330077	729900	1/20/2015	Cherry Ridge Dr	3201	20	Debris	Cleaned Main	0.45	0.45	Street	Area Cleaned and Disinfected, Flushed Area with H2O
1073933	329792	727258	1/16/2015	Travis W	3714	100	Structural	Cleaned Main	1.73	0.48	Alley	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Has Been Created For Repairs
1072487	329199	722240	1/13/2015	Morales	3215	75	Structural	Repaired Main	4.07	1.32	Street	Area Cleaned and Disinfected, - Work Order Created To Repair Sewer Main
1070880	328945	718373	1/8/2015	Dahlgreen Ave	1510	200	Structural	Cleaned Main	1.05	0.55	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Was Created For Repairs
	328430	714189	1/6/2015	Sylvanoaks	4207	50	Debris	Cleaned Main	0.80	0.30	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
	328380	714629	1/6/2015	Travis St W	1211	300	Grease	Cleaned Main	1.25	0.25	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	328266	712879	1/5/2015	Waverly	1039	1,500	Debris	Cleaned Main	2.32	1.82	Creek Bed - Spilled Into Alazan Creek	Area Cleaned and Disinfected, Flushed Area with H2O
	328256	713663	1/5/2015	Alice Fay Ave	403	3	Debris	Cleaned Main	3.45	1.45	Street	Area Cleaned and Disinfected,
Total Events:	12			**Total Gallons:**		49,280		**Total Duration:**	38.70			

OVERFLOW REPORT

PERIOD: JANUARY 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	331247	743525	1/30/2015	Canyon Golf 22601	75	Contractor	Cleaned Main	0.05	0.00	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
		732665	1/22/2015	Holbrook 668	30,000	I / I	Diluted By Heavy Rain Water	3.33	1.92	Creek Bed - Spilled Into Salado Creek	Monitored Area
	329706	725943	1/15/2015	Tuttle Rd 113	500	Vandalism	Cleaned Main	2.45	0.73	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	3			Total Gallons:	30,575		Total Duration:	5.83			

Wednesday, February 11, 2015

Note: Comments reflect status reported on the 5-Day report

Received
FEB 20 2015
6EN-W

Received
FEB 20 2015
6EN-W

OVERFLOW REPORT

PERIOD: JANUARY 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1076940			1/27/2015	Loop 410 Sw	8671	100	Lift Station	Replaced Ball Valve And Vinyl Hose On Pump #1 - Ls #225	0.03	0.00	Ground	Area Cleaned and Disinfected,
		734854	1/24/2015	Quintana Rd	7703	900	I / I	Monitored Area	1.50	0.58	Ground	Area Cleaned and Disinfected,
		711498	1/3/2015	Shadow Mist	999	972,400	Structural	Cleaned Area	1.07	1.07	Ground	Contractors Will Make Repairs.
	327884	711519	1/3/2015	Old Pearsall Rd	4820	2,200	Debris	Cleaned Main	2.43	0.60	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
	327926	711517	1/3/2015	Ih 10 W	14500	3,240	Grease	Cleaned Main	2.88	0.23	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	5			**Total Gallons:**		978,840		**Total Duration:**	7.91			

Thursday, February 12, 2015

Note: Comments reflect status reported on the 5-Day report

Received
FEB 20 2015
6EN-W

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Wednesday, February 11, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: FEBRUARY 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1084716		762684	2/16/2015	Culebra Rd	5518	2,000	Structural	Repaired Main	0.47	0.47	Ground	Work Order Created To Repair Sewer Force Main
	333428	762934	2/16/2015	Deer Horn	5807	200	Debris	Cleaned Main	2.00	0.90	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
1083350	333069	758598	2/11/2015	San Simeon	5334	40	Structural	Cleaned Main	1.02	0.52	Easement	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
1082362		754871	2/9/2015	Pleasanton Rd	12060	10	Structural	Repaired A/r Valve	1.85	1.25	Ground	Sewer Air Release Valve- Valve Was Turned Off- Work Order Created To Repair Sewer Air Release Valve
	331404	744711	2/1/2015	Babcock Rd	15500	2,850	Grease	Cleaned Main	1.57	0.57	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	5			Total Gallons:		5,100	Total Duration:		6.91			

Wednesday, March 04, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: FEBRUARY 2015

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1081881	331944	753163	2/7/2015	Angel Valley Dr	8802	5	Structural	Cleaned Main	0.95	0.70	Ground	Area Cleaned and Disinfected, Flushed Area with H2O 6 Inch Sewer Lateral - Unstopped Lateral - Work Order Created To Repair Lateral
Total Events:	1			Total Gallons:		5		Total Duration:	0.95			

Tuesday, March 03, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: FEBRUARY 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1089661		778871	2/28/2015	Grosvenor Blvd	1122	5	Structural	Repaired Lateral	0.53	0.17	Ground	Area Cleaned and Disinfected, Work Order Created To Repair Lateral
1089482		778269	2/27/2015	Woodlawn W	932	10	Structural	Repaired Lateral	0.87	0.37	Ground	Area Cleaned and Disinfected, Work Order Created To Repair Lateral
	335121	777944	2/27/2015	Barlite Blvd	7515	100	Grease	Cleaned Main	1.17	0.67	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
	334410	775697	2/25/2015	Fredericksburg Rd	2719	20	Grease	Cleaned Main	1.22	0.18	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	334118	771902	2/23/2015	Ih 35 N	2535	40	Grease	Cleaned Main	1.40	0.40	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	334131	772431	2/23/2015	Villa Verde	3	200	Grease	Cleaned Main	1.30	0.85	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
1087030	333948	770643	2/21/2015	Audubon S	203	30	Structural	Cleaned Main	4.85	1.35	Ground	Area Cleaned and Disinfected, Work Order Created To Repair Sewer Main
1085496	333455	765359	2/17/2015	Audubon S	203	50	Structural	Cleaned Main	3.85	0.77	Ground	Area Cleaned and Disinfected, Work Order Created To Repair Sewer Main
1084239	333242	761163	2/13/2015	Mertz Dr	9000	5	Structural	Cleaned Main	1.13	0.63	Alley	Area Cleaned and Disinfected, Repaired Main, Flushed Area with H2O Work Order Created To Repair Sewer Main
	332829	754227	2/9/2015	Chappie James Way	100	10	Debris	Cleaned Main	0.98	0.68	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	332329	753343	2/8/2015	New Braunfels Ave N	6800	1,500	Debris	Cleaned Main	0.62	0.12	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	11				Total Gallons:	1,970		Total Duration:	17.92			

Tuesday, March 03, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: FEBRUARY 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	333026	757261	2/10/2015	Sandman	11500	2	Debris	Cleaned Main	2.63	0.63	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
	331967	751530	2/5/2015	Goliad Rd	3401	31,875	Contractor	Cleaned Main	7.08	6.75	Ground	Contractor Installed A Bypass And Contractor Is To Hire A Contractor To Finish Cleaning The Sewer Main
	331934	752032	2/5/2015	Binz-engleman Rd	5895	13,500	Debris	Cleaned Main	2.22	0.47	Creek Bed-Spilled Into Rosillo Creek	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	3			Total Gallons:		45,377		Total Duration:	11.93			

Tuesday, March 03, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: MARCH 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1101866		817990	3/31/2015	Wetmore Rd	12133	1,590	Lift Station	Cleaned Area	0.88	0.22	Drainage Culvert	L S #111 - Grease Was Broken Up And Removed, Floats Were Tested And Verbatim Was Checked, Mechanical Was Operating Properly, Work Order Will Be Issued To Bolt Down 2 Manholes Upstream Of Lift Station
1098929	338264	811304	3/25/2015	Allen Chase	2	1,725	Structural	Cleaned Main	5.73	0.23	Ground	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
		805420	3/21/2015	Holbrook	900	3,240	I/I	Diluted By Heavy Rainwater	2.02	0.02	Creek Bed - Spilled Into Salado Creek	Monitored Area
	337727	805338	3/21/2015	Modesta Place	14203	6,300	Grease	Cleaned Main	2.57	0.82	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
	336366	792223	3/11/2015	Bitters Rd	841	3,500	Grease	Cleaned Main	0.58	0.43	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
	336239	791279	3/10/2015	Spotted Bear	107	50	Grease	Cleaned Main	1.43	0.93	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
	336237	790945	3/10/2015	Lindbergh Landing	8045	180	Debris	Cleaned Main	1.53	0.53	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
		789587	3/9/2015	Holbrook	902	690	I/I	Diluted By Heavy Rainwater	3.35	0.60	Creek Bed - Spilled Into Salado Creek	Monitored Area
	335559	786454	3/5/2015	Summer Wind St	9219	10	Grease	Cleaned Main	1.93	0.77	Street	Area Cleaned and Disinfected, Flushed Area with H2O

Total Events: 9	Total Gallons: 17,285	Total Duration: 20.02

Thursday, April 02, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: MARCH 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	346031	815297	3/30/2015	Old Gate	2507	1,155	Debris	Cleaned Main	1.27	1.02	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
	338007	809103	3/24/2015	Rexford	827	12,900	Debris	Cleaned Main	1.43	0.27	Alley	Area Cleaned and Disinfected, Flushed Area with H2O
	337707	805398	3/21/2015	Leal St	1337	20	Grease	Cleaned Main	2.60	2.10	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
	337706	805317	3/21/2015	Greenlawn	227	10	Debris	Cleaned Main	3.77	3.52	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
	337612	804160	3/20/2015	Jones Maltsberger Rd	8620	9,000	Debris	Cleaned Main	1.50	0.08	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
1094437	336506	794861	3/12/2015	Garcia St	519	1,500	Contractor	Cleaned Main	1.00	0.00	Ground	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
		793867	3/12/2015	Gibbs St	1342	30	Grease	Cleaned Lateral	0.92	0.42	Street	6 Inch Lateral, Unstopped Lateral
	336308	791900	3/11/2015	Vance Jackson	1106	200	Grease	Cleaned Main	1.12	0.78	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
	336207	790505	3/10/2015	Oakbrook	8903	50	Debris	Cleaned Main	2.73	1.73	Easement	Area Cleaned and Disinfected, Flushed Area with H2O
1094302	336233	791047	3/10/2015	Craig Place W	1224	300	Structural	Cleaned Main	1.00	0.00	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
	336236	791276	3/10/2015	Rigsby Ave	1889	100	Grease	Cleaned Main	0.68	0.43	Street	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	11			Total Gallons:		25,265	Total Duration:		18.02			

OVERFLOW REPORT

PERIOD: MARCH 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
✓	336718	796652	3/16/2015	Sid Katz	4711	7,100	Debris	Cleaned Main	0.85	0.52	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O Clean Up Still In Progress.
✓	336574	795629	3/14/2015	Bandera Rd	7730	56,200	Roots	Cleaned Main	4.68	2.77	Creek Bed - Spilled Into Leon Creek	Area Cleaned and Disinfected, Flushed Area with H2O Cleanup Efforts Ongoing
✓		789203	3/9/2015	Quintana Rd	7703	4,175	I/I	Diluted By Heavy Rainwater	2.78	0.27	Creek Bed - Spilled Into Leon Creek	Monitored Area
Total Events:	3				Total Gallons:	67,475		Total Duration:	8.31			

Thursday, April 02, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Wednesday, May 06, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: APRIL 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1113383		847071	4/27/2015	Palomino Bay	7327	330	Lift Station	Restored Power	5.75	0.00	Ground	Area Cleaned and Disinfected, Cps Energy Restored Power To The Lift Station #267
		847033	4/26/2015	Loop 410 Nw	7400	58,650	I/i	Diluted By Heavy Rain Water	18.25	4.17	Creek Bed - Spilled Into Leon Creek	Monitored Area
		846753	4/25/2015	Kim Valley	5802	7,500	I/i	Diluted By Heavy Rain Water	6.00	2.12	Ground	Monitored Area
		846752	4/25/2015	Yolanda	111	6,300	I/i	Diluted By Heavy Rain Water	10.50	0.25	Street	Monitored Area
	351375	845010	4/22/2015	Bennington Dr	5826	2,125	Debris	Cleaned Main	1.42	0.58	Easement	Area Cleaned and Disinfected, Flushed Area with H2O
	346318	820339	4/1/2015	Garrett Crk	12414	30	Grease	Cleaned Main	1.00	0.70	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	6				**Total Gallons:**	74,935		**Total Duration:**	42.92			

Wednesday, May 06, 2015

Note: Comments reflect status reported on the 5-Day report

Received
MAY 18 2015
GEN-W

OVERFLOW REPORT

PERIOD: APRIL 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
		846820	4/25/2015	Ira Lee Rd	200	1,010	I/i	Diluted By Heavy Rain Water	3.37	2.78	Ground	Monitored Area
		846788	4/25/2015	Arion Cir	1074	55,530	I/i	Diluted By Heavy Rain Water	9.85	7.10	Creek Bed - Spilled Into Salado Creek	Monitored Area
		846617	4/24/2015	Starcrest Dr	11400	107,730	I/i	Diluted By Heavy Rain Water	11.48	4.72	Creek Bed - Spilled Into Mud Creek	Monitored Area
		846664	4/24/2015	Holbrook	668	106,590	I/i	Diluted By Heavy Rain Water	20.17	0.83	Creek Bed - Spilled Into Salado Creek	Monitored Area
	348385	833250	4/13/2015	Gazelle Field	15	200	Vandalism	Cleaned Main	2.20	1.47	Ground	Area Cleaned and Disinfected, Flushed Area with H2O Locking Bolts Installed On Manhole #58909
		831732	4/13/2015	Holbrook	668	4,290	I/i	Diluted By Heavy Rain Water	2.77	2.02	Creek Bed - Spilled Into Salado Creek	Monitored Area
1105616		826492	4/7/2015	Loop 1604 N E	1010	3,875	Structural	Repaired A/r Valve	5.15	0.57	Ground	Area Cleaned and Disinfected, Flushed Area with H2O Force Main Air Release Sewer Valve Assembly - Work Order Created To Repair Force Main Air Release Sewer Valve Assembly

Total Events: 7	Total Gallons: 279,225	Total Duration: 54.99

Wednesday, May 06, 2015

Note: Comments reflect status reported on the 5-Day report

Received
MAY 18 2015
6EN-W

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Wednesday, May 06, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: APRIL 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1116707	353018	854670	4/30/2015	San Pedro Ave	6435	70	Structural	Cleaned Main	1.30	0.00	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O - Work Order Created To Repair Sewer Main
1113844		848264	4/27/2015	Zarzamora St S	8030	200	Structural	Cleaned Lateral	1.72	1.22	Street	Area Cleaned and Disinfected, Flushed Area with H2O 6 Inch Sewer Lateral - Cleaned Sewer Lateral - Work Order Created To Repair Sewer Lateral
		846741	4/25/2015	Arbor Place	2630	3,620	I/i	Diluted By Heavy Rain Water	6.03	2.03	Street	Monitored Area
		846835	4/25/2015	Mission Rd	1135	72,250	I/i	Diluted By Heavy Rain Water	3.33	0.83	Ground	Monitored Area
		846746	4/25/2015	Lombrano	1235	3,600	I/i	Diluted By Rain Water	6.00	3.80	Creek Bed (Spilled Into Alazan Creek)	Monitored Area
	351718	846844	4/25/2015	Ruiz St	726	30	Grease	Cleaned Main	0.98	0.75	Street	Area Cleaned and Disinfected, Flushed Area with H2O
		846610	4/24/2015	Avondale Ave	755	9,640	I/i	Diluted By Heavy Rain Water	10.84	3.28	Drainage Culvert	Monitored Area
		846699	4/24/2015	Cheryl Dr E	409	20,940	I/i	Diluted By Heavy Rain Water	13.40	0.65	Street	Monitored Area
	351228	841611	4/20/2015	Hunter Blvd	1439	1,500	Grease	Cleaned Main	1.77	1.22	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
1104792	346747	824081	4/6/2015	Mission Rd	1500	200	Contractor	Cleaned Main	5.50	0.33	Ground	Area Cleaned and Disinfected, Repaired Main, Flushed Area with H2O
	346617	823326	4/4/2015	Nueva W	402	300	Grease	Cleaned Main	3.68	0.43	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	11			**Total Gallons:**		112,350		**Total Duration:**	54.55			

Wednesday, May 06, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: MAY 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

Received JUN 22 2015 GEN

WO.#	INSRT#	SR/#	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
		890403	5/30/2015	Holbrook 668	191,040	I/i	Diluted By Heavy Rainwater	17.00	0.00	Creek Bed - Spilled Into Salado Creek	Monitored Area
		889330	5/29/2015	Holbrook 900	49,310	I/i	Diluted By Heavy Rainwater	6.19	2.50	Creek Bed - Spilled Into Salado Creek	Monitored Area
		884074	5/25/2015	Starcrest Dr 11401	525	I/i	Diluted By Heavy Rain Water	0.58	0.00	Creek Bedspilled Into Mud Creek	Monitored Area
		882675	5/25/2015	Arion Cir 1074	4,200	I/i	Diluted By Heavy Rain Water	4.67	0.00	Creek Bed - Spilled Into Salado Creek	Monitored Area
		882582	5/24/2015	Ira Lee Rd 173	52,250	I/i	Diluted By Heavy Rainwater	10.33	0.00	Creek Bed - Spilled Into Salado Creek	Monitored Area
1124610		888159	5/24/2015	Evans Rd E 4615	200	Lift Station	Repaired Faulty Equipment	0.33	0.00	Ground	Area Cleaned and Disinfected, Ls #235
		882358	5/23/2015	Holbrook 700	442,954	I/i	Diluted By Heavy Rainwater	59.88	0.63	Creek Bed - Spilled Into Salado Creek	Monitored Area
1123989	357147	876336	5/19/2015	Ih 35 N 9706	8,000	Structural	Cleaned Main	1.33	0.58	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
		873813	5/17/2015	Starcrest Dr 11401	286,800	I/i	Diluted By Heavy Rain Water	19.45	7.38	Creek Bed Spilled Into Mud Creek	Monitored Area
		873855	5/17/2015	Holbrook 902	94,980	I/i	Diluted By Heavy Rainwater	15.57	0.00	Creek Bed - Spilled Into Salado Creek	Monitored Area
		872635	5/15/2015	Holbrook 700	96,900	I/i	Diluted By Heavy Rain Water	8.80	4.30	Creek Bed - Spilled Into Salado Creek	Monitored Area
1118222		859348	5/5/2015	Southcross Ranch Rd 5365	12,850	Structural	Repaired Main	8.57	0.57	Ground	Area Cleaned and Disinfected, Flushed Area with H2O - Work Order Created To Repair Sewer Main

Total Events: 12	Total Gallons: 1,240,009	Total Duration: 152.70	-

Friday, June 12, 2015

Note: Comments reflect status reported on the 5-Day report

Received
JUN 22 2015
6EN-W

OVERFLOW REPORT

PERIOD: MAY 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1129152	✓		5/29/2015	38th St Sw	1033	675	Lift Station	Turned Off Air Release Valve	1.00	0.75	Stormdrain	Area Cleaned and Disinfected, The Air Release Valve Was Placed In The Off Position .saws Only Stocks 2" Arvs ; Therefore , A 3" Arv Will Be Purchased And Installed. Ls #248
	✓	889733	5/24/2015	Ih 10 W	23500	103,000	I/I	Diluted By Heavy Rain Water	112.08	0.00	Creek Bed - Spilled Into Leon Creek	Manholes Will Have Work Orders Issued To Repair Deficiencies, Area Will Be Cleaned And Disinfected After The Flood Waters Recede
1123175	✓	874608	5/17/2015	Ih 10 W *	23500	417,000	I/I	Diluted By Heavy Rain Water	34.75	0.00	Creek Bed - Spilled Into Leon Creek	An Emegency Project Is Under Construction To Repair The 24" Sewer Main
1123162	✓		5/17/2015	Loop 410 Access Rd Sw	8671	500	Lift Station	Restored Power	0.42	0.00	Ground	Area Cleaned and Disinfected, Ls #225
1123152	✓	873781	5/17/2015	Kim Valley	5802	8,050	I/I	Diluted By Heavy Rain Water	2.68	1.60	Creek Bed - Spilled Into Indian Creek	Monitored Area
✓	353805	856337	5/1/2015	Amberwood Dr	6203	21,300	Grease	Cleaned Main	4.50	0.12	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	6			Total Gallons:		550,525		Total Duration:	155.43			

Thursday, June 11, 2015

Note: Comments reflect status reported on the 5-Day report

* See NOR dated 5/22/2015 + 6/5/2015

OVERFLOW REPORT

PERIOD: MAY 2015

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1123163			5/17/2015	Valley Hi Dr	818	9,450	Lift Station	Restored Power	0.45	0.35	Ground	Area Cleaned and Disinfected, Ls #188
Total Events:	1			Total Gallons:		9,450		Total Duration:	0.45			

Thursday, June 11, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: MAY 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
1126884	357959	884485	5/26/2015	Contour Dr E	715	30,900	Structural	Cleaned Main	4.43	3.68	Ground	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
	357866	884194	5/26/2015	Betty Jean	2438	36,550	Structural	Cleaned Main	4.52	0.52	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
	357729	882663	5/25/2015	Silver Arrow	9014	640	Debris	Cleaned Main	2.13	0.18	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
	357656	882534	5/24/2015	San Francisco	1318	200	Debris	Cleaned Main	0.45	0.12	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
		882484	5/24/2015	Avondale Ave	755	55,300	I/i	Diluted By Heavy Rainwater	18.43	5.18	Stormdrain	Monitored Area
		882458	5/24/2015	Flores St S	2900	12,900	I/i	Diluted By Heavy Rainwater	4.30	2.80	Ground	Monitored Area
		883703	5/24/2015	Valley Rd	3495	538,600	I/i	Diluted By Heavy Rainwater	1.00	0.00	Drainage Culvert-spilled Into Medina River	Monitored Area
	357664	882556	5/24/2015	Alamo St N	2222	33,550	I/i	Cleaned Main	3.28	0.28	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
		882408	5/23/2015	Buena Vista St	1333	56,400	I/i	Diluted By Heavy Rain Water	6.27	1.93	Creek Bed-spilled Into Alazan Creek	Monitored Area
		882393	5/23/2015	Hedges St	1600	32,900	I/i	Diluted By Heavy Rain Water	5.48	1.82	Street	Monitored Area
		882384	5/23/2015	Fresno	630	75,600	I/i	Diluted By Heavy Rain Water	6.30	0.72	Drainage Culvert	Monitored Area
		882375	5/23/2015	Pinewood Ln	202	1,725	I/i	Diluted By Heavy Rain Water	1.15	0.40	Stormdrain	Monitored Area
		882394	5/23/2015	Crystal	804	41,850	I/i	Diluted By Heavy Rain Water	9.30	2.67	Ground	Monitored Area
		882409	5/23/2015	Hearne	114	37,625	I/i	Diluted By Heavy Rain Water	3.58	0.33	Stormdrain	Monitored Area

TX77801

✓		873836	5/17/2015	Cheryl Dr E	409	25,335	I/I	Diluted By Heavy Rain Water	6.38	0.63	Street		Monitored Area
✓		873778	5/17/2015	Arbor Place	2630	195	I/I	Diluted By Heavy Rain Water	0.65	0.00	Drainage Culvert		Monitored Area
✓		873088	5/15/2015	Cheryl Dr E	409	41,075	I/I	Diluted By Heavy Rain Water	4.42	0.35	Ground		Monitored Area
		872978	5/15/2015	Piedmont Ave	4201	9,750	I/I	Diluted By Heavy Rainwater	1.08	0.00	Street		Monitored Area
✓	356824	871517	5/14/2015	Northill Dr	207	140	Debris	Cleaned Main	1.17	0.42	Alley		Area Cleaned and Disinfected, Flushed Area with H2O
✓	356695	870534	5/14/2015	Linda Lou Dr	624	100	Grease	Cleaned Main	1.05	0.68	Street		Area Cleaned and Disinfected, Flushed Area with H2O
1119232	✓	862767	5/7/2015	Hackberry St N	1306	251	Structural	Repaired Main	4.18	0.18	Stormdrain		Area Cleaned and Disinfected, - Work Order Created To Repair Sewer Main
✓	355721	861521	5/6/2015	Plymouth	9615	50	Grease	Cleaned Main	0.98	0.48	Street		Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	22			Total Gallons:		1,031,636		Total Duration:		90.53			

Thursday, June 11, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Thursday, June 11, 2015

Note: Comments reflect status reported on the 5-Day report

Received
JUL 16 2015
OBN-W

OVERFLOW REPORT

PERIOD: JUNE 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
		914476	6/17/2015	Yolanda	111	9,600	I/I	Diluted By Heavy Rainwater	2.00	0.62	Drainage Culvert	Monitored Area
		896594	6/1/2015	Ih 10 W	23500	95,880	I/I	Area Will Be Cleaned And Disinfected After The Flood Waters Recede	50.50	0.00	Creek Bed(Spilled Into Leon Creek)	Manholes Were Raised, A Low Water Crossing In The Area Was Cut Open To Allow The Creek To Flow Through
Total Events:	2			Total Gallons:		105,480		Total Duration:	52.50			

Monday, July 06, 2015

Note: Comments reflect status reported on the 5-Day report

Received
JUL 16 2015
GEN-W

OVERFLOW REPORT

PERIOD: JUNE 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	361951	930626	6/30/2015	Mission Rdg	15751	2,000	Vandalism	Cleaned Main	1.33	0.83	Drainage Culvert	Diluted By Heavy Rainwater, Area Cleaned, The Contained Diluted Sewage Was Vacuumed Up
1139854		918610	6/22/2015	Holbrook	700	90,200	I/I	Cleanup Is On-going And Fresh Soil Is Being Placed To Bring The Area Back To Natural Grade	16.57	0.57	Creek Bed (Spilled Into Salado Creek)	Work Order Created To Repair Manhole Ring And Cover
		917555	6/21/2015	Holbrook	668	9,000	I/I	Diluted By Heavy Rain Water	10.00	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area
		917508	6/20/2015	Holbrook	668	9,000	I/I	Diluted By Heavy Rain Water	10.00	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area
		916310	6/19/2015	Harry Wurzbach	1427	2,600	I/I	Diluted By Heavy Rain Water	2.17	0.00	Drainage Culvert	Monitored Area
		916690	6/19/2015	Arion Cir	1074	7,500	I/I	Diluted By Heavy Rain Water	5.00	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area
		916338	6/19/2015	Ira Lee Rd	200	43,500	I/I	Diluted By Heavy Rain Water	7.25	0.00	Street	Monitored Area
		916839	6/19/2015	Holbrook	700	43,750	I/I	Diluted By Heavy Rain Water	14.58	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area
1138324		915304	6/17/2015	Pyrite Loop	6138	850	Lift Station	Diluted By Heavy Rainwater, Also Disinfected Area	0.57	0.00	Ground	Restored The Power To Lift Station #261
		914530	6/17/2015	Starcrest Dr	11400	4,950	I/I	Diluted By Heavy Rain Water	2.75	0.00	Ground	Monitored Area
1136547		911651	6/14/2015	Eagle Crk	3540	10,100	Lift Station	Lift Station Honeywagon Removed Several Loads From The Wet Well	3.37	0.00	Drainage Culvert	Power Was Restored By Cps Energy Ls #156
		908801	6/14/2015	Arrowhead Dr	83	204	Other	Diluted By Heavy Rainwater	3.40	0.60	Stormdrain	Monitored Area
	359612	904742	6/10/2015	La Pena Dr	21023	2,620	Debris	Cleaned Main	8.73	1.07	Drainage Culvert	Cleanup Efforts Are Ongoing

TX 52647

✓	359416	902789	6/9/2015	Rimcrest Dr	10606	25	Debris	Cleaned Main	3.60	1.85	Easement	Area Cleaned and Disinfected, Flushed Area with H2O
✓	358928	896534	6/4/2015	Benham	4903	100	Grease	Cleaned Main	0.98	0.52	Street	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	15			Total Gallons:	226,399		Total Duration:	90:30				

Monday, July 06, 2015

Note: Comments reflect status reported on the 5-Day report

Received
JUL 10 20
GEN-W

OVERFLOW REPORT

PERIOD: JUNE 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	361422	923482	6/25/2015	Commerce St W	4303	2,000	Grease	Cleaned Main	0.67	0.42	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	360992	919325	6/22/2015	Mossrock	2639	75	Debris	Cleaned Main	1.80	1.30	Street	Area Cleaned and Disinfected, Flushed Area with H2O
		916303	6/19/2015	Manor Dr	908	135	I/I	Diluted By Heavy Rainwater	2.25	0.00	Street	Monitored Area
		914487	6/17/2015	Kampmann Blvd	310	27,000	I/I	Diluted By Heavy Rain Water	3.00	2.02	Creek Bed (Spilled Into Woodlawn Lake)	Monitored Area
	360216	912741	6/16/2015	San Francisco	1426	120	Debris	Cleaned Main	1.05	0.48	Street	Area Cleaned and Disinfected, Flushed Area with H2O
		910640	6/14/2015	Mission Rd	1135	15,000	I/I	Diluted By Heavy Rain Water	2.50	0.00	Stormdrain	Monitored Area
		908788	6/14/2015	Woodlawn W	2302	24,200	I/I	Diluted By Heavy Rain Water	4.03	0.47	Creek Bed (Spilled Into Woodlawn Lake)	Monitored Area
		908767	6/14/2015	Tulane	407	8,025	I/I	Diluted By Heavy Rainwater	5.35	1.40	Street	Monitored Area
		908796	6/14/2015	Cheryl Dr E	409	2,475	I/I	Diluted By Heavy Rain Water	1.65	0.10	Street	Monitored Area
		908763	6/14/2015	Poplar St W	2204	24,625	I/I	Diluted By Heavy Rain Water	3.28	0.53	Creek Bed (Spilled Into Alazan Creek)	Monitored Area
		908811	6/14/2015	Leal St	1026	28,500	I/I	Diluted By Heavy Rain Water	4.75	1.23	Creek Bed (Spilled Into Alazan Creek)	Monitored Area
		908780	6/14/2015	Lombrano	1235	9,000	I/I	Diluted By Heavy Rain Water	6.00	1.92	Creek Bed (Spilled Into Alazan Creek)	Monitored Area
Total Events:	12			Total Gallons:		141,155		Total Duration:	36.33			

Monday, July 06, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Monday, July 06, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:				Total Gallons:			Total Duration:				

Monday, July 06, 2015

Note: Comments reflect status reported on the 5-Day report

Received
JUL 16 2015
6EN-W

OVERFLOW REPORT

PERIOD: JULY 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	365964	970082	7/30/2015	Mission Rd	1515	200,575	Structural	Repaired Main	7.00	0.00	Creek Bed (Spilled Into San Antonio River)	Area Cleaned and Disinfected, Flushed Area with H2O A Blind Flange And Cap Were Installed On The Two (2) Pipes From The Abandoned Lift Station That Were Connected To The 54-inch Sewer Main.
	364888	958426	7/22/2015	Martin St W	4215	90	Roots	Cleaned Main	0.92	0.17	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
	363916	950047	7/15/2015	Alamo St N	2222	1,830	Grease	Cleaned Main	5.08	0.00	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
	363901	947902	7/15/2015	Blanco Rd	2922	120	Grease	Cleaned Main	1.00	0.75	Street	Area Cleaned and Disinfected, Flushed Area with H2O
1145226		934777	7/2/2015	Industrial Vw	303	50	Lift Station	Replaced Broken Discharge Pipe On Gravity Line	0.00	0.00	Ground	Broken Discharge Pipe On Gravity Line Was Replaced With New 4-inch Pipe Including Unions That Replaced The Leaking Cap Ls#313, Area Cleaned And Disinfected
Total Events:	5				Total Gallons:	202,665		Total Duration:	14.00			

Wednesday, August 05, 2015

Note: Comments reflect status reported on the 5-Day report

Received
AUG 17 2015
6EN-W

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Wednesday, August 05, 2015

Note: Comments reflect status reported on the 5-Day report

Received
AUG 17 2015
6EN-W

OVERFLOW REPORT

PERIOD: JULY 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
✓	365349	964734	7/28/2015	Greencastle Dr	6815	30	Grease	Cleaned Main	2.68	1.68	Alley	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	1			Total Gallons:		30		Total Duration:	2.68			

Wednesday, August 05, 2015

Note: Comments reflect status reported on the 5-Day report

Received
AUG 17 2015
6EN-W

OVERFLOW REPORT

PERIOD:

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:				Total Gallons:			Total Duration:				

Wednesday, August 05, 2015

Note: Comments reflect status reported on the 5-Day report

Received
AUG 17 2015
6EN-W

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:				Total Gallons:			Total Duration:				

Wednesday, August 05, 2015

Note: Comments reflect status reported on the 5-Day report

Received
AUG 17 2015
GEN-W

OVERFLOW REPORT

PERIOD: AUGUST 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	373764	1008823	8/31/2015	Apple Valley Dr	6219	2	Grease	Cleaned Lateral	2.50	1.25	Alley	Area Cleaned and Disinfected, Flushed Area with H2O 6 Inch Sewer Lateral - Unstopped Lateral
	371422	990825	8/17/2015	Loop 410 Nw	7007	8,500	Grease	Cleaned Main	1.42	0.50	Creek Bed (Spilled Into Leon Creek)	Area Cleaned and Disinfected, Flushed Area with H2O
	371337	989135	8/16/2015	Wiseman Blvd	3600	1,780	Debris	Cleaned Main	1.48	0.65	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
	368305	983697	8/11/2015	Seacliff	8955	24,000	Debris	Cleaned Main	1.33	0.00	Creek Bed (Spilled Into Indian Creek)	Area Cleaned and Disinfected, Flushed Area with H2O
1160186		978377	8/6/2015	Pleasanton Rd	10762	80	Other	The Lift Station Pump Was Turned Off As Well As The 4 Inch Isolation Valve	0.03	0.00	Ground	Area Cleaned And Disinfected. Ls# 192
Total Events:	5				Total Gallons:	34,362		Total Duration:	6.76			

Wednesday, September 09, 2015

Note: Comments reflect status reported on the 5-Day report

Received
SEP 21 2015
GEN-W

pdf

OVERFLOW REPORT

PERIOD: AUGUST 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	373598	1007495	8/28/2015	West Ave	12798	100	Grease	Cleaned Main	1.35	0.83	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	372512	993116	8/18/2015	Trophy Rdg	17	660	Debris	Cleaned Main	10.33	1.52	Creek Bed (Spilled Into Dry Mudd Creek)	Area Cleaned and Disinfected, Flushed Area with H2O
	371420	990470	8/17/2015	Perrin Beitel	11612	8,400	Grease	Cleaned Main	0.70	0.37	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	3			Total Gallons:		9,160		Total Duration:	12.38			

Wednesday, September 09, 2015

Note: Comments reflect status reported on the 5-Day report

Received
SEP 18 2015
M-NEO

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Wednesday, September 09, 2015

Note: Comments reflect status reported on the 5-Day report

Received
SEP 21 2015
6EN-W

OVERFLOW REPORT

PERIOD: AUGUST 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
		1008858	8/31/2015	Escalon Ave	230	5 Debris	Cleaned Lateral	1.52	0.68	Ground	Unstopped 6" Lateral
	373765	1009413	8/31/2015	Travis St W	1714	555 Grease	Cleaned Main	1.85	0.60	Creek Bed(Spilled Into Alazan Creek)	Area Cleaned and Disinfected, Flushed Area with H2O The 8" Siphon Was Cleaned
	373674	1007855	8/29/2015	24th St Nw	602	595 Grease	Cleaned Lateral	2.02	1.77	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events: 3				Total Gallons:		1,155	Total Duration:	5.39			

Wednesday, September 09, 2015

Note: Comments reflect status reported on the 5-Day report

Received
SEP 21 2015
GEN-W

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Wednesday, September 09, 2015

Note: Comments reflect status reported on the 5-Day report

Received
SEP 21 2015
GEN-W

pdf

OVERFLOW REPORT

PERIOD: SEPTEMBER 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	382525	1045428	9/28/2015	Hermosa W	535	4,175	Debris	Cleaned Main	2.78	0.78	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
1186692		1042972	9/24/2015	Elmira St W	618	20	Structural	Repaired Lateral	0.33	0.00	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair 6" Lateral
1186811		1042510	9/24/2015	Weizmann	907	20	Structural	Repaired Lateral	8.67	1.42	Ground	Area Cleaned and Disinfected, Work Order Created To Repair Broken 6" Lateral
	381547	1030382	9/17/2015	Lennon Ave	1830	75	Grease	Cleaned Main	0.90	0.53	Street	Area Cleaned and Disinfected, Flushed Area with H2O
		1022614	9/10/2015	El Monte Blvd	303	300	I/i	Diluted By Heavy Rain Water	0.17	0.00	Street	8" Main Monitored Area
1180736		1018815	9/9/2015	Flores St N	6410	1,000	Structural	Repaired Main	1.50	0.00	Street	Area Cleaned And Disinfected, Work Order Created To Repair Sewer Main
1178370	374500	1016494	9/4/2015	Mayfield Blvd W	1807	25	Structural	Repaired Lateral	1.17	0.75	Ground	Area Cleaned and Disinfected, Flushed Area with H2O Unstopped 6" Lateral, Work Order Created To Repair Lateral
	374832	1016661	9/5/2015	Lincolnshire Dr	534	25	Grease	Cleaned Main	1.23	0.68	Street	Area Cleaned and Disinfected, Flushed Area with H2O
	374392	1014157	9/3/2015	Ridgemont Ave	101	3	Debris	Cleaned Main	2.15	1.15	Ground	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	9			Total Gallons:		5,643		Total Duration:	18.90			

RECEIVED
OCT 19 2015

Thursday, October 01, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: SEPTEMBER 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	382461	1045117	9/27/2015	Meadow Corner	0	1,000	Grease	Cleaned Main	1.13	0.63	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
	381850	1036089	9/21/2015	Loop 410 Sw	231	5,686	Grease	Cleaned Main	0.63	0.47	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
	375113	1017357	9/8/2015	Norman Ln	7211	4,250	Grease	Cleaned Main	1.42	0.92	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O
1173723		1011090	9/1/2015	Pleasanton Rd	10750	140,000	Structural	Replaced A/r Valve	2.55	0.00	Ground	Replaced Unmapped Sewer Air Release Valve.
Total Events:	4				**Total Gallons:**	150,936		**Total Duration:**	5.73			

Thursday, October 01, 2015

Note: Comments reflect status reported on the 5-Day report

Received
OCT 19 2015
6EN-W

OVERFLOW REPORT

PERIOD: SEPTEMBER 2015

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	381858	1036731	9/21/2015	Walnut Crest	10402	6,750	Grease	Cleaned Main	2.25	0.83	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O
1174773		1015451	9/3/2015	Adams Hill Dr	9500	1,355	Structural	Repaired Main	4.52	0.00	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O Work Order Created To Repair Sewer Main
Total Events:	2			Total Gallons:		8,105		Total Duration:	6.77			

Thursday, October 01, 2015

Note: Comments reflect status reported on the 5-Day report

Received
OCT 19 2015
6EN-W

OVERFLOW REPORT

PERIOD: SEPTEMBER 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
	381340	1027700	9/15/2015	Hialeah Ave	231	25	Grease	Cleaned Main	3.75	1.77	Alley	Area Cleaned and Disinfected, Flushed Area with H2O
Total Events:	1			Total Gallons:		25		Total Duration:	3.75			

Thursday, October 01, 2015

Note: Comments reflect status reported on the 5-Day report

Received
OCT 19 2015
6EN-W

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Total Duration:					

Thursday, October 01, 2015

Note: Comments reflect status reported on the 5-Day report

Received
OCT 19 2015
6EN-W

OVERFLOW REPORT

PERIOD: OCTOBER 2015

WATERSHED: SALADO CREEK

TCEQ PERMIT # 10137-008

EPA PERMIT # 0052647

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
		1076132	10/30/2015	Holbrook	700	207,000	I/i	The Area Will Be Cleaned And Disinfected After The Flood Waters Recede	24.45	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area. Saws Is In The Process Of Engaging An Engineering Firm To Design The Remedial Measure To Address This Issue. 48 Inch Sewer Main
		1072848	10/24/2015	Holbrook	700	180,545	I/i	Diluted By Heavy Rainwater, Clean-up I S Ongoing And Area Has Been Brought Back To Natural Grade	14.73	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area, Saws Is In The Process Of Engaging An Engineering Firm To Design The Remedial Measure To Address This Issue 48 Inch Sewer Main
		1070559	10/24/2015	Farview Ln	12251	1,335	I/i	Diluted By Heavy Rainwater	4.45	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area 8 Inch Sewer Main
		1070539	10/24/2015	Wurzbach Pkwy	11601	1,575	I/i	Diluted By Heavy Rainwater	5.25	0.00	Creek Bed (Spilled Into Salado Creek)	Monitored Area 27 Inch Sewer Main
	384416	1070581	10/24/2015	La Bahia	12510	1,850	Vandalism	Cleaned Main	9.17	8.15	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O 12 Inch Sewer Main
	383982	1065031	10/19/2015	Barrington	3803	10	Grease	Cleaned Main	1.80	0.33	Ground	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main

Total Events:	6	Total Gallons:	392,315	Average Duration:	9.98

Wednesday, November 04, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD: OCTOBER 2015

WATERSHED: DOS RIOS

TCEQ PERMIT # 10137-033

EPA PERMIT # 0077801

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
		1076082	10/30/2015	San Bernardo S	851	16,200	I/i	Diluted By Heavy Rainwater	2.70	1.20	Street	12 Inch Sewer Main Monitored Area
	384983	1077031	10/30/2015	Margaret	101	2,900	Grease	Cleaned Main	1.02	0.43	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O 10 Inch Sewer Main
	384978	1074088	10/28/2015	Aganier Ave	101	15	Debris	Cleaned Main	0.75	0.63	Street	Area Cleaned and Disinfected, 12 Inch Sewer Main
1203572	384840	1073859	10/28/2015	Waverly	1039	25	Contractor	Repaired Main	1.08	0.58	Creek Bed (Spilled Into Alazan Creek)	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main Work Order Created To Repair Siphon Pipe
	384541	1070824	10/25/2015	Calmar	126	200	Grease	Cleaned Main	1.67	0.25	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main
		1070532	10/24/2015	Crystal	804	4,500	I/i	Diluted By Heavy Rainwater	3.00	0.00	Street	10 Inch Sewer Main Monitored Area
		1070569	10/24/2015	Kampmann Blvd	310	498	I/i	Diluted By Heavy Rainwater	4.15	3.40	Street (Spilled Into Woodlawn Lake)	18" Main Monitored Area
		1070575	10/24/2015	Mccullough Ave	8210	40,400	I/i	Diluted By Heavy Rainwater	3.30	0.00	Stormdrain	15 Inch Sewer Main Monitored Area
		1070550	10/24/2015	Elmendorf N	1300	20,300	I/i	Diluted By Heavy Rainwater	3.38	3.63	Creek Bed (Spilled Into Alazan Creek)	24 Inch Sewer Main Monitored Area
		1070443	10/24/2015	Lombrano	1200	74,000	I/i	Diluted By Heavy Rainwater	4.08	0.00	Creek Bed (Spilled Into Alazan Creek)	8 Inch Sewer Main Monitored Area
		1070655	10/24/2015	Mission Rd	1151	25,590	I/i	Diluted By Heavy Rainwater	7.25	0.00	Ground	54 Inch Sewer Main Monitored Area
	384289	1068759	10/22/2015	Commerce St E	3138	3,200	Debris	Cleaned Main	1.32	0.83	Drainage Culvert	Area Cleaned and Disinfected, Flushed Area with H2O 12 Inch Sewer Main
	383924	1064606	10/18/2015	Poplar St W	2128	10	Grease	Cleaned Main	1.15	0.65	Street	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main

	383878	1064479	10/17/2015	Holder Ave	506	5	Grease	Cleaned Main	1.60	1.10	Alley	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main
	383625	1061637	10/14/2015	Newson	226	20	Debris	Cleaned Main	0.52	0.45	Street	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main
	383338	1058682	10/10/2015	Jean St	203	5	Grease	Cleaned Main	0.75	0.50	Stormdrain	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main
1194214	383235	1055995	10/7/2015	Hermitage Ct	211	100	Other	Cleaned Main	0.25	0.00	Alley	Area Cleaned and Disinfected, Repaired Main, Flushed Area with H2O 6 Inch Sewer Main
	382988	1052624	10/5/2015	New Braunfels Ave S	5717	1,475	Debris	Cleaned Main	1.90	0.40	Street	Area Cleaned and Disinfected, Flushed Area with H2O 8 Inch Sewer Main
	382914	1052097	10/3/2015	Parkdale	3800	24,450	Grease	Cleaned Main	3.30	0.80	Drainage Culvert	Flushed Area with H2O 12 Inch Sewer Main Cleanup Efforts Are Ongoing

Total Events:	19	Total Gallons:	213,893	Average Duration:	2.27

Wednesday, November 04, 2015

Note: Comments reflect status reported on the 5-Day report

OVERFLOW REPORT

PERIOD:

WATERSHED: SUBSCRIBER

TCEQ PERMIT # Subscriber

EPA PERMIT # Subscriber

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Average Duration:					

Wednesday, November 04, 2015

Note: Comments reflect status reported on the 5-Day report

Received
NOV 16 2015
GLN-W

OVERFLOW REPORT

PERIOD: OCTOBER 2015

WATERSHED: LEON CREEK

TCEQ PERMIT # 10137-003

EPA PERMIT # 0052639

WO #	INSPT#	SR #	Date	Address		Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
		1077203	10/31/2015	Loop 410 Nw	7300	886	I/i	Diluted By Heavy Rainwater	14.77	5.68	Creek Bed (Spilled Into Leon Creek)	66 Inch Sewer Main Monitored Area
		1077900	10/30/2015	Ih 10 W	23500	67,200	I/i	Area Will Be Cleaned And Disinfected After Flood Water Recede	5.00	0.00	Creek Bed (Spilled Ino Leon Creek)	24 Inch Sewer Main
Total Events:	2			Total Gallons:		68,086		Average Duration:	9.89			

Wednesday, November 04, 2015

Note: Comments reflect status reported on the 5-Day report

RECEIVED
NOV 05 2015
GENV

OVERFLOW REPORT

PERIOD:

WATERSHED: MEDIO CREEK

TCEQ PERMIT # 10137-040

EPA PERMIT # 0055689

WO #	INSPT#	SR #	Date	Address	Gallons	Cause	Action	Duration	Response Time	Discharged To	Comments
Total Events:			Total Gallons:			Average Duration:					

Wednesday, November 04, 2015

Note: Comments reflect status reported on the 5-Day report

Received
DEC 10 2015
CERTIFIED