PERMIT NO. HI 0020877

AUTHORIZATION TO DISCHARGE UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Clean Water Act, as amended, (33 U.S.C. §1251 et seq.; the "Act"); Hawaii Revised Statutes (HRS), Chapter 342D; and Hawaii Administrative Rules (HAR), Chapters 11-54 and 11-55, Department of Health (DOH), State of Hawaii,

CITY AND COUNTY OF HONOLULU
DEPARTMENT OF ENVIRONMENTAL SERVICES

(hereinafter PERMITTEE),

is authorized to discharge treated wastewater to the receiving waters named Mamala Bay, Pacific Ocean through Outfall Serial No. 001 at Latitude 21°16'47"N and Longitude 158°01'40"W,

from its Honouliuli Wastewater Treatment Plant Located at 91-1000 Geiger Road, Ewa Beach, Hawaii, 96706,

in accordance with the effluent limitations, monitoring requirements and other conditions set forth herein, and in the DOH "Standard NPDES Permit Conditions," that is available on the DOH, Clean Water Branch (CWB) website at http://health.hawaii.gov/cwb/site-map/home/standard-npdes-permit-conditions/.

All references to Title 40 of the Code of Federal Regulations (CFR) are to regulations that are in effect on July 1, 2013, except as otherwise specified. Unless otherwise specified herein, all terms are defined as provided in the applicable regulations in Title 40 of the CFR.

This permit, including the Zone of Mixing, became effective on **March 30, 2014.**

A minor permit modification (Pages 4, 19, 21, and 56), became effective on April 17, 2014.

This minor permit modification (Pages 3 and 4) became effective on March 30, 2014.

This permit, including the Zone of Mixing, and the authorization to discharge will expire at midnight, **February 27, 2019**

Signed this 28th day of April, 2014.

Alan Wong
(For) Director of Health

FINAL PERMIT
February 28, 2014

This Page was modified on April 28, 2014.

TABLE OF CONTENTS

PART A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

PART B. WHOLE-EFFLUENT TOXICITY REQUIREMENTS

1. Monitoring Frequency
2. Test Species and Methods
3. Chronic WET Permit Limit
4. Quality Assurance
5. Initial Investigation TRE Work Plan
6. Accelerated Toxicity Testing and TRE/TIE Process
7. Reporting of Chronic Toxicity Monitoring Results
8. Permit Reopener for Chronic Toxicity

PART C. WATER QUALITY CRITERIA

PART D. ZONE OF INITIAL DILUTION AND ZONE OF MIXING LIMITATIONS

PART E. RECEIVING WATER MONITORING PROGRAM REQUIREMENTS

PART F. WASTEWATER POLLUTION PREVENTION PROGRAM

PART G. PRETREATMENT REQUIREMENTS

PART H. SLUDGE/BIOSOLIDS REQUIREMENTS

PART I. REPORTING REQUIREMENTS

1. Schedule of Compliance
2. Transmittal and Monitoring Results Reporting Requirements
3. Reporting of Noncompliance, Unanticipated Bypass, or Upset
4. Other Reporting Requirements
5. Planned Changes
6. Types of Sample

PART J. SPECIAL CONDITIONS

PART K. LOCATION MAP, ZOM MAP, FACILITY FLOW DIAGRAM, AND FACILITY SITE MAP

APPENDIX 1. MONITORING METHODS

ATTACHMENT: STANDARD NPDES PERMIT CONDITIONS (VERSION 14)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning with the effective date of this permit and lasting until the expiration date of this permit, the Permittee is authorized to discharge treated wastewater from Outfall Serial No. 001. The discharge shall be limited and monitored as specified below.

Effluent Characteristics	Discharge Limitations[1]				Monitoring Requirements	
	Average Monthly	Average Weekly	Maximum Daily	Units	Measurement Frequency	Sample Type
Flow	[2]	[2]	[2]	MGD	Continuous/ Estimate[3]	--
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	30	45	[2]	mg/L	Daily[3]	24-Hour Composite
	9,508	14,261	[2]	lbs/day		
	The average monthly percent removal shall not be less than 85 percent					
Total Suspended Solids (TSS)	30	45	[2]	mg/L	Daily[3]	24-Hour Composite
	9,508	14,261	[2]	lbs/day		
	The average monthly percent removal shall not be less than 85 percent					

MGD – Million Gallons per Day

[1] Compliance with mass-based effluent limitations shall be determined using the following formula and a design flow of 38 MGD:

lbs/day = 8.34 * concentration (mg/L) * flow (MGD)

[2] The Permittee shall monitor and report the test results.

[3] Both influent and effluent samples shall be taken, as specified in Part A.2 of this Permit

Effluent Characteristics	Discharge Limitations[1]				Monitoring Requirements	
	Average Annual	Average Monthly	Maximum Daily	Units	Measurement Frequency	Sample Type
pH	Not less than 6.0 and not greater than 9.0			standard units	5/Week[2]	Grab
Chronic Toxicity	--	--	Pass[3]	---	1/Month	24-Hour Composite
Chlordane	0.076	--	0.58	µg/L	1/Month[2]	24-Hour Composite
	0.024	--	0.184	lbs/day		
Dieldrin	0.012	--	0.27	µg/L	1/Month[2]	24-Hour Composite
	0.004	--	0.086	lbs/day		
DDT[4]	0.004	--	0.14	µg/L	1/Month[2]	24-Hour Composite
	0.001	--	0.044	lbs/day		
Enterococci	--	5,040[5]	72,144[6]	CFU/100 mL	1/Day[7]	Grab[8]
Total Nitrogen	[9]	[9]	--	µg/L	1/Month	24-Hour Composite
Total Phosphorus	[9]	[9]	--	µg/L	1/Month	24-Hour Composite
Ammonia Nitrogen	[9]	[9]	69,700	µg/L	1/Week	24-Hour Composite
	--	--	22,089	lbs/day		
Nitrate + Nitrite Nitrogen	[9]	[9]	--	µg/L	1/Month	24-Hour

This Page was modified on April 28, 2014.

Effluent Characteristics	Discharge Limitations[1]				Monitoring Requirements	
	Average Annual	Average Monthly	Maximum Daily	Units	Measurement Frequency	Sample Type
						Composite
Temperature	[9]	[9]	--	°C	1/Week	Grab
Total Oil and Grease	[9]	[9]	--	mg/L	2/Week[2]	Grab
Total Petroleum Hydrocarbons	[9]	[9]	--	mg/L	2/Week	Grab
Fats, Oils, and Grease	[9]	[9]	--	mg/L	2/Week	Calculate[10]
Turbidity	[9]	[9]	--	NTU	1/Month	Grab
Remaining Pollutants[11]	[9]	[9]	--	µg/L	2/Year	Grab

[1] Compliance with mass-based effluent limitations shall be determined using the following formula and a design flow of 38 MGD:

lbs/day = 8.34 * concentration (mg/L) * flow (MGD)

[2] Both influent and effluent samples shall be taken, as specified in Part A.2 of this Permit.
[3] "Pass", As described in Section B.3 of this Permit.
[4] DDT shall mean the sum of 4,4'-DDT, 4,4'-DDE and 4,4'-DDD.
[5] Effluent limitation expressed as a monthly geometric mean.
[6] Effluent limitation expressed as a single sample maximum.
[7] Report enterococci as a geometric mean and as a single sample.
[8] Effluent monitoring shall consist of one grab sample. Enterococci samples shall be analyzed using Method 1600, *Enterococci in Water by Membrane Filtration Using membrane-Enterococcus Indoxyl-β-D-Glucoside Agar(mEI)* (EPA 821-R-09-016).
[9] The Permittee shall monitor and report the parameter analytical test results.
[10] Fats, oils, and grease is equal to the total oil and grease minus total petroleum hydrocarbons.
[11] The Permittee shall perform semi-annual monitoring on all remaining pollutants listed in Appendix 1 of this permit, except those already specified in the table above. Effluent analyses for metals shall be reported as total recoverable.

2. For individual discharge parameters monitored in the influent and effluent, monitoring shall be conducted on the same day.

3. All influent and effluent monitoring shall be arranged so that each day of the calendar week is represented once per month (i.e., for discharge parameters monitoring five (5) days per week or three (3) days per week), or once per two (2) months (i.e., for discharge parameters monitored once per week). If the Permittee cannot arrange monitoring as prescribed, the Permittee shall provide a written explanation of the reasons with the discharge monitoring report.

4. Effluent monitoring for total nitrogen, total phosphorus, ammonia nitrogen, nitrate plus nitrite nitrogen, and turbidity shall be conducted on the same day that receiving water monitoring for said pollutants is conducted.

5. Samples taken in compliance with the monitoring requirements in Part A of this permit shall be taken at the following locations:

   a. Influent Monitoring, Monitoring Location INF: All influent samples shall be taken downstream of any additions to the trunk sewer, upstream of any

This Page was modified on April 28, 2014.