Permit Name	NPDES ID	vDisch-Desig	Limit Set Name	Perm Feature Type Desc	DMR Parameters.Parameter Code	Limits.Parameter Desc	Monitoring Location Desc	Statistical Base Short Desc	Limit Unit Desc	Limit Value Consolidation	vDMR Value	Monitoring Period End Date	Percent Exceedance	Violation Desc	NODI Desc
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	33	06/30/2002	83%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	2.104	02/28/2003	5%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	1.89	05/31/2003	5%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	2279.507	05/31/2003	14%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	1319.529	06/30/2003	32%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	2345.207	06/30/2003	17%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00300	Oxygen, dissolved [DO]	Effluent Gross	DAILY MN	Milligrams per Liter	5	.8	10/31/2003	84%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	1.236666	09/30/2004	3%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	1.9725	09/30/2004	10%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00552	Oil and grease, hexane extr method	Effluent Gross	DAILY MX	Milligrams per Liter	10	19.9	10/31/2005	99%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	3.30923	12/31/2005	65%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	6.6525	12/31/2005	122%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	2.218	01/31/2006	11%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	23.25	06/30/2006	29%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	001 FINAL EFFLUENT	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	4265.751	07/31/2007	113%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	4142.138	09/30/2007	314%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	12250.71	09/30/2007	513%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	1.516666	10/31/2007	26%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	3.885	10/31/2007	116%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	3596.468	10/31/2007	260%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	6774.302	10/31/2007	239%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	4.055	11/30/2007	35%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	3.775	01/31/2008	26%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	18.35	05/31/2008	2%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	2849.561	06/30/2008	42%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	1793.846	07/31/2008	79%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	6334.035	07/31/2008	217%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	12.65	08/31/2008	5%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	3.50225	08/31/2008	192%	DMR, Limited - Numeric Violation	

McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	9.27	08/31/2008	415%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00300	Oxygen, dissolved [DO]	Effluent Gross	DAILY MN	Milligrams per Liter	5	2.9	09/30/2008	42%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	1155.828	09/30/2008	16%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	3324.154	09/30/2008	66%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00400	pH	Effluent Gross	DAILY MX	Standard Units	9	9.9	10/31/2008	%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00552	Oil and grease, hexane extr method	Effluent Gross	DAILY MX	Milligrams per Liter	10	90	10/31/2008	800%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	1.866666	10/31/2008	56%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	4.556666	10/31/2008	153%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	2066.017	10/31/2008	107%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	3976.493	10/31/2008	99%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	2.194	12/31/2008	10%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	4.07	12/31/2008	36%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	3.4325	01/31/2009	72%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	4.795	01/31/2009	60%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	12.06	01/31/2009	21%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	15.15	01/31/2009	1%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	3.51	02/28/2009	17%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	10.125	02/28/2009	1%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	2.07275	03/31/2009	4%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	3.79	03/31/2009	26%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	18	03/31/2009	20%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	2.25875	04/30/2009	13%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	15.55	04/30/2009	4%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	14.8125	05/31/2009	23%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00552	Oil and grease, hexane extr method	Effluent Gross	DAILY MX	Milligrams per Liter	10	13	05/31/2009	30%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	2.6	05/31/2009	44%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	13.875	06/30/2009	16%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	22.3	06/30/2009	24%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	18.6	09/30/2009	3%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	12.7875	11/30/2009	7%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	16.975	11/30/2009	70%	DMR, Limited - Numeric Violation	

McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	20.3	11/30/2009	35%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	12.20625	12/31/2009	22%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	13.1	05/31/2010	9%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	15.60625	06/30/2010	30%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	20.7	06/30/2010	15%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	1112.391	06/30/2010	11%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	2371.708	06/30/2010	19%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	11.51875	08/31/2010	15%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	15.65	08/31/2010	4%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	1322.405	09/30/2010	32%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	11.665	09/30/2010	17%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00552	Oil and grease, hexane extr method	Effluent Gross	DAILY MX	Milligrams per Liter	10	14	10/31/2010	40%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	MO AVG	Number per 100 Milliliters	1000	1853.711	10/31/2010	85%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	2000	2237.297	10/31/2010	12%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	14.85	10/31/2010	48%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	20	10/31/2010	33%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	14.46875	11/30/2010	21%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	15.7375	11/30/2010	57%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	19.45	11/30/2010	30%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Kilograms per Day	.000006	.000007	12/31/2010	17%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	18.6	12/31/2010	1,331%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	18.5	12/31/2010	85%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	27.8	12/31/2010	85%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	10.9	01/31/2011	9%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	21	02/28/2011	40%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Kilograms per Day	.000006	.0000443	03/31/2011	638%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	33.8	03/31/2011	2,500%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	10.9	03/31/2011	9%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	22.4	06/30/2011	24%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	1000	3074	06/30/2011	207%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	7.3	06/30/2011	462%	DMR, Limited - Numeric Violation	

McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	1000	1526	07/31/2011	53%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	9.2	08/31/2011	608%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	31616	Coliform, fecal MF, MFC broth, 44.5 C	Effluent Gross	WKLY MAX	Number per 100 Milliliters	1000	1766	09/30/2011	77%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	20.3	10/31/2011	13%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Kilograms per Day	.000006	.0000161	12/31/2011	168%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	12.2	12/31/2011	838%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	10.1	01/31/2012	1%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Kilograms per Day	.000006	.0000111	03/31/2012	85%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	10.6	03/31/2012	715%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Kilograms per Day	.000006	.0000062	06/30/2012	3%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	20.5	06/30/2012	1,477%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	10.1	08/31/2012	677%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	5.25	12/31/2012	304%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Kilograms per Day	.000006	.000016	03/31/2013	167%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A	FINAL OUTFALL	External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	1.3	10.2	03/31/2013	685%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	373	05/31/2013	3%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	679.7	08/31/2013	88%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	MO GEOMN	Most Probable Number (MPN) per 100ml	161	298	09/30/2013	85%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	403	09/30/2013	11%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	5.55	03/31/2014	178%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	11.1	03/31/2014	270%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	23	04/30/2014	92%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	20	04/30/2014	11%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	6.18	04/30/2014	209%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	10.6	04/30/2014	253%	DMR, Limited - Numeric Violation	

McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	14	04/30/2014	40%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	19	04/30/2014	27%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	23	05/31/2014	92%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	34	05/31/2014	89%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Kilograms per Day	4.7	9.52	05/31/2014	103%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	12.6	05/31/2014	950%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Kilograms per Day	7.1	12.4	05/31/2014	75%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	15.6	05/31/2014	767%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	MO GEOMN	Most Probable Number (MPN) per 100ml	161	2440	05/31/2014	1,416%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	2500	05/31/2014	591%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	25	05/31/2014	150%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	34	05/31/2014	127%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	36	06/30/2014	200%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	57	06/30/2014	217%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	4.44	06/30/2014	270%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	12.4	06/30/2014	589%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	MO GEOMN	Most Probable Number (MPN) per 100ml	161	784.6	06/30/2014	387%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	2420	06/30/2014	569%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	11	06/30/2014	10%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	17	06/30/2014	13%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	MO GEOMN	Most Probable Number (MPN) per 100ml	161	777.8	07/31/2014	383%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	1254	07/31/2014	246%	DMR, Limited - Numeric Violation	

McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	16.3	08/31/2014	36%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	22.2	08/31/2014	23%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	6.96	08/31/2014	480%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	11.8	08/31/2014	556%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	MO GEOMN	Most Probable Number (MPN) per 100ml	161	2178	08/31/2014	1,253%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	4840	08/31/2014	1,237%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	22.2	33.8	08/31/2014	52%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	1.73	09/30/2014	44%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	3.17	09/30/2014	76%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	MO GEOMN	Most Probable Number (MPN) per 100ml	161	1092	09/30/2014	578%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	3293	09/30/2014	810%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	13.5	10/31/2014	13%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	21.4	10/31/2014	19%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	1.2	2.97	10/31/2014	148%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	1.8	7.76	10/31/2014	331%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	MO GEOMN	Most Probable Number (MPN) per 100ml	161	2234	10/31/2014	1,288%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	31648	E. coli, MTEC-MF	Effluent Gross	WK GEOMN	Most Probable Number (MPN) per 100ml	362	3422	10/31/2014	845%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	12	22.8	11/30/2014	90%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00530	Solids, total suspended	Effluent Gross	WKLY MAX	Milligrams per Liter	18	31.7	11/30/2014	76%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	7.14	11/30/2014	257%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	10	11/30/2014	233%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	15.28	11/30/2014	53%	DMR, Limited - Numeric Violation	

McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	20.35	11/30/2014	36%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	3.63	12/31/2014	82%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	7.3	12/31/2014	143%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	01119	Copper, total recoverable	Effluent Gross	MO AVG	Micrograms per Liter	22	28	12/31/2014	27%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	3.45	01/31/2015	73%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	5.64	01/31/2015	88%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	17.1	01/31/2015	14%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	8.31	02/28/2015	316%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	11.6	02/28/2015	287%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	4.01	03/31/2015	101%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	5.75	03/31/2015	92%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Kilograms per Day	.000088	.000137	03/31/2015	56%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	50092	Mercury, total low level	Effluent Gross	MO AVG	Nanograms per Liter	22.2	50.7	03/31/2015	128%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	MO AVG	Milligrams per Liter	10	15.2	03/31/2015	52%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	80082	BOD, carbonaceous, 05 day, 20 C	Effluent Gross	WKLY MAX	Milligrams per Liter	15	18.3	03/31/2015	22%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	MO AVG	Milligrams per Liter	2	4.3	04/30/2015	115%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Kilograms per Day	12	26.3	04/30/2015	119%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0026263	001-A		External Outfall	00610	Nitrogen, ammonia total [as N]	Effluent Gross	WKLY MAX	Milligrams per Liter	3	13.3	04/30/2015	343%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.41	05/31/2006	2,058%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.	11	09/30/2006	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.	11	09/30/2006	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.	39	09/30/2007	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.	39	09/30/2007	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	DAILY MX	Milligrams per Liter	45	54	10/31/2007	20%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	DAILY MX	Milligrams per Liter	45	68	05/31/2008	51%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.07	08/31/2008	268%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.	5.3	09/30/2008	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.	5.3	09/30/2008	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	DAILY MX	Milligrams per Liter	45	68	11/30/2008	51%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	DAILY MX	Milligrams per Liter	45	49.5	12/31/2008	10%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	DAILY MX	Milligrams per Liter	45	104	01/31/2009	131%	DMR, Limited - Numeric Violation	

McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	00530	Solids, total suspended	Effluent Gross	MO AVG	Milligrams per Liter	30	52.25	01/31/2009	74%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.05	02/28/2009	163%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.05	05/31/2009	163%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.	23.3	09/30/2009	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.	23.3	09/30/2009	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.12	05/31/2010	532%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.06	07/31/2010	216%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.1	09/30/2010	426%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.	72.3	09/30/2010	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.	72.3	09/30/2010	%		
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.06	11/30/2010	216%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A	FINAL OUTFALL	External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.08	12/31/2010	321%	DMR, Limited - Numeric Violation	
McComb, Village of	OH0042081	001-A		External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.	49.9	09/30/2012	%		
McComb, Village of	OH0042081	001-A		External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.	49.9	09/30/2012	%		
McComb, Village of	OH0042081	001-A		External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.	32.6	09/30/2013	%		
McComb, Village of	OH0042081	001-A		External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.	32.6	09/30/2013	%		
McComb, Village of	OH0042081	001-A		External Outfall	82080	Trihalomethane, tot.	Effluent Gross	DAILY MX	Micrograms per Liter	Req. Mon.		09/30/2014	%	DMR, Monitor Only - Overdue	Invalid Test
McComb, Village of	OH0042081	001-A		External Outfall	82080	Trihalomethane, tot.	Effluent Gross	MO AVG	Micrograms per Liter	Req. Mon.		09/30/2014	%	DMR, Monitor Only - Overdue	Invalid Test
McComb, Village of	OH0042081	001-A		External Outfall	50060	Chlorine, total residual	Effluent Gross	DAILY MX	Milligrams per Liter	.019	.18	02/28/2015	847%	DMR, Limited - Numeric Violation	