Pier 91 May 15, 1992

WA 2917
5.15.92
5 of (1)

Tanks - clarifying status of old tanks. Sludges all passed TCLP.

Does not meet definition marketer. Voluntarily meets requirements. Did notify as marketer as protective filer.

Waste oil not designated unless it fails chlor-detect. Oil that fails is not unloaded - shipped to Georgetown.

FILE COPY

USEPA RCRA
3012637

Leak detection for tanks.
Having trouble finding workable system. May be able to use pressurized system in void space.

Oil pick up company is gen.
Single generator loads original generator is gen.

Three baker tanks being certified for HW
1 for Antifreeze, coolants 2 for
6500 gal

Sludges - accept few.
Part B allows handling more
suspended or settled solids.
Most sludges go to Kent.
Determination made on liquid
phase.

Satellites in both labs no
DW or HW labels.