~~34~~
195

Initial Notification of Applicability[b]

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines
40 CFR Part 63 Subpart ZZZZ

REC'D
AUG 05 2010
APCO

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221112 Source ID 0010019

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for <u>existing sources</u> applies to the following engine types:

- Existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: City of Iola, KS

Facility name (if different): _____

Facility (physical location) address: 1300 S Washington
Iola KS 66749

My facility is a (please choose one): ☐ Major source ☐ Area source
☒ Synthetic minor

Owner name/title: Judy Brigham Administrator

Owner/company address: P.O. Box 308

Iola KS 66749

Owner telephone number: 620 - 365 - 4950

Owner email address (if available): _____

If the Operator information is different from the Owner, please provide the following:

Operator name/title: Mike Phillips Superintendent

Operator telephone number: 620 - 365 - 4950

Operator email address (if available): PowerPlt@iolaks.com

I hereby certify that the information presented herein is correct to the best of my knowledge.

Mike Phillips (Signature) 8-4-10 (Date)

Mike Phillips Superintendent (Name/title) (620) 365 - 4950 (Telephone No.)