Table 2 - Interstate Power and Light Company Power Plants Affected CI RICEs at HAPs Minor Sources

Facility File Number	Facility Name	Facility Name and Mailing Address	Facility Physical Location	EP/EU	Type of Engine (Compression Ignition or Spark Ignition)	Construction Date	Engine Model Year	Brake HP	Nature and Method of Operation	Any Numerical Emission Limit from this RICE Rule ? (Yes or No)	Pursuant to 63.6645(a)(5), is an Initial Notification Required ? (Yes or No)
29-02-003	IPL/Burlington Agency Street Combustion Turbine Generating Station	IPL-Burlington Generating Station, 4282 Sullivan Slough Road, Burlington, Iowa 52601	3320 Agency Street, Burlington, IA 52601	EP01S/EU02	CI RICE	Before year 2000	Before year 2000	<500	Existing starting engine for combustion turbine (Black Start)	No	No
				EP08S/EU08	CI RICE			<500			No
				EP15S/EU14	CI RICE			<500			No
				EP22S/EU20	CI RICE			<500			No
04-01-003	IPL-Centerville Conbustion Turbines & Diesel Generators	IPL-Ottumwa Generating Station, 20775 Power Plant Road, Ottumwa, Iowa 52501	North 14th Street, Centerville, Iowa	EP14/EU14	CI RICE			2680	Existing Emergency Gnerators	No	No
				EP15/EU15	CI RICE			2680			No
				EP16/EU16	CI RICE			2680			No
				EP4/EU2	CI RICE			600	Existing starting engine for combustion turbine (Black	No	No
				EP9/EU7	CI RICE			600			No
17-02-016	IPL-Emery Generating Station	IPL- Emery Generating Station, 11295 230th Street, Clear Lake, IA 50428	11295 230th Street, Clear Lake, IA 50428	BSG1/EU8	CI RICE	2004 (before 6/12/2006)	2004 (before 6/12/2006)	>500	Existing Emergency Generators (63.6590(a)(1)(iii)	No	No
				BSG2/EU9	CI RICE			>500			No
				BSG3/EU10	CI RICE			>500			No
				BSG4/EU11	CI RICE			>500			No
				BSG5/EU12	CI RICE			>500			No
				BSG6/EU15	CI RICE			>500			No
				FP1/EU7	CI RICE			<500	Existing Emergency Generators	No	No
79-01-022	IPL-Grinnell Combustion Turbine	IPL-Sutherland Generating Station, 3001 East Main Street, Marshalltown, IA50158	188 375th Av., Road F-27, Grinnell, Iowa 50112	EP5/EU2	CI RICE	Before 2000	Before 2000	<500	Existing starting engine for combustion turbine (Black Start)	No	No
				EP13/EU9	CI RICE			<500			No
17-01-066	IPL- Lime Creek Combustion Turbines	IPL- Emery Generating Station, 11295 230th Street, Clear Lake, IA 50428	24510 Orchid Avenue, Mason City, IA 50402	D1/LCD1	CI RICE			>500			No
				D2/LCD2	CI RICE			>500			No