(8)
10/17-18/12
MJM

Waste Minization - Annual Certification
Security - 40 CFR 264.14(b)(2)(c) Section B-5
Gen. Inspection Requirements Section F3 + G3
Personnel Training - 40 CFR 264.16(d)(+)(e) 5 yrs for former employees
Contingency Plan 40 CFR 264.53(a)
Records - Biennial Report
Closure Plan ~~40 264~~ 40 CFR 264.112(a)

+ Storage in Containers K, B, D, J + closed
174,570 total capacity
✓ Bldg C C100 - C700 mm 10/17/12 ~~99,1100~~ 99,110 gallons
✓ Processing Area P100 9,900 gallons V1-V8 tanks V9-V26 closed
✓ Drum Dock (10 Day Transfer) L100 14,960 gallons
✓ Bldg I I100 - I300 mm 10/17/12 ~~50,600~~ 50,600 10/17/12
no pallets more than two tiers containment free of ~~cracks~~ mm cracks
containers condition + remove precipitation
weekly inspections Section F3 G3 Daily inspection rail + tankers

+ Storage in Tanks
V1-V8 open 65,689 gallon total capacity
V9-V26 closed
Daily inspections
Monthly BB inspection BB equipment tags 10,000 pm of higher is leak
what kind of gas used 15 calendar days

Air Standards
BB
CC

3-4 shipments per week