801621 GC-2

SDMS Document ID
801621 - R8 SDMS

Case # _____

ADMINISTRATIVE RECORD

DISPOSITION FORM

PCB/PESTICIDE INVESTIGATION

Case: Sharonsteel Midvale, UT

Inspector: Henry Bonzek **Date of Inspection:** 6-20-86

I. Procedural Aspects:

Satisfactory

II. Conformance with Program Requirements:

Satisfactory

III. Disposition and Comments:

Violations:

40CFR 761.60(a) improper disposal. Two leaking pyranol transformers one each at two sites

40CFR 761.30(a)(1)(v.) 3 PCB Transformers not reported to primary Fire response personnel

40CFR 761.30(a)(1)(xii) no inspection & maintenance records

40CFR 761.65 improper storage for disposal of 2 PCB transformers

Action: forward to RC for civil complaint.

Drew Bensel
Section Chief

8-26-86
Date

Copies to:
Case File, Inspector
Section Chief, Attorney