ACUSHNET COMPANY

December 21, 1983

Mr. Richard A. Cavagnero
Sanitary Engineer
Permit Branch
U.S. Environmental Protection Agency
Region 1
J.F.Kennedy Federal Building
Boston, Massachusetts 02203

re: NPDES #MA0003913

Dear Mr. Cavagnero:

Enclosed please find copy of Discharge Report for period

May 1, 1983 to October 30, 1983.

Please notify me if there are any questions.

Very truly yours,

ACUSHNET COMPANY

Eugene Labonte
Mgr. Plant Services

EL/ra
Attachment

cc: DEQE
Division of Water Pollution Control
Lakeville Hospital
Lakeville, Mass. 02346

Tibbetts Engineering

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

Form Approved
OMB NO. 158-R0073

...rty or discharge location

Name THE ACUSHNET CO., RUBBER DIVISION, PLANT "B"
Street 744 BELLEVILLE AVE.
City NEW BEDFORD
State/Zip code MA. 02745

see INSTRUCTIONS on back

Remarks : CONSULTANTS
TIBBETTS ENGINEERING LABORATORY
210 DEANE STREET
NEW BEDFORD, MASS. 02746

23 DEC 1983

Telephone number (including area code) (617) 997 - 2811

(2-3) ST	(4-16) PERMIT NUMBER	(17-19) DIS
MA	0003913	001

REPORTING PERIOD: FROM (20-21) YEAR 83, (22-23) MO 05, (24-25) DAY 01 TO (26-27) YEAR 83, (28-29) MO 10, (30-31) DAY 31

* THE 12 OPEN BUCKET GRAB SAMPLES WERE COLLECTED OVER THE SAMPLING DAY, AND EXAMINED, THEN COMBINED INTO ONE COMPOSITE SAMPLE FOR ANALYSIS

(32-37) PARAMETER		(3 card only) QUANTITY (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(62-63) NO. EX	(4 card only) CONCENTRATION (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	(62-63) NO. EX	(64-68) FREQUENCY OF ANALYSIS	(69-70) SAMPLE TYPE
FLOW	REPORTED	0.611	0.652	0.710	M.G.D.	0						1/30	NA
	PERMIT CONDITION											1/30	
OIL & GREASE	REPORTED	0.4	0.8	1.4	LBS./DAY	0						1/30	GRAB*
	PERMIT CONDITION		3.3	9.3								1/30	GRAB*
T.S.S.	REPORTED	1.4	3.5	14.7	LBS./DAY	0						1/30	GRAB*
	PERMIT CONDITION		9.0	18.0								1/30	GRAB*
Cr (TOTAL)	REPORTED						<0.03	<0.05	<0.05	mg/l	0	1/30	GRAB*
	PERMIT CONDITION							0.3				1/30	GRAB*
C.O.D.	REPORTED						6.2	13.4	23.4	mg/l	0	1/30	GRAB*
	PERMIT CONDITION											1/30	GRAB*
pH	REPORTED						7.0	7.3	8.0	STD. UNITS	0	12/30	GRAB
	PERMIT CONDITION						6.5		8.0			12/30	GRAB
	REPORTED												
	PERMIT CONDITION												
	REPORTED												
	PERMIT CONDITION												

NAME OF PRINCIPAL EXECUTIVE OFFICER	TITLE OF THE OFFICER	DATE		
Labonte, Eugene W.	Mgr. Plant Services	83	12	20
LAST FIRST MI	TITLE	YEAR	MO	DAY

I certify that I am familiar with the information contained in this report and that to the best of my knowledge and belief such information is true, complete, and accurate.

E. Labonte
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

Facil