MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON		
SAMPLE POINT	DS000		

	LEAD 90TH	#SAMPLES	COPPER 90TH	#SAMPLES
01/01/2013-12/31/2015	0.0286* mg/l	57	0.4091 mg/l	57
Action Level	0.015 mg/l		1.3 mg/l	

* Action Level Exceeded

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHARLES GIBSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-121PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0047 ppm	0.015 ppm	AS	2015-07-15 16:40
1022	COPPER, FREE	200.8	0.0333 ppm	1.3 ppm	AS	2015-07-15 16:40

Comments: 3 Y2013 / SITE 20 / 5014 KAYBROOK DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THOMAS MONSOON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 05:18
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-122PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2015-07-15 16:42
1022	COPPER, FREE	200.8	0.0253 ppm	1.3 ppm	AS	2015-07-15 16:42

Comments: 3 Y2013 / SITE 78 / 4316 NEW POST RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE CHAPPELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-123PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.1284** ppm	0.015 ppm	AS	2015-07-15 16:44
1022	COPPER, FREE	200.8	0.1071 ppm	1.3 ppm	AS	2015-07-15 16:44

Comments: 3 Y2013 / SITE 25 / 5061 KAY BROOK DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ERRENCE D. WILSON, S	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-124PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.1012** ppm	0.015 ppm	AS	2015-07-15 16:46
1022	COPPER, FREE	200.8	0.4282 ppm	1.3 ppm	AS	2015-07-15 16:46

Comments: 3 Y2013 / SITE 24 / 5039 KAY BROOK DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AGNES WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-22 21:44
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-125PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0385** ppm	0.015 ppm	AS	2015-07-15 16:48
1022	COPPER, FREE	200.8	0.0217 ppm	1.3 ppm	AS	2015-07-15 16:48

Comments: 3 Y2013 / SITE 75 / 419 SHARON HILL DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KAMORO CAMPBELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 23:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-126PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2015-07-15 16:51
1022	COPPER, FREE	200.8	0.0387 ppm	1.3 ppm	AS	2015-07-15 16:51

Comments: 3 Y2013 / SITE 79 / 4318 NEW POST DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA HENDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-127PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0793** ppm	0.015 ppm	AS	2015-07-15 17:05
1022	COPPER, FREE	200.8	0.2016 ppm	1.3 ppm	AS	2015-07-15 17:05

Comments: 3 Y2013 / SITE 81 / 4315 NEW POST RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLA ORR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 07:47
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-070PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	AS	2015-07-01 19:14
1022	COPPER, FREE	200.8	0.4183 ppm	1.3 ppm	AS	2015-07-01 19:14

Comments: 3 Y2013 / SITE 220 / 5136 KAYWOOD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANNA RICKARD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-071PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0036 ppm	0.015 ppm	AS	2015-07-01 19:16
1022	COPPER, FREE	200.8	0.4737 ppm	1.3 ppm	AS	2015-07-01 19:16

Comments: 3 Y2013 / SITE 226 / 662 NEWLAND DRIVE

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILL ROBEOSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-24 07:44
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-072PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0242** ppm	0.015 ppm	AS	2015-07-01 19:18
1022	COPPER, FREE	200.8	0.181 ppm	1.3 ppm	AS	2015-07-01 19:18

Comments: 3 Y2013 / SITE 83 / 5644 DOGWOOD TRAIL

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY STIFF	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-24 04:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-073PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2015-07-01 19:33
1022	COPPER, FREE	200.8	0.0172 ppm	1.3 ppm	AS	2015-07-01 19:33

Comments: 3 Y2013 / SITE 97 / 1403 N. LAMAR ST.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVID H.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-074PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0059 ppm	0.015 ppm	AS	2015-07-01 19:35
1022	COPPER, FREE	200.8	0.3249 ppm	1.3 ppm	AS	2015-07-01 19:35

Comments: 3 Y2013 / SITE 251 / 2206 SHEFFIELD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHANEE LEO	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-21 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-075PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2015-07-01 19:37
1022	COPPER, FREE	200.8	0.3619 ppm	1.3 ppm	AS	2015-07-01 19:37

Comments: 3 Y2013 / SITE 244 / 1519 SHEFFIELD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEVE REEVES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-076PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2015-07-01 19:39
1022	COPPER, FREE	200.8	0.172 ppm	1.3 ppm	AS	2015-07-01 19:39

Comments: 3 Y2013 / SITE 232 / 5264 WAYNELAND DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-077PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0171** ppm	0.015 ppm	AS	2015-07-01 19:41
1022	COPPER, FREE	200.8	0.4453 ppm	1.3 ppm	AS	2015-07-01 19:41

Comments: 3 Y2013 / SITE 240 / 2030 SHEFFIELD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 07:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-078PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0036 ppm	0.015 ppm	AS	2015-07-01 19:44
1022	COPPER, FREE	200.8	0.3743 ppm	1.3 ppm	AS	2015-07-01 19:44

Comments: 3 Y2013 / SITE 246 / 1709 SHEFFIELD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN A. FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-24 08:26
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-079PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0111 ppm	0.015 ppm	AS	2015-07-01 19:46
1022	COPPER, FREE	200.8	0.2557 ppm	1.3 ppm	AS	2015-07-01 19:46

Comments: 3 Y2013 / SITE 192 / 6010 WHITESTONE RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D'JANO GAINES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 12:34
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-080PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0028 ppm	0.015 ppm	AS	2015-07-01 20:00
1022	COPPER, FREE	200.8	0.0727 ppm	1.3 ppm	AS	2015-07-01 20:00

Comments: 3 Y2013 / SITE 133 / 414 WOODY DRIVE

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NATASHA BARKSDALE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-081PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	AS	2015-07-01 20:02
1022	COPPER, FREE	200.8	0.115 ppm	1.3 ppm	AS	2015-07-01 20:02

Comments: 3 Y2013 / SITE 134 / 542 WOODY DRIVE

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEMETROUS GILBERT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-082PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0019 ppm	0.015 ppm	AS	2015-07-01 20:05
1022	COPPER, FREE	200.8	0.4052 ppm	1.3 ppm	AS	2015-07-01 20:05

Comments: 3 Y2013 / SITE 136 / 1436 WOODY DRIVE

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FREDDIE LEE WILLIAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 02:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-083PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2015-07-01 20:07
1022	COPPER, FREE	200.8	0.2489 ppm	1.3 ppm	AS	2015-07-01 20:07

Comments: 3 Y2013 / SITE 100 / 1725 N. LAMAR ST.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LISA SKIPPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 05:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-084PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0041 ppm	0.015 ppm	AS	2015-07-01 20:09
1022	COPPER, FREE	200.8	0.0537 ppm	1.3 ppm	AS	2015-07-01 20:09

Comments: 3 Y2013 / SITE 142 / 3015 SUNCREST DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANGELA FOSTER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-085PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	AS	2015-07-01 20:11
1022	COPPER, FREE	200.8	0.2763 ppm	1.3 ppm	AS	2015-07-01 20:11

Comments: 3 Y2013 / SITE 188 / 6017 WOODHAVEN RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NORMANY GREEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-086PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0056 ppm	0.015 ppm	AS	2015-07-01 20:13
1022	COPPER, FREE	200.8	0.3233 ppm	1.3 ppm	AS	2015-07-01 20:13

Comments: 3 Y2013 / SITE 245 / 1603 SHEFFIELD DRIVE

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SYLVESTER RANDELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-087PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0254** ppm	0.015 ppm	AS	2015-07-01 20:28
1022	COPPER, FREE	200.8	0.2569 ppm	1.3 ppm	AS	2015-07-01 20:28

Comments: 3 Y2013 / SITE 187 / 5907 WOODHAVEN ROAD

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL C. ROSS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:21
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-088PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2015-07-01 20:30
1022	COPPER, FREE	200.8		0.0231	ppm	1.3	ppm	AS	2015-07-01 20:30

Comments: 3 Y2013 / SITE 179 / 533 WITSELL ROAD

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CORNELIUS COOPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-089PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2015-07-01 20:32
1022	COPPER, FREE	200.8	0.0682 ppm	1.3 ppm	AS	2015-07-01 20:32

Comments: 3 Y2013 / SITE 139 / 704 WOODY DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DIANN ENGLISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 10:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-090PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0041 ppm	0.015 ppm	AS	2015-07-01 20:35
1022	COPPER, FREE	200.8	0.0722 ppm	1.3 ppm	AS	2015-07-01 20:35

Comments: 3 Y2013 / SITE 189 / 6103 WOODHAVEN RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TOMMY G. BRUMFIELD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-091PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0132 ppm	0.015 ppm	AS	2015-07-01 20:37
1022	COPPER, FREE	200.8	0.2102 ppm	1.3 ppm	AS	2015-07-01 20:37

Comments: 3 Y2013 / SITE 190 / 5911 WHITESTONE ROAD

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JACOB BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-092PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2015-07-01 20:41
1022	COPPER, FREE	200.8	0.2319 ppm	1.3 ppm	AS	2015-07-01 20:41

Comments: 3 Y2013 / SITE 173 / 320 VALLEY N. BLVD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY HORTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-22 23:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-093PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2015-07-15 14:48
1022	COPPER, FREE	200.8		0.3145 ppm	1.3 ppm	AS	2015-07-15 14:48

Comments: 3 Y2013 / SITE 185 / 613 BEAVERBROOK

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHERYL ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-094PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0097 ppm	0.015 ppm	AS	2015-07-15 14:50
1022	COPPER, FREE	200.8	0.4011 ppm	1.3 ppm	AS	2015-07-15 14:50

Comments: 3 Y2013 / SITE 191 / 5942 WHITESTONE RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE HAMBLIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-095PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	AS	2015-07-15 14:53
1022	COPPER, FREE	200.8	0.107 ppm	1.3 ppm	AS	2015-07-15 14:53

Comments: 3 Y2013 / SITE 143 / 3121 SUNCREST DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROBERT JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 10:29
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-096PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0108 ppm	0.015 ppm	AS	2015-07-15 14:55
1022	COPPER, FREE	200.8	0.2841 ppm	1.3 ppm	AS	2015-07-15 14:55

Comments: 3 Y2013 / SITE 129 / 2951 LAKEWOOD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	B. RAMSAY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-097PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2015-07-15 14:58
1022	COPPER, FREE	200.8		0.0324	ppm	1.3	ppm	AS	2015-07-15 14:58

Comments: 3 Y2013 / SITE 234 / 5456 WAYNELAND DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	YOLANDA BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 07:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-098PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0096 ppm	0.015 ppm	AS	2015-07-15 15:01
1022	COPPER, FREE	200.8	0.2159 ppm	1.3 ppm	AS	2015-07-15 15:01

Comments: 3 Y2013 / SITE 193 / 6064 WHITESTONE RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARA WILKES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:59
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-099PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2015-07-15 15:15
1022	COPPER, FREE	200.8	0.6347 ppm	1.3 ppm	AS	2015-07-15 15:15

Comments: 3 Y2013 / SITE 186 / 729 BEAVERBROOK DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMBERA ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:29
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-100PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2015-07-15 15:17
1022	COPPER, FREE	200.8	0.3253 ppm	1.3 ppm	AS	2015-07-15 15:17

Comments: 3 Y2013 / SITE 110 / 336 E. BELL ST.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THOMAS TANNEHILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 09:04
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-101PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2015-07-15 15:19
1022	COPPER, FREE	200.8	0.207 ppm	1.3 ppm	AS	2015-07-15 15:19

Comments: 3 Y2013 / SITE 144 / 3257 SUNCREST DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JEANNETTE PENGUIT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-102PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0128 ppm	0.015 ppm	AS	2015-07-15 15:21
1022	COPPER, FREE	200.8	0.2959 ppm	1.3 ppm	AS	2015-07-15 15:21

Comments: 3 Y2013 / SITE 132 / 282 WOODY DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EMILY MOKRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:18
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-103PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	AS	2015-07-15 15:24
1022	COPPER, FREE	200.8	0.0331 ppm	1.3 ppm	AS	2015-07-15 15:24

Comments: 3 Y2013 / SITE 127 / 2835 LAKEWOOD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MONICA JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-104PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0023 ppm	0.015 ppm	AS	2015-07-15 15:26
1022	COPPER, FREE	200.8	0.0356 ppm	1.3 ppm	AS	2015-07-15 15:26

Comments: 3 Y2013 / SITE 128 / 2858 LAKEWOOD DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GAIL ROY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 07:46
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-105PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2015-07-15 15:28
1022	COPPER, FREE	200.8	0.0124 ppm	1.3 ppm	AS	2015-07-15 15:28

Comments: 3 Y2013 / SITE 88 / 2017 N. LAMAR STREET

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARQUIA DIXON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:18
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-106PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2015-07-15 15:42
1022	COPPER, FREE	200.8		0.0365 ppm	1.3 ppm	AS	2015-07-15 15:42

Comments: 3 Y2013 / SITE 117 / 325 SPANISH COURT

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 05:43
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-107PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2015-07-15 15:45
1022	COPPER, FREE	200.8		0.0513 ppm	1.3 ppm	AS	2015-07-15 15:45

Comments: 3 Y2013 / SITE 116 / 303 SPANISH CT.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JACKSON / WILLIE DIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-108PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2015-07-15 15:47
1022	COPPER, FREE	200.8		0.028	ppm	1.3	ppm	AS	2015-07-15 15:47

Comments: 3 Y2013 / SITE 96 / 1347 N. LAMAR ST.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAURA DRAIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-109PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0192** ppm	0.015 ppm	AS	2015-07-15 15:49
1022	COPPER, FREE	200.8	0.168 ppm	1.3 ppm	AS	2015-07-15 15:49

Comments: 3 Y2013 / SITE 135 / 1105 WOODY DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BELINDA CULPEPPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 11:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-110PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0104 ppm	0.015 ppm	AS	2015-07-15 15:51
1022	COPPER, FREE	200.8	0.5935 ppm	1.3 ppm	AS	2015-07-15 15:51

Comments: 3 Y2013 / SITE 80 / 4330 NEW POST RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHERWONDA TAYLOR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 19:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-111PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0197** ppm	0.015 ppm	AS	2015-07-15 15:53
1022	COPPER, FREE	200.8	0.0985 ppm	1.3 ppm	AS	2015-07-15 15:53

Comments: 3 Y2013 / SITE 27 / 5479 BROOKHOLLOW DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHUN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-112PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0216** ppm	0.015 ppm	AS	2015-07-15 15:56
1022	COPPER, FREE	200.8	0.1065 ppm	1.3 ppm	AS	2015-07-15 15:56

Comments: 3 Y2013 / SITE 76 / 4310 NEW POST RD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHELLIE MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-113PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0072 ppm	0.015 ppm	AS	2015-07-15 16:10
1022	COPPER, FREE	200.8	0.0589 ppm	1.3 ppm	AS	2015-07-15 16:10

Comments: 3 Y2013 / SITE 28 / 5477 BROOKHOLLOW DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TRACY WESTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 09:43
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-114PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0099 ppm	0.015 ppm	AS	2015-07-15 16:12
1022	COPPER, FREE	200.8	0.3361 ppm	1.3 ppm	AS	2015-07-15 16:12

Comments: 3 Y2013 / SITE 30 / 1716 BROOKHOLLOW CIR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEGGY STANSELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-22 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-115PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0264** ppm	0.015 ppm	AS	2015-07-15 16:14
1022	COPPER, FREE	200.8	0.0866 ppm	1.3 ppm	AS	2015-07-15 16:14

Comments: 3 Y2013 / SITE 22 / 5022 KAY BROOK DRIVE

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELISSA RESTEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-22 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-116PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0055 ppm	0.015 ppm	AS	2015-07-15 16:17
1022	COPPER, FREE	200.8	0.0442 ppm	1.3 ppm	AS	2015-07-15 16:17

Comments: 3 Y2013 / SITE 23 / 5026 KAY BROOK DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	J. ALEXANDER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 10:14
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-117PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0362** ppm	0.015 ppm	AS	2015-07-15 16:19
1022	COPPER, FREE	200.8	0.0347 ppm	1.3 ppm	AS	2015-07-15 16:19

Comments: 3 Y2013 / SITE 69 / 4430 WILLOWOOD BLVD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SAMANTHA JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-22 17:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-118PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0088 ppm	0.015 ppm	AS	2015-07-15 16:21
1022	COPPER, FREE	200.8	0.0692 ppm	1.3 ppm	AS	2015-07-15 16:21

Comments: 3 Y2013 / SITE 21 / 5019 KAY BROOK DR.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JUDY HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-22 18:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-119PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.096** ppm	0.015 ppm	AS	2015-07-15 16:23
1022	COPPER, FREE	200.8	0.1035 ppm	1.3 ppm	AS	2015-07-15 16:23

Comments: 3 Y2013 / SITE 29 / 1704 BROOKHOLLOW CIRCLE

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLTON STEPHEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2015-06-23 13:09
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2015-06-25
SAMPLE POINT	DS000	**LAB ID**	150625-120PB	**COMPOSITED**	NO

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0034 ppm	0.015 ppm	AS	2015-07-15 16:37
1022	COPPER, FREE	200.8	0.2185 ppm	1.3 ppm	AS	2015-07-15 16:37

Comments: 3 Y2013 / SITE 71 / 4724 WILL O WOOD BLVD.

Generated 2016-01-28

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	# Samples	Copper 90th	# Samples
01/01/2016-06/30/2016 (6 Month)	0.016 mg/L *	101	0.5 mg/L	101
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHERWANDA TAYLOR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2016-02-02 11:32
1022	COPPER, FREE	200.8	0.0313 ppm	1.3 ppm	AS	2016-02-02 11:32

Comments: 6M12016 / SITE 27 / 5479 BROOKHOLLOW DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY C. RICHARDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0147 ppm	0.015 ppm	AS	2016-02-02 11:34
1022	COPPER, FREE	200.8	0.1183 ppm	1.3 ppm	AS	2016-02-02 11:34

Comments: 6M12016 / SITE 178 / 513 WITSELL RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL ROSS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-003PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-02-02 11:37
1022	COPPER, FREE	200.8		0.0161	ppm	1.3	ppm	AS	2016-02-02 11:37

Comments: 6M12016 / SITE 179 / 533 WITSELL RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 07:07
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-004PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0616** ppm	0.015 ppm	AS	2016-02-02 11:39
1022	COPPER, FREE	200.8	0.2984 ppm	1.3 ppm	AS	2016-02-02 11:39

Comments: 6M12016 / SITE 180 / 546 WITSELL RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-005PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-02-02 11:42
1022	COPPER, FREE	200.8		0.0188	ppm	1.3	ppm	AS	2016-02-02 11:42

Comments: 6M12016 / SITE 181 / 576 WITSELL RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MRS. SPANN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 03:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-006PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-03 11:10
1022	COPPER, FREE	200.8		0.0224 ppm	1.3 ppm	AS	2016-02-03 11:10

Comments: 6M12016 / SITE 182 / 625 WITSELL RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHRISTOPHER WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-01-31 20:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-007PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-02-02 11:59
1022	COPPER, FREE	200.8		0.6895	ppm	1.3	ppm	AS	2016-02-02 11:59

Comments: 6M12016 / SITE 183 / 363 BEAVERBROOK DR. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIMBERLY QUINN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-008PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0037 ppm	0.015 ppm	AS	2016-02-02 12:01
1022	COPPER, FREE	200.8	0.3979 ppm	1.3 ppm	AS	2016-02-02 12:01

Comments: 6M12016 / SITE 184 / 517 BEAVERBROOK DR. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY HORTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 07:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-009PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-02-02 12:03
1022	COPPER, FREE	200.8		0.7372	ppm	1.3	ppm	AS	2016-02-02 12:03

Comments: 6M12016 / SITE 185 / 613 BEAVERBROOK DR. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARA WILKES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 07:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-010PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-02-02 12:05
1022	COPPER, FREE	200.8	0.5135 ppm	1.3 ppm	AS	2016-02-02 12:05

Comments: 6M12016 / SITE 186 / 729 BEAVERBROOK DR. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANGELA FOSTER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 05:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-011PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2016-02-02 12:08
1022	COPPER, FREE	200.8	0.0781 ppm	1.3 ppm	AS	2016-02-02 12:08

Comments: 6M12016 / SITE 188 / 6017 WOODHAVEN ROAD / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TOMMY BRUMFIELD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-012PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2016-02-02 12:10
1022	COPPER, FREE	200.8	0.0895 ppm	1.3 ppm	AS	2016-02-02 12:10

Comments: 6M12016 / SITE 190 / 5911 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHERYL ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-013PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.013 ppm	0.015 ppm	AS	2016-02-03 11:38
1022	COPPER, FREE	200.8	0.0849 ppm	1.3 ppm	AS	2016-02-03 11:38

Comments: 6M12016 / SITE 191 / 5942 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-014PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0112 ppm	0.015 ppm	AS	2016-02-02 12:26
1022	COPPER, FREE	200.8	0.0966 ppm	1.3 ppm	AS	2016-02-02 12:26

Comments: 6M12016 / SITE 192 / 6010 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARK LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-015PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0209** ppm	0.015 ppm	AS	2016-02-02 12:28
1022	COPPER, FREE	200.8	0.1965 ppm	1.3 ppm	AS	2016-02-02 12:28

Comments: 6M12016 / SITE 246 / 1709 SHEFFIELD DR. / 39211

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAUREN BENNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-016PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-02-02 12:31
1022	COPPER, FREE	200.8	0.4132 ppm	1.3 ppm	AS	2016-02-02 12:31

Comments: 6M12016 / SITE 250 / 2110 SHEFFIELD DR. / 39211

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-017PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0191** ppm	0.015 ppm	AS	2016-02-02 12:33
1022	COPPER, FREE	200.8	0.1951 ppm	1.3 ppm	AS	2016-02-02 12:33

Comments: 6M12016 / SITE 252 / 3951 EASTWOOD DR. / 39211

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	YOLANDA BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-018PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0105 ppm	0.015 ppm	AS	2016-02-02 12:35
1022	COPPER, FREE	200.8	0.2164 ppm	1.3 ppm	AS	2016-02-02 12:35

Comments: 6M12016 / SITE 193 / 6064 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAMES FIELDS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-019PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0032 ppm	0.015 ppm	AS	2016-02-02 12:37
1022	COPPER, FREE	200.8	0.0455 ppm	1.3 ppm	AS	2016-02-02 12:37

Comments: 6M12016 / SITE 194 / 6114 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIMBERLY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-020PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0045 ppm	0.015 ppm	AS	2016-02-02 12:39
1022	COPPER, FREE	200.8	0.1268 ppm	1.3 ppm	AS	2016-02-02 12:39

Comments: 6M12016 / SITE 195 / 6143 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 05:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-021PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0132 ppm	0.015 ppm	AS	2016-02-02 12:54
1022	COPPER, FREE	200.8	0.5519 ppm	1.3 ppm	AS	2016-02-02 12:54

Comments: 6M12016 / SITE 196 / 6203 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ERIC LEWIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 06:51
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-022PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2016-02-02 12:56
1022	COPPER, FREE	200.8	0.4456 ppm	1.3 ppm	AS	2016-02-02 12:56

Comments: 6M12016 / SITE 197 / 6335 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHARLES R. SMITH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-023PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2016-02-02 12:58
1022	COPPER, FREE	200.8	0.1665 ppm	1.3 ppm	AS	2016-02-02 12:58

Comments: 6M12016 / SITE 198 / 6355 WHITESTONE RD. / 39206

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ELIZABETH SULLIVAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-024PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-02 13:00
1022	COPPER, FREE	200.8		0.0199 ppm	1.3 ppm	AS	2016-02-02 13:00

Comments: 6M12016 / SITE 243 / 1437 SHEFFIELD DR. / 39211

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHANEE LEO	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-01
SAMPLE POINT	DS000	**LAB ID**	160201-025PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-02-02 13:02
1022	COPPER, FREE	200.8	0.43 ppm	1.3 ppm	AS	2016-02-02 13:02

Comments: 6M12016 / SITE 244 / 1519 SHEFFIELD DR. / 39211

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 23:59
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF106	**LAB ID**	160202-013PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-03 11:54
1022	COPPER, FREE	200.8		0.0057 ppm	1.3 ppm	AS	2016-02-03 11:54

Comments: 6M12016 / SO OF HWY 18 AND WEST OF SIWELL ROAD

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 13:35
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF101	**LAB ID**	160202-014PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-03 11:56
1022	COPPER, FREE	200.8		0.0078 ppm	1.3 ppm	AS	2016-02-03 11:56

Comments: 6M12016 / WIGGINS ROAD

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 07:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF081	**LAB ID**	160202-015PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION	FEWELL PLANT - PEARL RIVER				

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-03 11:58
1022	COPPER, FREE	200.8		0.0007 ppm	1.3 ppm	AS	2016-02-03 11:58

Comments: 6M12016 / TREATMENT FACILITY TF081 FEWELL

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 12:03
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF082	**LAB ID**	160202-016PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION	O B CURTIS PLANT - BARNETT RESERVOIR				

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-03 12:01
1022	COPPER, FREE	200.8		0.0012 ppm	1.3 ppm	AS	2016-02-03 12:01

Comments: 6M12016 / TREATMENT FACILITY TF081 OB CURTIS

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 13:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF103	**LAB ID**	160202-017PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-02-03 12:03
1022	COPPER, FREE	200.8		0.0092	ppm	1.3	ppm	AS	2016-02-03 12:03

Comments: 6M12016 / SOUTH OF TV ROAD AND E OF MADDOX ROAD

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 12:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF102	**LAB ID**	160202-018PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-03 12:05
1022	COPPER, FREE	200.8		0.0031 ppm	1.3 ppm	AS	2016-02-03 12:05

Comments: 6M12016 / WILLOWOOD S/D E OF SIWELL RD.

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 13:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF107	**LAB ID**	160202-019PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	AS	2016-02-04 16:17
1022	COPPER, FREE	200.8	0.0041 ppm	1.3 ppm	AS	2016-02-04 16:17

Comments: 6M12016 / MADDOX RD & HWY 18

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L. HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 11:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-02
SAMPLE POINT	TF105	**LAB ID**	160202-020PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-02-03 12:21
1022	COPPER, FREE	200.8		0.0161	ppm	1.3	ppm	AS	2016-02-03 12:21

Comments: 6M12016 / EAST OF SIWELL RD AND NO OF MCCLUER RD.

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NORMAN GREEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-02-04 16:20
1022	COPPER, FREE	200.8	0.2661 ppm	1.3 ppm	AS	2016-02-04 16:20

Comments: 6M12016 / SITE 245 / 1603 SHEFFIELD DR. / 39211

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	K. JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 07:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0031 ppm	0.015 ppm	AS	2016-02-04 16:22
1022	COPPER, FREE	200.8	0.1028 ppm	1.3 ppm	AS	2016-02-04 16:22

Comments: 6M12016 / SITE 77 / 4314 NEW POST RD. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D. WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 11:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-003PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0085 ppm	0.015 ppm	AS	2016-02-04 16:25
1022	COPPER, FREE	200.8	0.1705 ppm	1.3 ppm	AS	2016-02-04 16:25

Comments: 6M12016 / SITE 58 / 206 SUNDOWN TRAIL / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THOMAS J. MONSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 06:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-004PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-02-04 16:28
1022	COPPER, FREE	200.8	0.0835 ppm	1.3 ppm	AS	2016-02-04 16:28

Comments: 6M12016 / SITE 78 / 4316 NEW POST RD. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ARTESSA JENKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 05:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-005PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0025 ppm	0.015 ppm	AS	2016-02-04 16:30
1022	COPPER, FREE	200.8	0.0249 ppm	1.3 ppm	AS	2016-02-04 16:30

Comments: 6M12016 / SITE 34 / 4270 WILL-O-RUN RD. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TRACY WESTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 08:46
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-006PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0063 ppm	0.015 ppm	AS	2016-02-04 16:44
1022	COPPER, FREE	200.8	0.1211 ppm	1.3 ppm	AS	2016-02-04 16:44

Comments: 6M12016 / SITE 30 / 1716 BROOKHOLLOW CR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RACHEL GIBSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-007PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2016-02-04 16:46
1022	COPPER, FREE	200.8	0.0651 ppm	1.3 ppm	AS	2016-02-04 16:46

Comments: 6M12016 / SITE 20 / 5014 KAY BROOK DR. / 39272

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROSALIND ESSEX	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 13:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-008PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-02-04 16:49
1022	COPPER, FREE	200.8	0.2068 ppm	1.3 ppm	AS	2016-02-04 16:49

Comments: 6M12016 / SITE 86 / 1417 TAYLOR AVE. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 19:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-009PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-02-04 16:51
1022	COPPER, FREE	200.8	0.0109 ppm	1.3 ppm	AS	2016-02-04 16:51

Comments: 6M12016 / SITE 88 / 2017 N. LAMAR ST. / 39202

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CORNELIUS COOPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-010PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-04 16:53
1022	COPPER, FREE	200.8		0.0112 ppm	1.3 ppm	AS	2016-02-04 16:53

Comments: 6M12016 / SITE 139 / 704 WOODY DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVID B.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 18:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-011PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2016-02-04 16:55
1022	COPPER, FREE	200.8	0.1144 ppm	1.3 ppm	AS	2016-02-04 16:55

Comments: 6M12016 / SITE 114 / 309 NEARVIEW ST. / 39202

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMIA MOORE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 03:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-012PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2016-02-04 16:57
1022	COPPER, FREE	200.8	0.0869 ppm	1.3 ppm	AS	2016-02-04 16:57

Comments: 6M12016 / SITE 157 / 6612 LYNDON B. JOHNSON DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-013PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-02-04 17:12
1022	COPPER, FREE	200.8	0.0374 ppm	1.3 ppm	AS	2016-02-04 17:12

Comments: 6M12016 / SITE 160 / 6709 LYNDON B. JOHNSON / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROBERT E. CLARK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-014PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0503** ppm	0.015 ppm	AS	2016-02-04 17:14
1022	COPPER, FREE	200.8	0.4023 ppm	1.3 ppm	AS	2016-02-04 17:14

Comments: 6M12016 / SITE 165 / 6609 FDR DR. / 39213

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHAROLETTE JORDAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 11:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-015PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2016-02-04 17:16
1022	COPPER, FREE	200.8	0.0452 ppm	1.3 ppm	AS	2016-02-04 17:16

Comments: 6M12016 / SITE 217 / 5925 SEDGWICK DR. / 39211

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-016PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0024 ppm	0.015 ppm	AS	2016-02-04 17:18
1022	COPPER, FREE	200.8	0.1924 ppm	1.3 ppm	AS	2016-02-04 17:18

Comments: 6M12016 / SITE 150 / 6240 AMBLEWOOD DR. / 39213

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	QUINTON X. BEARD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-017PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	AS	2016-02-04 17:20
1022	COPPER, FREE	200.8	0.0936 ppm	1.3 ppm	AS	2016-02-04 17:20

Comments: 6M12016 / SITE 59 / 249 SUNDOWN TRAIL / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALICE R. HUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 06:21
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-018PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0111 ppm	0.015 ppm	AS	2016-02-04 17:23
1022	COPPER, FREE	200.8	0.0927 ppm	1.3 ppm	AS	2016-02-04 17:23

Comments: 6M12016 / SITE 156 / 6570 LBJ DRIVE / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	IVYE L. ALLEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-019PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-02-04 17:25
1022	COPPER, FREE	200.8	0.672 ppm	1.3 ppm	AS	2016-02-04 17:25

Comments: 6M12016 / SITE 148 / 6161 AMBLEWOOD DRIVE / 39213

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE BURNETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-020PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2016-02-04 17:39
1022	COPPER, FREE	200.8	0.4914 ppm	1.3 ppm	AS	2016-02-04 17:39

Comments: 6M12016 / SITE 166 / 6631 FRANKLIN D. ROOSEVELT / 39213

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EDITH CRAYTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-021PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2016-02-04 17:41
1022	COPPER, FREE	200.8	0.0384 ppm	1.3 ppm	AS	2016-02-04 17:41

Comments: 6M12016 / SITE 170 / 6917 FRANKLIN ROOSEVELT DR. / 39213

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THOMAS D. TANNEHILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 22:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-022PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0029 ppm	0.015 ppm	AS	2016-02-04 17:43
1022	COPPER, FREE	200.8	0.0773 ppm	1.3 ppm	AS	2016-02-04 17:43

Comments: 6M12016 / SITE 144 / 3257 SUNCREST DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LISA SKIPPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 16:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-023PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-02-04 17:46
1022	COPPER, FREE	200.8	0.0129 ppm	1.3 ppm	AS	2016-02-04 17:46

Comments: 6M12016 / SITE 142 / 3015 SUNCREST DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JEANNETTE PENQUITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-024PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.005 ppm	0.015 ppm	AS	2016-02-04 17:48
1022	COPPER, FREE	200.8	0.1663 ppm	1.3 ppm	AS	2016-02-04 17:48

Comments: 6M12016 / SITE 132 / 282 WOODY DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHIRLEY MORGAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 10:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-025PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-02-04 17:50
1022	COPPER, FREE	200.8	0.0379 ppm	1.3 ppm	AS	2016-02-04 17:50

Comments: 6M12016 / SITE 66 / 218 WESTERN HILLS DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NATASHA BARKSDALE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 12:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-026PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2016-02-04 17:52
1022	COPPER, FREE	200.8	0.0213 ppm	1.3 ppm	AS	2016-02-04 17:52

Comments: 6M12016 / SITE 134 / 542 WOODY DRIVE / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA H. BRASSELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-01 17:47
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-027PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-02-04 18:06
1022	COPPER, FREE	200.8	0.0431 ppm	1.3 ppm	AS	2016-02-04 18:06

Comments: 6M12016 / SITE 145 / 3335 SUNCREST DRIVE / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBORAH JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-028PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-02-04 18:09
1022	COPPER, FREE	200.8		0.0369	ppm	1.3	ppm	AS	2016-02-04 18:09

Comments: 6M12016 / SITE 115 / 314 NEARVIEW ST. / 39202

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KATHY R.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02 18:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-029PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0047 ppm	0.015 ppm	AS	2016-02-04 18:11
1022	COPPER, FREE	200.8	0.077 ppm	1.3 ppm	AS	2016-02-04 18:11

Comments: 6M12016 / SITE 23 / 5026 KAYBROOK DRIVE / 39272

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-03
SAMPLE POINT	DS000	**LAB ID**	160203-030PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.1064** ppm	0.015 ppm	AS	2016-02-04 18:15
1022	COPPER, FREE	200.8	0.9199 ppm	1.3 ppm	AS	2016-02-04 18:15

Comments: 6M12016 / SITE 159 / 6663 LBJ DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	IRVIN LEWIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 05:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	AS	2016-02-05 11:29
1022	COPPER, FREE	200.8	0.0314 ppm	1.3 ppm	AS	2016-02-05 11:29

Comments: 6M12016 / SITE 42 / 2326 E.. FLOWERS RD. / 39170

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	J. HOLLINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 07:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.006 ppm	0.015 ppm	AS	2016-02-05 11:32
1022	COPPER, FREE	200.8	0.1481 ppm	1.3 ppm	AS	2016-02-05 11:32

Comments: 6M12016 / SITE 63 / 2335 N. PINE LEA DR. / 39209

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LARRY MILLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-003PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0029 ppm	0.015 ppm	AS	2016-02-05 11:34
1022	COPPER, FREE	200.8	0.0366 ppm	1.3 ppm	AS	2016-02-05 11:34

Comments: 6M12016 / SITE 15 / 150 CARPENTER DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HUGH J. RUSHING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-004PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2016-02-05 11:37
1022	COPPER, FREE	200.8	0.8904 ppm	1.3 ppm	AS	2016-02-05 11:37

Comments: 6M12016 / SITE 56 / 3628 FOREST HILL RD. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HILDA PERRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-005PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-02-05 11:39
1022	COPPER, FREE	200.8	0.0231 ppm	1.3 ppm	AS	2016-02-05 11:39

Comments: 6M12016 / SITE / 1720 BROOKHOLLOW CIRCLE / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-006PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2016-02-05 11:42
1022	COPPER, FREE	200.8	0.0476 ppm	1.3 ppm	AS	2016-02-05 11:42

Comments: 6M12016 / SITE 28 / 5477 BROOKHOLLOW DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SAMANTHA JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-03 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-007PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	AS	2016-02-05 11:56
1022	COPPER, FREE	200.8	0.0269 ppm	1.3 ppm	AS	2016-02-05 11:56

Comments: 6M12016 / SITE 21 / 5019 KAYBROOK DRIVE / 39272

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DELBERT HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-008PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2016-02-05 11:58
1022	COPPER, FREE	200.8	0.0344 ppm	1.3 ppm	AS	2016-02-05 11:58

Comments: 6M12016 / SITE 64 / 2405 S. PINE LEA DR. / 39209

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODESTER JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-009PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0584** ppm	0.015 ppm	AS	2016-02-05 12:00
1022	COPPER, FREE	200.8	0.1188 ppm	1.3 ppm	AS	2016-02-05 12:00

Comments: 6M12016 / SITE 84 / 164 DURANVILLE DR. / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SPURGEON STAMPS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-010PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-05 12:03
1022	COPPER, FREE	200.8		0.0107 ppm	1.3 ppm	AS	2016-02-05 12:03

Comments: 6M12016 / SITE 14 / 125 CARPENTER DRIVE / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D'JANO GAINES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-011PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0034 ppm	0.015 ppm	AS	2016-02-05 12:05
1022	COPPER, FREE	200.8	0.0358 ppm	1.3 ppm	AS	2016-02-05 12:05

Comments: 6M12016 / SITE 133 / 414 WOODY DRIVE / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	K. ODOM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-012PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2016-02-05 12:07
1022	COPPER, FREE	200.8	0.0503 ppm	1.3 ppm	AS	2016-02-05 12:07

Comments: 6M12016 / SITE 85 / 166 DURANVILLE DRIVE / 39212

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLEVELAND RAY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-04 09:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-04
SAMPLE POINT	DS000	**LAB ID**	160204-013PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0033 ppm	0.015 ppm	AS	2016-02-10 13:40
1022	COPPER, FREE	200.8	0.0788 ppm	1.3 ppm	AS	2016-02-10 13:40

Comments: 6M12016 / SITE 50 / 358 OLD SPANISH TRAIL

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LENORE HICKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-08 13:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-08
SAMPLE POINT	WL007	**LAB ID**	160208-001PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION MADDOX RD & HWY 18■MSGW-15813, Well # M 0127

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-02-10 13:45
1022	COPPER, FREE	200.8	0.0029 ppm	1.3 ppm	AS	2016-02-10 13:45

Comments: 6M12016 / MADDOX RD. WELL

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHANIE WOLFE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 13:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-18
SAMPLE POINT	IN072	**LAB ID**	160218-001PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION	RESERVOIR INTAKE - CURTIS PLANT				

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2016-02-23 12:55
1022	COPPER, FREE	200.8	0.2284 ppm	1.3 ppm	AS	2016-02-23 12:55

Comments: INTAKE IN072 (OB CURTIS)

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHANIE WOLFE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 14:04
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-18
SAMPLE POINT	WL003	**LAB ID**	160218-002PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION SOUTH OF TV RD AND E OF MADDOX RD■MSGW-02702, Well # M 0099

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-23 12:57
1022	COPPER, FREE	200.8		0.0063 ppm	1.3 ppm	AS	2016-02-23 12:57

Comments: WELL W003 MADDOX

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHANIE WOLFE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 14:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-18
SAMPLE POINT	WL006	**LAB ID**	160218-003PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION SO OF HWY 18 AND WEST OF SIWELL ROAD■MSGW-02707, Well # M 0117

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	AS	2016-02-23 13:00
1022	COPPER, FREE	200.8	0.008 ppm	1.3 ppm	AS	2016-02-23 13:00

Comments: WELL W006

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHANIE WOLFE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 14:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-18
SAMPLE POINT	WL007	**LAB ID**	160218-004PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION	MADDOX RD & HWY 18■MSGW-15813, Well # M 0127				

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-02-23 13:02
1022	COPPER, FREE	200.8		0.0011 ppm	1.3 ppm	AS	2016-02-23 13:02

Comments: WELL W007

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHANIE WOLFE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 14:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-18
SAMPLE POINT	WL002	**LAB ID**	160218-005PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION WILLOWOOD S/D E OF SIWELL RD■MSGW-02704, Well # M 0104■former 0250012-02, now 0250008-02

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-02-23 13:05
1022	COPPER, FREE	200.8	0.0318 ppm	1.3 ppm	AS	2016-02-23 13:05

Comments: WELL W002 TV RD

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHANIE WOLFE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 14:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-18
SAMPLE POINT	WL005	**LAB ID**	160218-006PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION EAST OF SIWELL RD AND NO OF MCCLUER RD■MSGW-02706, Well # M 0112

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0034 ppm	0.015 ppm	AS	2016-02-23 13:08
1022	COPPER, FREE	200.8	0.0132 ppm	1.3 ppm	AS	2016-02-23 13:08

Comments: WELL WOO5

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHANIE WOLFE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 14:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-18
SAMPLE POINT	IN071	**LAB ID**	160218-007PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION	PEARL RIVER INTAKE - FEWELL PLANT				

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2016-02-23 13:22
1022	COPPER, FREE	200.8	0.0403 ppm	1.3 ppm	AS	2016-02-23 13:22

Comments: INTAKE IN071 (FEWELL)

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PHILLIP PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-17 18:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-19
SAMPLE POINT	DS000	**LAB ID**	160219-001PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.2031** ppm	0.015 ppm	AS	2016-02-23 13:28
1022	COPPER, FREE	200.8	0.2236 ppm	1.3 ppm	AS	2016-02-23 13:28

Comments: SITE 228 / 908 NEWLAND DRIVE / SAMPLE TAKEN FROM BATHROOM SELDOM USED

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PHILLIP PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-19
SAMPLE POINT	DS000	**LAB ID**	160219-002PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0031 ppm	0.015 ppm	AS	2016-02-23 13:30
1022	COPPER, FREE	200.8	0.1323 ppm	1.3 ppm	AS	2016-02-23 13:30

Comments: SITE 228 / 908 NEWLAND DRIVE

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEARL RANDLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-19
SAMPLE POINT	DS000	**LAB ID**	160219-003PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0104 ppm	0.015 ppm	AS	2016-02-23 13:33
1022	COPPER, FREE	200.8	0.0434 ppm	1.3 ppm	AS	2016-02-23 13:33

Comments: SITE 187 / 5901 WOODHAVEN RD. / WITH FILTER

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEARL RANDLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 07:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-19
SAMPLE POINT	DS000	**LAB ID**	160219-004PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0105 ppm	0.015 ppm	AS	2016-02-23 13:35
1022	COPPER, FREE	200.8	0.1058 ppm	1.3 ppm	AS	2016-02-23 13:35

Comments: SITE 187 / 5907 WOODHAVEN RD. / WITHOUT FILTER

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 05:41
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-19
SAMPLE POINT	DS000	**LAB ID**	160219-005PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0234** ppm	0.015 ppm	AS	2016-02-23 13:49
1022	COPPER, FREE	200.8	0.712 ppm	1.3 ppm	AS	2016-02-23 13:49

Comments: SITE 249 / 2030 SHEFFIELD DRIVE

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARK LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-18 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-19
SAMPLE POINT	DS000	**LAB ID**	160219-006PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	AS	2016-02-23 13:51
1022	COPPER, FREE	200.8	0.3964 ppm	1.3 ppm	AS	2016-02-23 13:51

Comments: 6M12016 / SITE 246 / 1709 SHEFFIELD DRIVE

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MS. INGRAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-23 06:49
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-23
SAMPLE POINT	DS000	**LAB ID**	160223-001PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0504** ppm	0.015 ppm	AS	2016-02-25 14:07
1022	COPPER, FREE	200.8	0.3029 ppm	1.3 ppm	AS	2016-02-25 14:07

Comments: SITE 180 / 546 WITSELL RD.

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-23 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-23
SAMPLE POINT	DS000	**LAB ID**	160223-002PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	SP		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0126 ppm	0.015 ppm	AS	2016-02-25 14:10
1022	COPPER, FREE	200.8	0.0807 ppm	1.3 ppm	AS	2016-02-25 14:10

Comments: SITE 84 / 164 DURANVILLE DR.

Generated 2016-05-13

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VANCE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-29 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-29
SAMPLE POINT	DS000	**LAB ID**	160229-001PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0393** ppm	0.015 ppm	AS	2016-03-02 14:22
1022	COPPER, FREE	200.8	0.0551 ppm	1.3 ppm	AS	2016-03-02 14:22

Comments: SITE 224 / 5481 KAYWOOD DRIVE

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MR. PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-02-29 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-02-29
SAMPLE POINT	DS000	**LAB ID**	160229-002PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	AS	2016-03-02 14:36
1022	COPPER, FREE	200.8	0.0755 ppm	1.3 ppm	AS	2016-03-02 14:36

Comments: SITE 228 / 908 NEWLAND DRIVE

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BUD PACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-03-01 05:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-03-01
SAMPLE POINT	DS000	**LAB ID**	160301-008PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-03-02 16:25
1022	COPPER, FREE	200.8	0.3987 ppm	1.3 ppm	AS	2016-03-02 16:25

Comments: 1253 EASTOVER DR. 39211 / SCHOOL FOR DEAF AND BLIND

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NELDA J. MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-03-01 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-03-01
SAMPLE POINT	DS000	**LAB ID**	160301-007PB	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.006 ppm	0.015 ppm	AS	2016-03-02 16:11
1022	COPPER, FREE	200.8	0.2445 ppm	1.3 ppm	AS	2016-03-02 16:11

Comments: 5560 TERRY RD.

EnviroChem, Inc.
Environmental Laboratories

4320 Midmost Drive Mobile, Alabama 36609
Phone (251) 344-9106 Fax (251) 341-9492

Report Date: 02/01/16 14:25

Sample Name: 908 Newland St.

Sample Date: 01/29/16 06:15 Date Received: 01/29/16 20:05 Sampled by: Client

Sample Type: Grab

Matrix: Drinking Water

Analyte	Result	Units	Reporting Limit	Analyst	Prepared	Analyzed	Method	Batch	Lab Number	Qualifier
Metals by EPA 200 Series Methods										
Copper	0.36	mg/L	0.01	ENC	01/30/16 09:38	01/30/16 18:58	EPA 200.8	6A30003	16A0572-01	
Lead	0.476	mg/L	0.005	ENC	01/30/16 09:38	01/30/16 18:58	EPA 200.8	6A30003	16A0572-01	

ACCREDITED IN ACCORDANCE WITH

The test results in this report meet NELAP requirements for accredited parameters, unless otherwise noted, and relate only to the sample(s) received by this laboratory. This report must be reproduced in its entirety unless approved by the laboratory.

Results are reported on a "wet weight basis", unless otherwise noted.

MS Public Health Laboratory
Drinking Water
Page 2 of 5

EnviroChem, Inc.
Environmental Laboratories

4320 Midmost Drive Mobile, Alabama 36609
Phone (251) 344-9106 Fax (251) 341-9492

Report Date: 02/01/16 14:19

Sample Name: 5481 Kaywood Dr.
Sample Date: 01/29/16 06:15
Date Received: 01/29/16 20:05
Sampled by: Client
Sample Type: Grab
Matrix: Drinking Water

Analyte	Result	Units	Reporting Limit	Analyst	Prepared	Analyzed	Method	Batch	Lab Number	Qualifier
Metals by EPA 200 Series Methods										
Copper	0.31	mg/L	0.01	ENC	01/30/16 09:38	01/30/16 21:28	EPA 200.8	6A30003	16A0586-01	
Lead	0.022	mg/L	0.005	ENC	01/30/16 09:38	01/30/16 21:28	EPA 200.8	6A30003	16A0586-01	

ACCREDITED IN ACCORDANCE WITH nelac

The test results in this report meet NELAP requirements for accredited parameters, unless otherwise noted, and relate only to the sample(s) received by this laboratory. This report must be reproduced in its entirety unless approved by the laboratory.

Results are reported on a "wet weight basis", unless otherwise noted.

MS Public Health Laboratory
Drinking Water
Page 2 of 5

EnviroChem, Inc.
Environmental Laboratories

4320 Midmost Drive Mobile, Alabama 36609
Phone (251) 344-9106 Fax (251) 341-9492

Report Date: 02/01/16 14:42

Sample Name: 2030 Sheffield Dr.

Sample Date: 01/29/16 07:00 Date Received: 01/29/16 20:05 Sampled by: Client

Sample Type: Grab

Matrix: Drinking Water

Analyte	Result	Units	Reporting Limit	Analyst	Prepared	Analyzed	Method	Batch	Lab Number	Qualifier
Metals by EPA 200 Series Methods										
Copper	0.71	mg/L	0.01	ENC	01/30/16 09:36	01/30/16 12:28	EPA 200.8	6A30002	16A0553-01	
Lead	0.016	mg/L	0.005	ENC	01/30/16 09:36	01/30/16 12:28	EPA 200.8	6A30002	16A0553-01	

ACCREDITED IN ACCORDANCE WITH nelac

The test results in this report meet NELAP requirements for accredited parameters, unless otherwise noted, and relate only to the sample(s) received by this laboratory. This report must be reproduced in its entirety unless approved by the laboratory.

Results are reported on a "wet weight basis", unless otherwise noted.

MS Public Health Laboratory
Drinking Water
Page 2 of 5

EnviroChem, Inc.
Environmental Laboratories

4320 Midmost Drive Mobile, Alabama 36609
Phone (251) 344-9106 Fax (251) 341-9492

Report Date: 02/01/16 14:37

Sample Name: 5907 Woodhaven

Sample Type: Grab

Sample Date: 01/29/16 11:00 Date Received: 01/29/16 20:05 Sampled by: Client

Matrix: Drinking Water

Analyte	Result	Units	Reporting Limit	Analyst	Prepared	Analyzed	Method	Batch	Lab Number	Qualifier
Metals by EPA 200 Series Methods										
Copper	0.10	mg/L	0.01	ENC	01/30/16 09:36	01/30/16 12:55	EPA 200.8	6A30002	16A0557-01	
Lead	0.016	mg/L	0.005	ENC	01/30/16 09:36	01/30/16 12:55	EPA 200.8	6A30002	16A0557-01	

ACCREDITED IN ACCORDANCE WITH nelac

The test results in this report meet NELAP requirements for accredited parameters, unless otherwise noted, and relate only to the sample(s) received by this laboratory. This report must be reproduced in its entirety unless approved by the laboratory.

Results are reported on a "wet weight basis", unless otherwise noted.

MS Public Health Laboratory
Drinking Water
Page 2 of 5

EnviroChem, Inc.
Environmental Laboratories

4320 Midmost Drive Mobile, Alabama 36609
Phone (251) 344-9106 Fax (251) 341-9492

Report Date: 02/01/16 14:23

Sample Name: 1055 Newland St.

Sample Date: 01/29/16 08:20 Date Received: 01/29/16 20:05 Sampled by: Client

Sample Type: Grab

Matrix: Drinking Water

Analyte	Result	Units	Reporting Limit	Analyst	Prepared	Analyzed	Method	Batch	Lab Number	Qualifier
Metals by EPA 200 Series Methods										
Copper	0.68	mg/L	0.01	ENC	01/30/16 09:38	01/30/16 19:25	EPA 200.8	6A30003	16A0576-01	
Lead	0.018	mg/L	0.005	ENC	01/30/16 09:38	01/30/16 19:25	EPA 200.8	6A30003	16A0576-01	

ACCREDITED IN ACCORDANCE WITH TNI

The test results in this report meet NELAP requirements for accredited parameters, unless otherwise noted, and relate only to the sample(s) received by this laboratory. This report must be reproduced in its entirety unless approved by the laboratory.

Results are reported on a "wet weight basis", unless otherwise noted.

MS Public Health Laboratory
Drinking Water
Page 2 of 5

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	# Samples	Copper 90th	# Samples
07/01/2016-12/31/2016 (6 Month)	0.017 mg/L *	120	0.1 mg/L	120
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBRA MILLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-017PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0189** ppm	0.015 ppm	AS	2016-08-29 17:35
1022	COPPER, FREE	200.8	0.0503 ppm	1.3 ppm	AS	2016-08-29 17:35

Comments: 6M / SITE 291 / 1930 AMBLEWOOD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FREDERICK KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-018PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0146 ppm	0.015 ppm	AS	2016-08-29 17:37
1022	COPPER, FREE	200.8	0.1011 ppm	1.3 ppm	AS	2016-08-29 17:37

Comments: 6M / SITE 293 / 6252 AMBLEWOOD DR - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE COLLINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 03:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-019PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0078 ppm	0.015 ppm	AS	2016-08-29 17:39
1022	COPPER, FREE	200.8	0.0515 ppm	1.3 ppm	AS	2016-08-29 17:39

Comments: 6M / SITE 289 / 6319 AMBLEWOOD CT - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAREK ASHLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-020PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0033 ppm	0.015 ppm	AS	2016-08-29 17:41
1022	COPPER, FREE	200.8	0.0878 ppm	1.3 ppm	AS	2016-08-29 17:41

Comments: 6M / SITE 290 / 6313 AMBLEWOOD - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BOBBY BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-021PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2016-08-29 17:43
1022	COPPER, FREE	200.8	0.1571 ppm	1.3 ppm	AS	2016-08-29 17:43

Comments: 6M / SITE 350 / 104 COLONY SQUARE - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KEIONA CAVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 16:19
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-022PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0063 ppm	0.015 ppm	AS	2016-08-29 17:58
1022	COPPER, FREE	200.8	0.0669 ppm	1.3 ppm	AS	2016-08-29 17:58

Comments: 6M / SITE 351 / 108 COLONY SQUARE - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SMITH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-023PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-08-29 18:00
1022	COPPER, FREE	200.8		0.0207	ppm	1.3	ppm	AS	2016-08-29 18:00

Comments: 6M / SITE 135 / 129 W COHEA ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HELEN HUDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-024PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-08-29 18:03
1022	COPPER, FREE	200.8	0.009 ppm	1.3 ppm	AS	2016-08-29 18:03

Comments: 6M / SITE 124 / 338 E. DAVIS STREET - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE CRAWFORD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-025PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 18:05
1022	COPPER, FREE	200.8		0.0117 ppm	1.3 ppm	AS	2016-08-29 18:05

Comments: 6M / SITE 138 / 128 W COHEA ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BIRDIA M. GRIFFIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-026PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 18:07
1022	COPPER, FREE	200.8		0.0064 ppm	1.3 ppm	AS	2016-08-29 18:07

Comments: 6M / SITE 134 / 123 W. COHEA ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBORAH JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-027PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 18:09
1022	COPPER, FREE	200.8		0.0033 ppm	1.3 ppm	AS	2016-08-29 18:09

Comments: 6M / SITE 130 / 314 NEARVIEW - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MYKEL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-26 06:37
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-028PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 18:11
1022	COPPER, FREE	200.8		0.0076 ppm	1.3 ppm	AS	2016-08-29 18:11

Comments: 6M / SITE 160 / 235 E. BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA WILSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-029PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2016-08-29 18:26
1022	COPPER, FREE	200.8	0.0099 ppm	1.3 ppm	AS	2016-08-29 18:26

Comments: 6M / SITE 126 / 346 E. DAVIS STREET - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DOROTHY GRAVES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-030PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 18:28
1022	COPPER, FREE	200.8		0.0086 ppm	1.3 ppm	AS	2016-08-29 18:28

Comments: 6M / SITE 167 / 112 NOEL STREET - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARIILYN BUSSUM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-031PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 18:30
1022	COPPER, FREE	200.8		0.0075 ppm	1.3 ppm	AS	2016-08-29 18:30

Comments: 6M / SITE 171 / 310 MCKEE ST - FACE BOWL

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL WELLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 23:43
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-032PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-08-29 18:33
1022	COPPER, FREE	200.8	0.0186 ppm	1.3 ppm	AS	2016-08-29 18:33

Comments: 6M / SITE 145 / 236 E COHEA - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALBERT ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-033PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	AS	2016-08-29 18:35
1022	COPPER, FREE	200.8	0.0923 ppm	1.3 ppm	AS	2016-08-29 18:35

Comments: 6M / SITE 146 / 240 E. COHEA STREET - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	OBEDIAH CURTIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-034PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 18:37
1022	COPPER, FREE	200.8		0.0065 ppm	1.3 ppm	AS	2016-08-29 18:37

Comments: 6M / SITE 139 / 143 W. COHEA STREET - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SOPHIA NEWSOME	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 23:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-035PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-29 18:39
1022	COPPER, FREE	200.8	0.018 ppm	1.3 ppm	AS	2016-08-29 18:39

Comments: 6M / SITE 179 / 355 MCKEE ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARNER BRISTER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 13:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-036PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-29 18:54
1022	COPPER, FREE	200.8	0.0071 ppm	1.3 ppm	AS	2016-08-29 18:54

Comments: 6M / SITE 125 / 340 E. DAVIS ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEDRA CURRE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 09:04
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-037PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2016-08-29 18:56
1022	COPPER, FREE	200.8	0.0067 ppm	1.3 ppm	AS	2016-08-29 18:56

Comments: 6M / SITE 123 / 330 E. DAVIS ST - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 13:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-038PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	AS	2016-08-29 18:58
1022	COPPER, FREE	200.8	0.0103 ppm	1.3 ppm	AS	2016-08-29 18:58

Comments: 6M / SITE 122 / 316 E. DAVIS ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-039PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-08-29 19:00
1022	COPPER, FREE	200.8	0.0087 ppm	1.3 ppm	AS	2016-08-29 19:00

Comments: 6M / SITE 179 / 361 MCKEE STREET - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA HUTSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-040PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-29 19:03
1022	COPPER, FREE	200.8	0.01 ppm	1.3 ppm	AS	2016-08-29 19:03

Comments: 6M / SITE 127 / 352 E. DAVIS ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DANITA VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-041PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 19:05
1022	COPPER, FREE	200.8		0.0059 ppm	1.3 ppm	AS	2016-08-29 19:05

Comments: 6M / SITE 187 / 184 WHITFIELD ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAPHNE WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-042PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-29 19:07
1022	COPPER, FREE	200.8	0.0172 ppm	1.3 ppm	AS	2016-08-29 19:07

Comments: 6M / SITE 186 / 188 WHITFIELD ST - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FELICIA PINKSTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:09
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-043PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-08-29 19:22
1022	COPPER, FREE	200.8		0.0553	ppm	1.3	ppm	AS	2016-08-29 19:22

Comments: 6M / SITE 197 / 1217 BLAIR ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARK LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-044PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-08-29 19:24
1022	COPPER, FREE	200.8	0.0458 ppm	1.3 ppm	AS	2016-08-29 19:24

Comments: 6M / SITE 239 / 1709 SHEFFIELD DRIVE / MASTER BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATSY MINER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-045PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-29 19:26
1022	COPPER, FREE	200.8	0.0156 ppm	1.3 ppm	AS	2016-08-29 19:26

Comments: 6M / SITE 206 / 238 E. ASH ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ESTHER W. JILES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:42
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-046PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-08-29 19:28
1022	COPPER, FREE	200.8	0.0124 ppm	1.3 ppm	AS	2016-08-29 19:28

Comments: 6M / SITE 241 E. ASH - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE E. RAWLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 09:03
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-047PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 19:31
1022	COPPER, FREE	200.8		0.0102 ppm	1.3 ppm	AS	2016-08-29 19:31

Comments: 6M / SITE 149 / 187 E. BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MOSES OWENS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 10:22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-048PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	AS	2016-08-29 19:33
1022	COPPER, FREE	200.8	0.0408 ppm	1.3 ppm	AS	2016-08-29 19:33

Comments: 6M / SITE 161 / 237 E. BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARMITHA SCOTT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 02:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-049PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-08-29 19:35
1022	COPPER, FREE	200.8	0.0101 ppm	1.3 ppm	AS	2016-08-29 19:35

Comments: 6M / SITE 155 / 204 E. BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE BRACEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-050PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 19:50
1022	COPPER, FREE	200.8		0.0109 ppm	1.3 ppm	AS	2016-08-29 19:50

Comments: 6M / SITE 151 / 161 E. BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EDWARDS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-051PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 19:52
1022	COPPER, FREE	200.8		0.0031 ppm	1.3 ppm	AS	2016-08-29 19:52

Comments: 6M / SITE 162 / 239 E. BELL ST - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARY BURKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-052PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 19:54
1022	COPPER, FREE	200.8		0.1597 ppm	1.3 ppm	AS	2016-08-29 19:54

Comments: 6M / SITE 154 / 200 E. BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TIMOTHY BOOKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 21:16
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-053PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-08-29 19:56
1022	COPPER, FREE	200.8	0.0531 ppm	1.3 ppm	AS	2016-08-29 19:56

Comments: 6M / SITE 235 / 408 EASTVIEW ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LUCILLE BUCK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-054PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2016-08-29 19:59
1022	COPPER, FREE	200.8	0.0123 ppm	1.3 ppm	AS	2016-08-29 19:59

Comments: 6M / SITE 185 / 156 WHITFIELD ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VICTOR COLEMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-055PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-08-29 20:01
1022	COPPER, FREE	200.8	0.0502 ppm	1.3 ppm	AS	2016-08-29 20:01

Comments: 6M / SITE 237 / 414 EASTVIEW - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:28
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-056PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 20:03
1022	COPPER, FREE	200.8		0.008 ppm	1.3 ppm	AS	2016-08-29 20:03

Comments: 6M / SITE 184 / 144 WHITFIELD ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ILETA DISHMEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 19:51
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-057PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	AS	2016-08-29 20:18
1022	COPPER, FREE	200.8	0.1483 ppm	1.3 ppm	AS	2016-08-29 20:18

Comments: 6M / SITE 212 / 257 E. ASH ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVE H. PERKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 19:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-058PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0066 ppm	0.015 ppm	AS	2016-08-29 20:20
1022	COPPER, FREE	200.8	0.0479 ppm	1.3 ppm	AS	2016-08-29 20:20

Comments: 6M / SITE 281 / 6248 WATERFORD DR - MASTER BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RESA WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-26 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-059PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 20:22
1022	COPPER, FREE	200.8		0.012 ppm	1.3 ppm	AS	2016-08-29 20:22

Comments: 6M / SITE 213 / 263 E. ASH - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARTHA JO VANCE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-26 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-060PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-08-29 20:24
1022	COPPER, FREE	200.8		0.0119	ppm	1.3	ppm	AS	2016-08-29 20:24

Comments: 6M / SITE 238 / 5481 KAYWOOD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY RICHARDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-26 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-061PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.022** ppm	0.015 ppm	AS	2016-08-29 20:27
1022	COPPER, FREE	200.8	0.0676 ppm	1.3 ppm	AS	2016-08-29 20:27

Comments: 6M / SITE 326 / 513 WITSEL RD - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:16
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-062PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0108 ppm	0.015 ppm	AS	2016-08-29 20:29
1022	COPPER, FREE	200.8	0.1172 ppm	1.3 ppm	AS	2016-08-29 20:29

Comments: 6M / SITE 240 / 2030 SHEFFIELD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LARRY HAGGARD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 12:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-063PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0033 ppm	0.015 ppm	AS	2016-08-29 20:31
1022	COPPER, FREE	200.8	0.0657 ppm	1.3 ppm	AS	2016-08-29 20:31

Comments: 6M / SITE 296 / 1615 FAIRWOOD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAVON LANE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-064PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	AS	2016-08-29 20:46
1022	COPPER, FREE	200.8	0.0799 ppm	1.3 ppm	AS	2016-08-29 20:46

Comments: 6M / SITE 258 / 1568 NORTHLAKE DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HILDA PERRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 03:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-065PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0062 ppm	0.015 ppm	AS	2016-08-29 20:48
1022	COPPER, FREE	200.8	0.0228 ppm	1.3 ppm	AS	2016-08-29 20:48

Comments: 6M / SITE 29 / 1220 BROOKHOLLOW CIR - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	E.T. RIENER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-066PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0234** ppm	0.015 ppm	AS	2016-08-29 20:50
1022	COPPER, FREE	200.8	0.4165 ppm	1.3 ppm	AS	2016-08-29 20:50

Comments: 6M / SITE 58 / 2335 N. PINE LEA DR - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AGNES WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:37
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-067PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0045 ppm	0.015 ppm	AS	2016-08-29 20:52
1022	COPPER, FREE	200.8	0.1431 ppm	1.3 ppm	AS	2016-08-29 20:52

Comments: 6M / SITE 68 / 419 SHARON HILLS DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATRICIA R.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-068PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.008 ppm	0.015 ppm	AS	2016-08-29 20:55
1022	COPPER, FREE	200.8	0.0421 ppm	1.3 ppm	AS	2016-08-29 20:55

Comments: 6M / SITE 21 / 5022 KAY BROOK DR - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE CHAPPELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-069PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2016-08-29 20:57
1022	COPPER, FREE	200.8	0.0212 ppm	1.3 ppm	AS	2016-08-29 20:57

Comments: 6M / SITE 22 / 5061 KAY BROOK - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENE AMOS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 07:28
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-070PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-08-29 20:59
1022	COPPER, FREE	200.8		0.1209	ppm	1.3	ppm	AS	2016-08-29 20:59

Comments: 6M / SITE 159 / 334 E BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 16:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-071PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 21:14
1022	COPPER, FREE	200.8		0.0357 ppm	1.3 ppm	AS	2016-08-29 21:14

Comments: 6M / SITE 131 / 303 SPANISH CT - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LISAREE WEST	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-072PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 21:16
1022	COPPER, FREE	200.8		0.0067 ppm	1.3 ppm	AS	2016-08-29 21:16

Comments: 6M / SITE 181 / 265 E DAVIS ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BETTY BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 11:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-073PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 21:18
1022	COPPER, FREE	200.8		0.0069 ppm	1.3 ppm	AS	2016-08-29 21:18

Comments: 6M / SITE 166 / 108 NOEL ST - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVID BLAKELEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 20:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-074PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-29 21:21
1022	COPPER, FREE	200.8		0.0097 ppm	1.3 ppm	AS	2016-08-29 21:21

Comments: 6M / SITE 129 / 309 NEAURVIEW ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LATORYA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 11:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-075PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2016-08-29 21:23
1022	COPPER, FREE	200.8	0.2582 ppm	1.3 ppm	AS	2016-08-29 21:23

Comments: 6M / SITE 157 / 346 E BELL ST - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JUDY HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-076PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-08-29 21:25
1022	COPPER, FREE	200.8	0.0218 ppm	1.3 ppm	AS	2016-08-29 21:25

Comments: 6M / SITE 28 / 1704 BROOKHOLLOW CIRCLE - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 16:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-077PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-29 21:27
1022	COPPER, FREE	200.8	0.0402 ppm	1.3 ppm	AS	2016-08-29 21:27

Comments: 6M / SITE 27 / 5477 BROOKHOLLOW DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARTER CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-078PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0037 ppm	0.015 ppm	AS	2016-08-29 21:42
1022	COPPER, FREE	200.8	0.0731 ppm	1.3 ppm	AS	2016-08-29 21:42

Comments: 6M / SITE 297 1609 FAIRWOOD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BEA CREIGHTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 17:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-079PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2016-08-29 21:44
1022	COPPER, FREE	200.8	0.0729 ppm	1.3 ppm	AS	2016-08-29 21:44

Comments: 6M / SITE 19 / 5014 RAYBROOK DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VELMA JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-080PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0321** ppm	0.015 ppm	AS	2016-08-29 21:47
1022	COPPER, FREE	200.8	0.1623 ppm	1.3 ppm	AS	2016-08-29 21:47

Comments: 6M / SITE 283 / 6663 L.B. JOHNSON - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PAMELA EUBANKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-081PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0398** ppm	0.015 ppm	AS	2016-08-29 21:49
1022	COPPER, FREE	200.8	0.031 ppm	1.3 ppm	AS	2016-08-29 21:49

Comments: 6M / SITE 273 / 25 ST ANDREWS DRIVE - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA L PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-082PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0124 ppm	0.015 ppm	AS	2016-08-29 21:51
1022	COPPER, FREE	200.8	0.0591 ppm	1.3 ppm	AS	2016-08-29 21:51

Comments: 6M / SITE 352 / 135 COLONY SQ - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BARBARA CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-083PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0044 ppm	0.015 ppm	AS	2016-08-29 21:53
1022	COPPER, FREE	200.8	0.1948 ppm	1.3 ppm	AS	2016-08-29 21:53

Comments: 6M / SITE 107 / 1120 N LAMAR ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JARRED HARPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 12:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-084PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2016-08-29 21:55
1022	COPPER, FREE	200.8	0.02 ppm	1.3 ppm	AS	2016-08-29 21:55

Comments: 6M / SITE 353 / 138 COLONY SQ - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAKEBA JACKSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 12:02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-085PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0036 ppm	0.015 ppm	AS	2016-08-30 14:03
1022	COPPER, FREE	200.8	0.2406 ppm	1.3 ppm	AS	2016-08-30 14:03

Comments: 6M / SITE 354 / 137 COLONY SQ - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODOSTER JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-086PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0051 ppm	0.015 ppm	AS	2016-08-30 14:06
1022	COPPER, FREE	200.8	0.0973 ppm	1.3 ppm	AS	2016-08-30 14:06

Comments: 6M / SITE 77 / 164 DURANVILLE ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TRACY WESTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-087PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2016-08-30 14:09
1022	COPPER, FREE	200.8	0.1212 ppm	1.3 ppm	AS	2016-08-30 14:09

Comments: 6M / SITE 30 / 1716 BROOKHOLLOW CIR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 18:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-088PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.004 ppm	0.015 ppm	AS	2016-08-30 14:11
1022	COPPER, FREE	200.8	0.1337 ppm	1.3 ppm	AS	2016-08-30 14:11

Comments: 6M / SITE 56 / 206 SUNDOWN TRL - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRANKIE L KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-26 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-089PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-30 14:14
1022	COPPER, FREE	200.8		0.0617 ppm	1.3 ppm	AS	2016-08-30 14:14

Comments: 6M / SITE 109 / 1111 N LAMAR ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAMES BROWN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 06:02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-090PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2016-08-30 14:16
1022	COPPER, FREE	200.8	0.1238 ppm	1.3 ppm	AS	2016-08-30 14:16

Comments: 6M / SITE 108 / 1130 N LAMAR ST APT A - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHERWANDA TAYLOR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-091PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0029 ppm	0.015 ppm	AS	2016-08-30 14:19
1022	COPPER, FREE	200.8	0.0273 ppm	1.3 ppm	AS	2016-08-30 14:19

Comments: 6M / SITE 26 / 5479 BROOKHOLLOW DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EDDIE CARVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 16:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-092PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2016-08-30 14:34
1022	COPPER, FREE	200.8	0.0582 ppm	1.3 ppm	AS	2016-08-30 14:34

Comments: 6M / SITE 105 / 1110 N LAMAR ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLEMON PARISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 08:54
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-093PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0897** ppm	0.015 ppm	AS	2016-08-30 14:36
1022	COPPER, FREE	200.8	0.1541 ppm	1.3 ppm	AS	2016-08-30 14:36

Comments: 6M / SITE 302 / 5911 FLORAL DRIVE - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CALVIN S. HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-094PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0054 ppm	0.015 ppm	AS	2016-08-30 14:38
1022	COPPER, FREE	200.8	0.0813 ppm	1.3 ppm	AS	2016-08-30 14:38

Comments: 6M / SITE 292 / 6239 AMBLEWOOD DR. - KITCHEN

Generated 2016-10-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAY C. NORALS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-095PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0212** ppm	0.015 ppm	AS	2016-08-30 14:40
1022	COPPER, FREE	200.8	0.2158 ppm	1.3 ppm	AS	2016-08-30 14:40

Comments: 6M / SITE 294 / 6412 AMBLEWOOD - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	R. BURNS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-096PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0166** ppm	0.015 ppm	AS	2016-08-30 14:42
1022	COPPER, FREE	200.8	0.0954 ppm	1.3 ppm	AS	2016-08-30 14:42

Comments: 6M / SITE 301 / 6512 CEDARWOOD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HERBIE NELSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-097PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-30 14:45
1022	COPPER, FREE	200.8		0.0269 ppm	1.3 ppm	AS	2016-08-30 14:45

Comments: 6M / SITE 292 / 6424 AMBLE WOOD PLACE - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KATHY RESTER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-098PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0108 ppm	0.015 ppm	AS	2016-08-30 14:47
1022	COPPER, FREE	200.8	0.097 ppm	1.3 ppm	AS	2016-08-30 14:47

Comments: 6M / SITE 23 / 5026 RAYBROOK DR- KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANTHONY KENNEDY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 11:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-099PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0857** ppm	0.015 ppm	AS	2016-08-30 15:01
1022	COPPER, FREE	200.8	0.1236 ppm	1.3 ppm	AS	2016-08-30 15:01

Comments: 6M / SITE 349 / 101 COLONY SQUARE - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELONIE HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 08:14
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-100PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0044 ppm	0.015 ppm	AS	2016-08-30 15:04
1022	COPPER, FREE	200.8	0.1578 ppm	1.3 ppm	AS	2016-08-30 15:04

Comments: 6M / SITE 300 / 6418 CEDARWOOD DR- KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALICE HUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-101PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	AS	2016-08-30 15:06
1022	COPPER, FREE	200.8	0.0751 ppm	1.3 ppm	AS	2016-08-30 15:06

Comments: 6M / SITE 282 / 6570 LBJ DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RALPH CLARK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-102PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0041 ppm	0.015 ppm	AS	2016-08-30 15:08
1022	COPPER, FREE	200.8	0.0303 ppm	1.3 ppm	AS	2016-08-30 15:08

Comments: 6M / SITE 284 / 6609 FRANK D ROOSEVELT - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EDDIE LAURIE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-103PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-30 15:10
1022	COPPER, FREE	200.8		0.0116 ppm	1.3 ppm	AS	2016-08-30 15:10

Comments: 6M / SITE 177 / 353 MCKEE ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RICHARD MORAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-104PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-08-30 15:12
1022	COPPER, FREE	200.8	0.0108 ppm	1.3 ppm	AS	2016-08-30 15:12

Comments: 6M / SITE 121 / 312 E DAVIS ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JEANNETTE PENQUTE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-105PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0144 ppm	0.015 ppm	AS	2016-08-30 15:14
1022	COPPER, FREE	200.8	0.0997 ppm	1.3 ppm	AS	2016-08-30 15:14

Comments: 6M / SITE 355 / 282 WOODY DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	E D WILSON SR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-106PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0106 ppm	0.015 ppm	AS	2016-08-30 15:29
1022	COPPER, FREE	200.8	0.1126 ppm	1.3 ppm	AS	2016-08-30 15:29

Comments: 6M / SITE 24 / 5039 KAY BROOK DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RASOUL SPRAGGING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-107PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-30 15:31
1022	COPPER, FREE	200.8		0.0124 ppm	1.3 ppm	AS	2016-08-30 15:31

Comments: 6M / SITE 173 / 320 MCKEE ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MINNIE BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-108PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-30 15:34
1022	COPPER, FREE	200.8	0.0061 ppm	1.3 ppm	AS	2016-08-30 15:34

Comments: 6M / SITE 181 / 326 E DAVIS ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CORNELL FOSTERS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-109PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2016-08-30 15:36
1022	COPPER, FREE	200.8		0.007	ppm	1.3	ppm	AS	2016-08-30 15:36

Comments: 6M / SITE 174 / 332 MCKEE ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PORTIA HINTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-110PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-30 15:38
1022	COPPER, FREE	200.8		0.0074 ppm	1.3 ppm	AS	2016-08-30 15:38

Comments: 6M / SITE 150 / 154 E BELL ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARLON BECKLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 16:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-111PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0045 ppm	0.015 ppm	AS	2016-08-30 15:40
1022	COPPER, FREE	200.8	0.0352 ppm	1.3 ppm	AS	2016-08-30 15:40

Comments: 6M / SITE 288 / 6306 AMBLEWOOD DOURT - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN A POTTS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-22 19:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-112PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2016-08-30 15:42
1022	COPPER, FREE	200.8	0.0192 ppm	1.3 ppm	AS	2016-08-30 15:42

Comments: 6M / SITE 202 / 141 E ASH ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA ALLEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-113PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0064 ppm	0.015 ppm	AS	2016-08-30 15:57
1022	COPPER, FREE	200.8	0.0759 ppm	1.3 ppm	AS	2016-08-30 15:57

Comments: 6M / SITE 203 / 227 E ASH - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MERIA ROBERTSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-114PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2016-08-30 15:59
1022	COPPER, FREE	200.8	0.0196 ppm	1.3 ppm	AS	2016-08-30 15:59

Comments: 6M / SITE 211 / 252 E ASHS T - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PINKIE JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-115PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0062 ppm	0.015 ppm	AS	2016-08-30 16:02
1022	COPPER, FREE	200.8	0.1095 ppm	1.3 ppm	AS	2016-08-30 16:02

Comments: 6M / SITE 204 / 229 E ASH ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	G JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 05:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-116PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-30 16:04
1022	COPPER, FREE	200.8		0.0107 ppm	1.3 ppm	AS	2016-08-30 16:04

Comments: 6M / SITE 208 / 248 E ASH ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-23 21:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-117PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.1226** ppm	0.015 ppm		
1022	COPPER, FREE	200.8	0.058 ppm	1.3 ppm	AS	2016-08-30 16:06

Comments: 6M / SITE 275 / 51 ST ANDREWS - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SCOTT WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-118PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2016-08-30 16:08
1022	COPPER, FREE	200.8	0.0088 ppm	1.3 ppm	AS	2016-08-30 16:08

Comments: 6M / SITE 279 / 6223 WATERFORD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VERSEL FLEMMING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-119PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2016-08-30 16:10
1022	COPPER, FREE	200.8	0.0117 ppm	1.3 ppm	AS	2016-08-30 16:10

Comments: 6M / SITE 191 / 221 WHITFIELD ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBBIE PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-120PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2016-08-30 16:25
1022	COPPER, FREE	200.8	0.0069 ppm	1.3 ppm	AS	2016-08-30 16:25

Comments: 6M / SITE 242 / 908 NEWLAND ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EMILY THORNTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 06:26
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-121PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0199** ppm	0.015 ppm	AS	2016-08-30 16:27
1022	COPPER, FREE	200.8	0.0244 ppm	1.3 ppm	AS	2016-08-30 16:27

Comments: 6M / SITE 244 / 950 NEWLAND ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHERYL ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-122PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0217** ppm	0.015 ppm	AS	2016-08-30 16:29
1022	COPPER, FREE	200.8	0.0559 ppm	1.3 ppm	AS	2016-08-30 16:29

Comments: 6M / SITE 329 / 5942 WHITESTONE RD - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEARL RANDLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:47
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-123PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0066 ppm	0.015 ppm	AS	2016-08-30 16:32
1022	COPPER, FREE	200.8	0.0632 ppm	1.3 ppm	AS	2016-08-30 16:32

Comments: 6M / SITE 328 / 5907 WOODHAVEN RD - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-124PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2016-08-30 16:34
1022	COPPER, FREE	200.8	0.0342 ppm	1.3 ppm	AS	2016-08-30 16:34

Comments: 6M / SITE 231 / 174 DELAWARE AVE - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	V. I.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-25 06:28
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-125PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0365** ppm	0.015 ppm	AS	2016-08-30 16:36
1022	COPPER, FREE	200.8	0.1155 ppm	1.3 ppm	AS	2016-08-30 16:36

Comments: 6M / SITE 327 / 546 - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	A P AUCHUS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-126PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2016-08-30 16:38
1022	COPPER, FREE	200.8		0.0251 ppm	1.3 ppm	AS	2016-08-30 16:38

Comments: 6M / SITE 272 / 16 ST ANDREWS DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN A FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-127PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2016-08-30 16:53
1022	COPPER, FREE	200.8	0.0433 ppm	1.3 ppm	AS	2016-08-30 16:53

Comments: 6M / SITE 330 / 6010 WHITESTONE RD - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SMOKEY ETHRIDGE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-128PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0058 ppm	0.015 ppm	AS	2016-08-30 16:55
1022	COPPER, FREE	200.8	0.0847 ppm	1.3 ppm	AS	2016-08-30 16:55

Comments: 6M / SITE 243 / 1055 NEWLAND ST - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOMEOWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 07:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-129PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0033 ppm	0.015 ppm	AS	2016-08-30 16:57
1022	COPPER, FREE	200.8	0.0652 ppm	1.3 ppm	AS	2016-08-30 16:57

Comments: 6M / SITE 331 / 6064 WHITESTONE RD - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SUSAN HARDEE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-130PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2016-08-30 16:59
1022	COPPER, FREE	200.8	0.0404 ppm	1.3 ppm	AS	2016-08-30 16:59

Comments: 6M / SITE 277 / 169 ST ANDREWS - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANTONIO JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-131PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0033 ppm	0.015 ppm	AS	2016-08-30 17:02
1022	COPPER, FREE	200.8	0.0254 ppm	1.3 ppm	AS	2016-08-30 17:02

Comments: 6M / SITE 332 / 6143 WHITESTONE RD - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THEO GOURAG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-132PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2016-08-30 17:04
1022	COPPER, FREE	200.8	0.0227 ppm	1.3 ppm	AS	2016-08-30 17:04

Comments: 6M / SITE 274 / 36 ST ANDREWS - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA TUCKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-133PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2016-08-30 17:06
1022	COPPER, FREE	200.8	0.0577 ppm	1.3 ppm	AS	2016-08-30 17:06

Comments: 6M / SITE 278 / 212 ST ANDREWS DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM F HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-134PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0064 ppm	0.015 ppm	AS	2016-08-30 17:21
1022	COPPER, FREE	200.8	0.0426 ppm	1.3 ppm	AS	2016-08-30 17:21

Comments: 6M / SITE 241 / 3951 EASTWOOD DR - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-24 06:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-26
SAMPLE POINT	DS000	**LAB ID**	160826-135PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0019 ppm	0.015 ppm	AS	2016-08-30 17:23
1022	COPPER, FREE	200.8	0.0271 ppm	1.3 ppm	AS	2016-08-30 17:23

Comments: 6M / SITE 333 / 6203 WHITESTONE RD - KITCHEN

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE A. PHILLIPS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-26 09:33
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-29
SAMPLE POINT	DS000	**LAB ID**	160829-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0024 ppm	0.015 ppm	AS	2016-08-30 17:25
1022	COPPER, FREE	200.8	0.0879 ppm	1.3 ppm	AS	2016-08-30 17:25

Comments: 6M / SITE 229 / 142 GLEN MARY ST - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROBERT TAPLIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2016-08-28 23:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2016-08-29
SAMPLE POINT	DS000	**LAB ID**	160829-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0039 ppm	0.015 ppm	AS	2016-08-30 17:27
1022	COPPER, FREE	200.8	0.0179 ppm	1.3 ppm	AS	2016-08-30 17:27

Comments: 6M / SITE 225 / 118 CLOVERLEAF CIRCLE - BATHROOM

Generated 2016-09-02

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	# Samples	Copper 90th	# Samples
01/01/2017-06/30/2017 (6 Month)	0.007 mg/L	114	0.1 mg/L	114
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATRICIA ROBINSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-012PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0023 ppm	0.015 ppm	AS	2017-05-12 12:24
1022	COPPER, FREE	200.8	0.0727 ppm	1.3 ppm	AS	2017-05-12 12:24

CORRECTIONS
↓
SITE 24 5039 KAY BROOK DR 39272

Comments: 6M2017 / SITE ~~22~~ / ~~5035~~ KAY BROOK DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-009PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0058 ppm	0.015 ppm	AS	2017-05-12 12:08
1022	COPPER, FREE	200.8	0.044 ppm	1.3 ppm	AS	2017-05-12 12:08

Comments: 6M2017 / SITE 77 / 164 DURANVILLE ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	E.. P.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-022PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.007 ppm	0.015 ppm	AS	2017-05-12 14:09
1022	COPPER, FREE	200.8	0.0993 ppm	1.3 ppm	AS	2017-05-12 14:09

Comments: 6M2017 / SITE 58 / 2335 N PINE LEA - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AGNES WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-026PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0035 ppm	0.015 ppm	AS	2017-05-12 14:31
1022	COPPER, FREE	200.8	0.1479 ppm	1.3 ppm	AS	2017-05-12 14:31

Comments: 6M2017 / SITE 68 / 419 SHARON HILLS DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TRACY WESTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-068PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 20:50
1022	COPPER, FREE	200.8		0.0528 ppm	1.3 ppm	AS	2017-05-12 20:50

Comments: 6M2017 / SITE 77 / 1716 BROOKHOLLOW CIR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-063PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	AS	2017-05-15 16:06
1022	COPPER, FREE	200.8	0.0634 ppm	1.3 ppm	AS	2017-05-15 16:06

Comments: 6M2017 / SITE 56 / 206 SUNDOWN TRAIL - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELISSA RESTER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-094PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-15 16:53
1022	COPPER, FREE	200.8	0.0191 ppm	1.3 ppm	AS	2017-05-15 16:53

Comments: 6M2017 / SITE 23 / 5026 KAY BROOK DR

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHARLES GIBSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-10 08:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-11
SAMPLE POINT	DS000	**LAB ID**	170511-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-15 20:19
1022	COPPER, FREE	200.8	0.0489 ppm	1.3 ppm	AS	2017-05-15 20:19

Comments: 6M2017 / SITE 19 / 5014 KAYBROOK DRIVE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEGGY STANSELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 13:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-087PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2017-05-15 15:45
1022	COPPER, FREE	200.8	0.1233 ppm	1.3 ppm	AS	2017-05-15 15:45

Comments: 6M2017 / SITE 21 / 5022 KAY BROOK DR - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE CHAPPELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-066PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2017-05-12 20:39
1022	COPPER, FREE	200.8	0.0227 ppm	1.3 ppm	AS	2017-05-12 20:39

Comments: 6M2017 / SITE 22 / 5061 KAY BROOK DR - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-064PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2017-05-12 20:28
1022	COPPER, FREE	200.8		0.0327	ppm	1.3	ppm	AS	2017-05-12 20:28

Comments: 6M2017 / SITE 27 / 5477 BROOKHOLLOW DR - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHERWANDA NAYLOR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 18:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-025PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2017-05-12 14:25
1022	COPPER, FREE	200.8	0.0276 ppm	1.3 ppm	AS	2017-05-12 14:25

Comments: 6M2017 / SITE 26 / 5479 BROOKHOLLOW - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JUDY HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-015PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.002 ppm	0.015 ppm	AS	2017-05-12 13:06
1022	COPPER, FREE	200.8	0.0521 ppm	1.3 ppm	AS	2017-05-12 13:06

Comments: 6M2017 / SITE 28 / 1704 BROOKHOLLOW - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	M. DILLON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-011PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-12 12:19
1022	COPPER, FREE	200.8	0.0316 ppm	1.3 ppm	AS	2017-05-12 12:19

Comments: 6M2017 / SITE 29 / 1720 BROOKHOLLOW CIRCLE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-027PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2017-05-12 14:36
1022	COPPER, FREE	200.8	0.0204 ppm	1.3 ppm	AS	2017-05-12 14:36

Comments: 6M2017 / SITE 333 / 6203 WHITESTONE RD - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	YOLANDA BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-028PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2017-05-12 14:41
1022	COPPER, FREE	200.8	0.0272 ppm	1.3 ppm	AS	2017-05-12 14:41

Comments: 6M2017 / SITE 331 / 6064 WHITESTONE RD - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANTONIO JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 07:11
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-030PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	AS	2017-05-12 15:18
1022	COPPER, FREE	200.8	0.0149 ppm	1.3 ppm	AS	2017-05-12 15:18

Comments: 6M2017 / SITE 332 / 6143 WHITESTONE RD - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D. INGRAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:16
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-058PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2017-05-12 19:31
1022	COPPER, FREE	200.8	0.0105 ppm	1.3 ppm	AS	2017-05-12 19:31

Comments: 6M2017 / SITE 327 / 546 WITSELL RD - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-037PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0025 ppm	0.015 ppm	AS	2017-05-12 16:21
1022	COPPER, FREE	200.8	0.03 ppm	1.3 ppm	AS	2017-05-12 16:21

Comments: 6M2017 / SITE 329 / 5942 WHITESTONE RD - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEARL RANDLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 12:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-095PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0093 ppm	0.015 ppm	AS	2017-05-15 16:59
1022	COPPER, FREE	200.8	0.0468 ppm	1.3 ppm	AS	2017-05-15 16:59

Comments: 6M2017 / SITE 328 / 5907 WOODHAVEN RD - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN A. FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:09
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-090PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0063 ppm	0.015 ppm	AS	2017-05-15 16:01
1022	COPPER, FREE	200.8	0.0277 ppm	1.3 ppm	AS	2017-05-15 16:01

Comments: 6M2017 / SITE 330 / 6010 WHITESTONE RD - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARYRICHARDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-032PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0179** ppm	0.015 ppm	AS	2017-05-12 15:28
1022	COPPER, FREE	200.8	0.0094 ppm	1.3 ppm	AS	2017-05-12 15:28

Comments: 6M2017 / SITE 326 / 513 WITSELL RD - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBRA MILLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 15:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-007PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0186** ppm	0.015 ppm	AS	2017-05-12 11:31
1022	COPPER, FREE	200.8	0.0466 ppm	1.3 ppm	AS	2017-05-12 11:31

Comments: 6M2017 / SITE 291 / 1930 AMBLEWOOD DRIVE - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STACEY PARISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:35
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-023PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.1301** ppm	0.015 ppm	AS	2017-05-12 14:14
1022	COPPER, FREE	200.8	0.0751 ppm	1.3 ppm	AS	2017-05-12 14:14

Comments: 6M2017 / SITE 302 / 5911 FLORAL DRIVE - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JOE LOWERY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 11:02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-078PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0038 ppm	0.015 ppm	AS	2017-05-12 22:35
1022	COPPER, FREE	200.8	0.0598 ppm	1.3 ppm	AS	2017-05-12 22:35

Comments: 6M2017 / SITE 299 / 600 CEDARWOOD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARLON BECKLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 16:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-073PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	AS	2017-05-12 21:42
1022	COPPER, FREE	200.8	0.0201 ppm	1.3 ppm	AS	2017-05-12 21:42

Comments: 6M2017 / SITE 288 / 6306 AMBLEWOOD COURT - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELONIE HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-065PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2017-05-12 20:34
1022	COPPER, FREE	200.8	0.0365 ppm	1.3 ppm	AS	2017-05-12 20:34

Comments: 6M2017 / SITE 300 / 6418 CEDARWOOD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ATHALIA KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-010PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-12 12:13
1022	COPPER, FREE	200.8	0.0213 ppm	1.3 ppm	AS	2017-05-12 12:13

Comments: 6M2017 / SITE 293 / 6252 AMBLEWOOD DR - GUEST BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAY C. NORALS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 19:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.008 ppm	0.015 ppm	AS	2017-05-12 10:59
1022	COPPER, FREE	200.8	0.1571 ppm	1.3 ppm	AS	2017-05-12 10:59

Comments: 6M2017 / SITE 294 / 6412 AMBLEWOOD PLACE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAREK ASHLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 17:17
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2017-05-12 11:04
1022	COPPER, FREE	200.8	0.5258 ppm	1.3 ppm	AS	2017-05-12 11:04

Comments: 6M2017 / SITE 289 / 6313 AMBLEWOOD COURT - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HUBIE NELSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-003PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 11:10
1022	COPPER, FREE	200.8		0.0423 ppm	1.3 ppm	AS	2017-05-12 11:10

Comments: 6M2017 / SITE 295 / 6424 AMBLEWOOD PLACE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CALVIN S. HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-004PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	AS	2017-05-12 11:15
1022	COPPER, FREE	200.8	0.0162 ppm	1.3 ppm	AS	2017-05-12 11:15

Comments: 6M2017 / SITE 292 / 6239 AMBLEWOOD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WALTER CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-005PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 11:21
1022	COPPER, FREE	200.8		0.0177 ppm	1.3 ppm	AS	2017-05-12 11:21

Comments: 6M2017 / SITE 296 / 1609 FAIRWOOD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE COLLINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-006PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0065 ppm	0.015 ppm	AS	2017-05-12 11:26
1022	COPPER, FREE	200.8	0.032 ppm	1.3 ppm	AS	2017-05-12 11:26

Comments: 6M2017 / SITE 290 / 6319 AMBLEWOOD COURT - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LARRY HAGGARD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 11:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-008PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2017-05-12 12:02
1022	COPPER, FREE	200.8	0.0404 ppm	1.3 ppm	AS	2017-05-12 12:02

Comments: 6M2017 / SITE 297 / 1615 FAIRWOOD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARTHA VANCE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-031PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 15:23
1022	COPPER, FREE	200.8		0.0304 ppm	1.3 ppm	AS	2017-05-12 15:23

Comments: 6M2017 / SITE 238 / 5481 KAYWOOD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-071PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0045 ppm	0.015 ppm	AS	2017-05-12 21:32
1022	COPPER, FREE	200.8	0.1316 ppm	1.3 ppm	AS	2017-05-12 21:32

Comments: 6M2017 / SITE 240 / 2030 SHEFFIELD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 07:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-072PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 21:37
1022	COPPER, FREE	200.8		0.0045 ppm	1.3 ppm	AS	2017-05-12 21:37

Comments: 6M2017 / SITE 239 / 1709 SHEFFIELD DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-077PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2017-05-15 18:13
1022	COPPER, FREE	200.8	0.0144 ppm	1.3 ppm	AS	2017-05-15 18:13

Comments: 6M2017 / SITE 241 / 3951 EASTWOOD DRIVE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KEITH SHUMAKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-086PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0101 ppm	0.015 ppm	AS	2017-05-15 15:39
1022	COPPER, FREE	200.8	0.0691 ppm	1.3 ppm	AS	2017-05-15 15:39

Comments: 6M2017 / SITE 243 / 1055 NEWLAND ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBBIE PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-084PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-15 19:16
1022	COPPER, FREE	200.8	0.0277 ppm	1.3 ppm	AS	2017-05-15 19:16

Comments: 6M2017 / SITE 242 / 908 NEWLAND ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVEY TUCKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-092PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2017-05-15 16:43
1022	COPPER, FREE	200.8	0.049 ppm	1.3 ppm	AS	2017-05-15 16:43

Comments: 6M2017 / SITE 278 / 212 ST. ANDREWS - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	T. C. G.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-081PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0063 ppm	0.015 ppm	AS	2017-05-12 22:51
1022	COPPER, FREE	200.8	0.0588 ppm	1.3 ppm	AS	2017-05-12 22:51

Comments: 6M2017 / SITE 274 / 36 ST. ANDREWS - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SUSAN HARDEE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-080PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2017-05-12 22:45
1022	COPPER, FREE	200.8	0.0391 ppm	1.3 ppm	AS	2017-05-12 22:45

Comments: 6M2017 / SITE 277 / 169 SAINT ANDREWS DRIVE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRED L. BANKS, JR.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 02:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-076PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2017-05-12 21:58
1022	COPPER, FREE	200.8		0.0177	ppm	1.3	ppm	AS	2017-05-12 21:58

Comments: 6M2017 / SITE 273 / 25 ST. ANDREWS DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EMILYTHORNTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-075PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.002 ppm	0.015 ppm	AS	2017-05-12 21:53
1022	COPPER, FREE	200.8	0.025 ppm	1.3 ppm	AS	2017-05-12 21:53

Comments: 6M2017 / SITE 244 / 950 NEWLAND ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVE H. PERKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 19:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-043PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	AS	2017-05-12 17:19
1022	COPPER, FREE	200.8	0.0498 ppm	1.3 ppm	AS	2017-05-12 17:19

Comments: 6M2017 / SITE 281 / 6248 WATERFORD DR - MASTER BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	M. A. WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-036PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0029 ppm	0.015 ppm	AS	2017-05-12 16:16
1022	COPPER, FREE	200.8	0.0708 ppm	1.3 ppm	AS	2017-05-12 16:16

Comments: 6M2017 / SITE 279 / 6223 WATER FORD DR - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-029PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2017-05-12 15:12
1022	COPPER, FREE	200.8		0.01	ppm	1.3	ppm	AS	2017-05-12 15:12

Comments: 6M2017 / SITE 272 / 16 ST ANDREWS - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	J. BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-021PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0036 ppm	0.015 ppm	AS	2017-05-12 13:38
1022	COPPER, FREE	200.8	0.028 ppm	1.3 ppm	AS	2017-05-12 13:38

Comments: 6M2017 / SITE 275 / 51 ST. ANDREWS DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	J. PENQUITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 05:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-016PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0263** ppm	0.015 ppm	AS	2017-05-12 13:11
1022	COPPER, FREE	200.8	0.0274 ppm	1.3 ppm	AS	2017-05-12 13:11

Comments: 6M2017 / SITE 355 / 282 WOODY DRIVE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROBERT CLARK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 08:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-020PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0049 ppm	0.015 ppm	AS	2017-05-12 13:33
1022	COPPER, FREE	200.8	0.0507 ppm	1.3 ppm	AS	2017-05-12 13:33

Comments: 6M2017 / SITE 284 / 6609 FDR DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALICE R. HUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 06:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-074PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2017-05-12 21:48
1022	COPPER, FREE	200.8		0.0286	ppm	1.3	ppm	AS	2017-05-12 21:48

Comments: 6M2017 / SITE 282 / 6570 LBJ DRIVE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 13:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-083PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0333** ppm	0.015 ppm	AS	2017-05-12 23:02
1022	COPPER, FREE	200.8	0.1764 ppm	1.3 ppm	AS	2017-05-12 23:02

Comments: 6M2017 / SITE 283 / 6663 LBJ DR - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TECORA OLIVER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-069PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0036 ppm	0.015 ppm	AS	2017-05-12 20:55
1022	COPPER, FREE	200.8	0.0202 ppm	1.3 ppm	AS	2017-05-12 20:55

Comments: 6M2017 / SITE 285 / 6756 G. WASHINGTON DR - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	BOBBY BLACKMAN	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:00
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	2017-05-08
COMPLIANCE	YES	**LAB ID**	170508-070PB	**COMPOSITED**	NO
		PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 17:10
1022	COPPER, FREE	200.8		0.0586 ppm	1.3 ppm	AS	2017-05-15 17:10

Comments: 6M2017 / SITE 350 / 104 COLONY SQUARE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KELONA CAVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 05:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-067PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0028 ppm	0.015 ppm	AS	2017-05-12 20:44
1022	COPPER, FREE	200.8	0.0333 ppm	1.3 ppm	AS	2017-05-12 20:44

Comments: 6M2017 / SITE 351 / 108 COLONY SQUARE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BARBARA BROADWATER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 09:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-034PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.027** ppm	0.015 ppm	AS	2017-05-12 15:39
1022	COPPER, FREE	200.8	0.1074 ppm	1.3 ppm	AS	2017-05-12 15:39

Comments: 6M2017 / SITE 352 / 135 COLONY SQUARE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-024PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 14:20
1022	COPPER, FREE	200.8		0.0239 ppm	1.3 ppm	AS	2017-05-12 14:20

Comments: 6M2017 / SITE 353 / 138 COLONY SQUARE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANTHONY KENNEDY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 09:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-013PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0119 ppm	0.015 ppm	AS	2017-05-12 12:29
1022	COPPER, FREE	200.8	0.0629 ppm	1.3 ppm	AS	2017-05-12 12:29

Comments: 6M2017 / SITE 349 / 101 COLONY SQUARE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALBERT ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-113PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2017-05-15 20:09
1022	COPPER, FREE	200.8	0.0882 ppm	1.3 ppm	AS	2017-05-15 20:09

Comments: 6M2017 / SITE 146 / 240 E. COHEA ST

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	B. BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 07:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-112PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 20:03
1022	COPPER, FREE	200.8		0.0223 ppm	1.3 ppm	AS	2017-05-15 20:03

Comments: 6M2017 / SITE 166 / 106 NOEL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVID GRAVES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-05 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-111PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2017-05-15 19:58
1022	COPPER, FREE	200.8	0.016 ppm	1.3 ppm	AS	2017-05-15 19:58

Comments: 6M2017 / SITE 167 / 118 NOEL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TUNICIA BURKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 08:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-110PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 19:53
1022	COPPER, FREE	200.8		0.5317 ppm	1.3 ppm	AS	2017-05-15 19:53

Comments: 6M2017 / SITE 154 / 200 E. BELL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 09:21
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-109PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 19:47
1022	COPPER, FREE	200.8		0.4268 ppm	1.3 ppm	AS	2017-05-15 19:47

Comments: 6M2017 / SITE 158 / 344 E. BELL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENA AMOS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-08 06:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-108PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 19:11
1022	COPPER, FREE	200.8		0.4224 ppm	1.3 ppm	AS	2017-05-15 19:11

Comments: 6M2017 / SITE 159 / 334 E. BELL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MOSES OWENS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 05:35
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-107PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2017-05-15 19:05
1022	COPPER, FREE	200.8	0.1101 ppm	1.3 ppm	AS	2017-05-15 19:05

Comments: 6M2017 / SITE 161 / 237 E. BELL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN RUSSUM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-08 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-106PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-15 19:00
1022	COPPER, FREE	200.8	0.0189 ppm	1.3 ppm	AS	2017-05-15 19:00

Comments: 6M2017 / SITE 171 / 310 MCKEE ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-105PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-15 18:55
1022	COPPER, FREE	200.8	0.0329 ppm	1.3 ppm	AS	2017-05-15 18:55

Comments: 6M2017 / SITE 160 / 234 E. BELL ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE CURTIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 09:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-104PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-15 18:49
1022	COPPER, FREE	200.8	0.0598 ppm	1.3 ppm	AS	2017-05-15 18:49

Comments: 6M2017 / SITE 134 / 123 W. COHEA ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CAMILLA SCOTT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 09:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-103PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2017-05-15 18:44
1022	COPPER, FREE	200.8	0.0232 ppm	1.3 ppm	AS	2017-05-15 18:44

Comments: 6M2017 / SITE 155 / 204 BELL STREET - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CYNTHIA HINTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-06 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-102PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-15 18:07
1022	COPPER, FREE	200.8	0.0131 ppm	1.3 ppm	AS	2017-05-15 18:07

Comments: 6M2017 / SITE 150 / 175 E BELL STREET - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL J. WELLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-05 10:26
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-101PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2017-05-15 18:02
1022	COPPER, FREE	200.8	0.0361 ppm	1.3 ppm	AS	2017-05-15 18:02

Comments: 6M2017 / SITE 145 / 236 E. COHEA STREET - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN FRANKLIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-05 06:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-100PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 17:57
1022	COPPER, FREE	200.8		0.0102 ppm	1.3 ppm	AS	2017-05-15 17:57

Comments: 6M2017 / SITE 174 / 332 MCKEE ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SMITH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-05 20:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-099PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2017-05-15 17:51
1022	COPPER, FREE	200.8		0.0302	ppm	1.3	ppm	AS	2017-05-15 17:51

Comments: 6M2017 / SITE 135 / 129 W. COHEA ST

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HELEN HUDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-05 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-097PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2017-05-15 17:41
1022	COPPER, FREE	200.8	0.0315 ppm	1.3 ppm	AS	2017-05-15 17:41

Comments: 6M2017 / SITE 124 / 338 E. DAVIS ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE E. RAWLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-096PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 17:04
1022	COPPER, FREE	200.8		0.033 ppm	1.3 ppm	AS	2017-05-15 17:04

Comments: 6M2017 / SITE 149 / 187 EAST BELL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	VALERIE R. WRIGHT	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 18:00
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	2017-05-08
COMPLIANCE	YES	**LAB ID**	170508-089PB	**COMPOSITED**	NO
		PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-15 15:55
1022	COPPER, FREE	200.8	0.0114 ppm	1.3 ppm	AS	2017-05-15 15:55

Comments: 6M2017 / SITE 182 / 326 E DAVIS ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA HUTSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-088PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 15:50
1022	COPPER, FREE	200.8		0.0354 ppm	1.3 ppm	AS	2017-05-15 15:50

Comments: 6M2017 / SITE 127 / 352 E DAVIS ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FLEICIA PINSTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-085PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-15 15:34
1022	COPPER, FREE	200.8		0.2603 ppm	1.3 ppm	AS	2017-05-15 15:34

Comments: 6M2017 / SITE 197 / 1217 BLAIR ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 04:30
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	2017-05-08
COMPLIANCE	YES	**LAB ID**	170508-062PB	**COMPOSITED**	NO
		PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 19:52
1022	COPPER, FREE	200.8		0.0749 ppm	1.3 ppm	AS	2017-05-12 19:52

Comments: 6M2017 / SITE 131 / 303 SPANISH COURT - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SOPHIA NEWSOME	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 05:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-061PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 19:47
1022	COPPER, FREE	200.8		0.0911 ppm	1.3 ppm	AS	2017-05-12 19:47

Comments: 6M2017 / SITE 178 / 355 MCKEE ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-060PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 19:41
1022	COPPER, FREE	200.8		0.0118 ppm	1.3 ppm	AS	2017-05-12 19:41

Comments: 6M2017 / SITE 123 / 330 E DAVIS ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	OBEDIAH CURTIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 15:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-059PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-12 19:36
1022	COPPER, FREE	200.8	0.0294 ppm	1.3 ppm	AS	2017-05-12 19:36

Comments: 6M2017 / SITE 139 / 143 W. COHEA ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LISAREE WEST	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-057PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 19:25
1022	COPPER, FREE	200.8		0.0116 ppm	1.3 ppm	AS	2017-05-12 19:25

Comments: 6M2017 / SITE 181 / 265 E DAVIS ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D. LAURY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-056PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2017-05-18 11:10
1022	COPPER, FREE	200.8		0.0469 ppm	1.3 ppm		2017-05-18 11:10

Comments: 6M2017 / SITE 177 / 353 MCKEE ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RICHARD MCNAIR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-054PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2017-05-12 18:44
1022	COPPER, FREE	200.8	0.0412 ppm	1.3 ppm	AS	2017-05-12 18:44

Comments: 6M2017 / SITE 121 / 312 E DAVIS ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBORAH JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-053PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 18:38
1022	COPPER, FREE	200.8		0.0131 ppm	1.3 ppm	AS	2017-05-12 18:38

Comments: 6M2017 / SITE 130 / 314 NEARVIEW STREET - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATRICIA BLUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-052PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-12 18:33
1022	COPPER, FREE	200.8	0.0265 ppm	1.3 ppm	AS	2017-05-12 18:33

Comments: 6M2017 / SITE 173 / 320 MCKEE ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARNER BRISTER, JR.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 13:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-051PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2017-05-12 18:28
1022	COPPER, FREE	200.8	0.0267 ppm	1.3 ppm	AS	2017-05-12 18:28

Comments: 6M2017 / SITE 125 / 340 E DAVIS ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MALISSA SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-047PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 17:40
1022	COPPER, FREE	200.8		0.0189 ppm	1.3 ppm	AS	2017-05-12 17:40

Comments: 6M2017 / SITE 179 / 361 MCKEE ST- KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAMES BROWN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-017PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.009 ppm	0.015 ppm	AS	2017-05-12 13:17
1022	COPPER, FREE	200.8	0.1269 ppm	1.3 ppm	AS	2017-05-12 13:17

Comments: 6M2017 / SITE 108 / 1130 N. LAMAR ST - APT A - BATHROOOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BARBARA CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:19
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-018PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2017-05-12 13:22
1022	COPPER, FREE	200.8	0.241 ppm	1.3 ppm	AS	2017-05-12 13:22

Comments: 6M2017 / SITE 107 / 1120 N. LAMAR ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EDDIE CAVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-019PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 13:27
1022	COPPER, FREE	200.8		0.0496 ppm	1.3 ppm	AS	2017-05-12 13:27

Comments: 6M2017 / SITE 105 / 1110 N. LAMAR ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRANKIE KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-014PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 12:35
1022	COPPER, FREE	200.8		0.1082 ppm	1.3 ppm	AS	2017-05-12 12:35

Comments: 6M2017 / SITE 109 / 1111 N LAMAR ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 03:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-046PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	AS	2017-05-12 17:35
1022	COPPER, FREE	200.8	0.0397 ppm	1.3 ppm	AS	2017-05-12 17:35

Comments: 6M2017 / SITE 122 / 316 E DAVIS ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CYNTHIA JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-045PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 17:30
1022	COPPER, FREE	200.8		0.008 ppm	1.3 ppm	AS	2017-05-12 17:30

Comments: 6M2017 / SITE 208 / 248 E. ASH ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	COLEMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-044PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-12 17:24
1022	COPPER, FREE	200.8	0.0463 ppm	1.3 ppm	AS	2017-05-12 17:24

Comments: 6M2017 / SITE 237 / 414 EASTVIEW ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PINKIE JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-042PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	AS	2017-05-12 16:48
1022	COPPER, FREE	200.8	0.0685 ppm	1.3 ppm	AS	2017-05-12 16:48

Comments: 6M2017 / SITE 204 / 229 E ASH ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN POTTS-WELLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-041PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-12 16:42
1022	COPPER, FREE	200.8	0.0256 ppm	1.3 ppm	AS	2017-05-12 16:42

Comments: 6M2017 / SITE 202 / 141 E ASH - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RESA C. WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-04 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-040PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 16:37
1022	COPPER, FREE	200.8		0.0187 ppm	1.3 ppm	AS	2017-05-12 16:37

Comments: 6M2017 / SITE 213 / 263 EAST ASH - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROBERT TAPLIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-039PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2017-05-12 16:32
1022	COPPER, FREE	200.8	0.0399 ppm	1.3 ppm	AS	2017-05-12 16:32

Comments: 6M2017 / SITE 225 / 118 CLOVERLEAF CIRCLE - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ILETHA DISMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 23:41
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-038PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0026 ppm	0.015 ppm	AS	2017-05-12 16:26
1022	COPPER, FREE	200.8	0.2272 ppm	1.3 ppm	AS	2017-05-12 16:26

Comments: 6M2017 / SITE 212 / 257 E ASH ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-035PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 15:45
1022	COPPER, FREE	200.8		0.015 ppm	1.3 ppm	AS	2017-05-12 15:45

Comments: 6M2017 / SITE 187 / 184 WHITFIELD ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE BLACKMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-033PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2017-05-12 15:34
1022	COPPER, FREE	200.8	0.0227 ppm	1.3 ppm	AS	2017-05-12 15:34

Comments: 6M2017 / SITE 231 / 174 DELAWARE AVE - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAPHNE WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-048PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-12 17:46
1022	COPPER, FREE	200.8	0.0195 ppm	1.3 ppm	AS	2017-05-12 17:46

Comments: 6M2017 / SITE 186 / 188 WHITFIELD ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATSY MINOR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 06:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-049PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2017-05-12 17:51
1022	COPPER, FREE	200.8		0.0068 ppm	1.3 ppm	AS	2017-05-12 17:51

Comments: 6M2017 / SITE 206 / 238 E. ASH ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA ALLEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 08:58
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-050PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0049 ppm	0.015 ppm	AS	2017-05-12 18:22
1022	COPPER, FREE	200.8	0.1462 ppm	1.3 ppm	AS	2017-05-12 18:22

Comments: 6M2017 / SITE 203 / 227 E ASH ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ESTER JILES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-03 05:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-055PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-12 18:49
1022	COPPER, FREE	200.8	0.0234 ppm	1.3 ppm	AS	2017-05-12 18:49

Comments: 6M2017 / SITE 209 / 241 E ASH ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LUCILLE BUCK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 16:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-079PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-12 22:40
1022	COPPER, FREE	200.8	0.0212 ppm	1.3 ppm	AS	2017-05-12 22:40

Comments: 6M2017 / SITE 185 / 156 WHITFIELD ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE BOBER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 20:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-082PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2017-05-12 22:56
1022	COPPER, FREE	200.8	0.0103 ppm	1.3 ppm	AS	2017-05-12 22:56

Comments: 6M2017 / SITE 191 / 221 WHITFIELD ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TIMOTHY BOOKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-01 18:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-091PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	AS	2017-05-15 16:37
1022	COPPER, FREE	200.8	0.0402 ppm	1.3 ppm	AS	2017-05-15 16:37

Comments: 6M2017 / SITE 235 / 408 EASTVIEW ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE L. BRACEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-05 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-093PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2017-05-15 16:48
1022	COPPER, FREE	200.8	0.03 ppm	1.3 ppm	AS	2017-05-15 16:48

Comments: 6M2017 / SITE 151 / 161 E. BELL ST - KITCHEN

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE A. PHILLIPS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-05-02 08:34
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-05-08
SAMPLE POINT	DS000	**LAB ID**	170508-098PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2017-05-15 17:46
1022	COPPER, FREE	200.8	0.0391 ppm	1.3 ppm	AS	2017-05-15 17:46

Comments: 6M2017 / SITE 229 / 142 GLENMARY ST - BATHROOM

Generated 2017-06-01

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	# Samples	Copper 90th	# Samples
07/01/2017-12/31/2017 (6 Month)	0.015 mg/L	110	0.2 mg/L	110
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	SMITH		
COUNTY	HINDS	**LAB**	MSDH LAB	**SAMPLE TYPE**	PBCU
SAMPLE POINT	DS000	**WORKORDER**		**COLLECTED**	2017-10-18 07:15
COMPLIANCE	YES	**LAB ID**	171023-001PB	**RECEIVED**	2017-10-23
		PURPOSE	RT	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 14:24
1022	COPPER, FREE	200.8		0.0152 ppm	1.3 ppm	DP	2017-10-24 14:24

Comments: 6M2 2017 / SITE 135 / 129 W COHEA STR. - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANNETTE BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 05:31
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 15:20
1022	COPPER, FREE	200.8		0.0085 ppm	1.3 ppm	DP	2017-10-24 15:20

Comments: 6M2 2017 / SITE 123 / 330 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	H. HUDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-003PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	DP	2017-10-24 15:24
1022	COPPER, FREE	200.8	0.0138 ppm	1.3 ppm	DP	2017-10-24 15:24

Comments: 6M2 2017 / SITE 124 / 338 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VALERIE GLASS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 18:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-004PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 15:40
1022	COPPER, FREE	200.8		0.0059	ppm	1.3	ppm	DP	2017-10-24 15:40

Comments: 6M2 2017 / SITE 182 / 325 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARNER BRISTER JR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 20:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-005PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 15:44
1022	COPPER, FREE	200.8		0.0067 ppm	1.3 ppm	DP	2017-10-24 15:44

Comments: 6M2 2017 / SITE 125 / 340 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAREK ASHLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 17:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-006PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0023 ppm	0.015 ppm	DP	2017-10-24 15:48
1022	COPPER, FREE	200.8	0.0648 ppm	1.3 ppm	DP	2017-10-24 15:48

Comments: 6M2 2017 / SITE 289 / 6306 AMBLEWOOD COURT - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARICE PENQUITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-007PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0269** ppm	0.015 ppm	DP	2017-10-24 16:04
1022	COPPER, FREE	200.8	0.1795 ppm	1.3 ppm	DP	2017-10-24 16:04

Comments: 6M2/2017 / SITE 355 / 282 WOODY DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENE AMOS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-008PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 16:08
1022	COPPER, FREE	200.8		0.132	ppm	1.3	ppm	DP	2017-10-24 16:08

Comments: 6M2 2017 / SITE 159 / 334 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-009PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 16:12
1022	COPPER, FREE	200.8		0.0908	ppm	1.3	ppm	DP	2017-10-24 16:12

Comments: 6M2 2017 / SITE 131 / 303 SPANISH COURT - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN YOUND	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 16:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-010PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 16:16
1022	COPPER, FREE	200.8		0.0982 ppm	1.3 ppm	DP	2017-10-24 16:16

Comments: 6M2 2017 / SITE 158 / 344 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHELLIE MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-011PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 16:32
1022	COPPER, FREE	200.8		0.0182	ppm	1.3	ppm	DP	2017-10-24 16:32

Comments: 6M2 2017 / SITE 27 / 5477 BROOKHOLLOW DR - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CALVIN HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 05:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-012PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0083 ppm	0.015 ppm	DP	2017-10-24 16:36
1022	COPPER, FREE	200.8	0.0922 ppm	1.3 ppm	DP	2017-10-24 16:36

Comments: 6M2 2017 / SITE 292 / 6239 AMBLEWOOD DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELONIE HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 15:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-013PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0031 ppm	0.015 ppm	DP	2017-10-24 16:40
1022	COPPER, FREE	200.8	0.0802 ppm	1.3 ppm	DP	2017-10-24 16:40

Comments: 6M2 2017 / SITE 300 / 6418 CEDARWOOD DRIVE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TECORA OLIVER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-014PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0064 ppm	0.015 ppm	DP	2017-10-24 16:56
1022	COPPER, FREE	200.8	0.08 ppm	1.3 ppm	DP	2017-10-24 16:56

Comments: 6M2 2017 / SITE 285 / 6756 GEORGE WASHINGTON DRIVE - BATHTUB

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STACEY PARISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-015PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.2199** ppm	0.015 ppm	DP	2017-10-24 17:00
1022	COPPER, FREE	200.8	0.5421 ppm	1.3 ppm	DP	2017-10-24 17:00

Comments: 6M2/2017 / SITE 302 / 5911 FLORAL DRIVE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JEANETTE ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 05:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-016PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0114 ppm	0.015 ppm	DP	2017-10-24 17:04
1022	COPPER, FREE	200.8	0.4812 ppm	1.3 ppm	DP	2017-10-24 17:04

Comments: 6M2 2017 / SITE 352 / 136 COLONY SQAURE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRANKLIN KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 05:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-017PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 17:08
1022	COPPER, FREE	200.8		0.0974 ppm	1.3 ppm	DP	2017-10-24 17:08

Comments: 6M2 2017 / SITE 109 / 1111 N LAMAR ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DOUG HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 14:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-018PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 17:24
1022	COPPER, FREE	200.8		0.025 ppm	1.3 ppm	DP	2017-10-24 17:24

Comments: 6M2 2017 / SITE 28 / 1704 BROOKHOLLOW CR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARLEN BECKLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 19:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-019PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	DP	2017-10-24 17:28
1022	COPPER, FREE	200.8	0.0126 ppm	1.3 ppm	DP	2017-10-24 17:28

Comments: 6M2 2017 / SITE 288 / 6306 AMBLEWOOD COURT - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-020PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0026 ppm	0.015 ppm	DP	2017-10-24 17:32
1022	COPPER, FREE	200.8	0.0891 ppm	1.3 ppm	DP	2017-10-24 17:32

Comments: 6M2 2017 / SITE 56 / 206 SUNDOWN TRAIL - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE PHILLIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-021PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2017-10-24 17:49
1022	COPPER, FREE	200.8	0.0459 ppm	1.3 ppm	DP	2017-10-24 17:49

Comments: 6M2 2017 / SITE 229 / 142 GLENMARY ST - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 05:18
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-022PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.105** ppm	0.015 ppm	DP	2017-10-24 17:53
1022	COPPER, FREE	200.8	0.3266 ppm	1.3 ppm	DP	2017-10-24 17:53

Comments: 6M2/2017 / SITE 333 / 6203 WHITESTONE RD - MASTER BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHANNON HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-023PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 17:57
1022	COPPER, FREE	200.8		0.0377	ppm	1.3	ppm	DP	2017-10-24 17:57

Comments: 6M2 2017 / SITE 227 / 1178 HORSESHOE CIRCLE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARTHA VANCE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-024PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 18:01
1022	COPPER, FREE	200.8		0.0196 ppm	1.3 ppm	DP	2017-10-24 18:01

Comments: 6M2 2017 / SITE 238 / 5481 KAYWOOD DRIVE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RESA WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-025PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2017-10-24 18:17
1022	COPPER, FREE	200.8	0.0209 ppm	1.3 ppm	DP	2017-10-24 18:17

Comments: 6M2 2017 / SITE 213 / 263 E ASH STREET - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MATT THORNTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 04:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-026PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0044 ppm	0.015 ppm	DP	2017-10-24 18:21
1022	COPPER, FREE	200.8	0.0513 ppm	1.3 ppm	DP	2017-10-24 18:21

Comments: 6M2 2017 / SITE 244 / 950 NEWLAND STREET - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-027PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 18:25
1022	COPPER, FREE	200.8		0.0101 ppm	1.3 ppm	DP	2017-10-24 18:25

Comments: 6M2 2017 / SITE 187 / 184 WHITFIELD ST - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	YOLANDA BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 14:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-028PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0118 ppm	0.015 ppm	DP	2017-10-24 18:41
1022	COPPER, FREE	200.8	0.1626 ppm	1.3 ppm	DP	2017-10-24 18:41

Comments: 6M2 2017 / SITE 331 / 6064 WHITESTON RD - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIM JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-029PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0147 ppm	0.015 ppm	DP	2017-10-24 18:45
1022	COPPER, FREE	200.8	0.3074 ppm	1.3 ppm	DP	2017-10-24 18:45

Comments: 6M2 2017 / SITE 332 / 6143 WHITESTON RD - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 06:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-030PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0203** ppm	0.015 ppm	DP	2017-10-24 18:49
1022	COPPER, FREE	200.8	0.2277 ppm	1.3 ppm	DP	2017-10-24 18:49

Comments: 6M2/2017 / SITE 240 / 2030 SHEFFIELD DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AP AUCHUS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 16:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-031PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2017-10-24 18:53
1022	COPPER, FREE	200.8	0.0799 ppm	1.3 ppm	DP	2017-10-24 18:53

Comments: 6M2 2017 / SITE 272 / 16 ST ANDREWS DR - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GAVALIN JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 06:02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-032PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:09
1022	COPPER, FREE	200.8		0.0198 ppm	1.3 ppm	DP	2017-10-24 19:09

Comments: 6M2 2017 / SITE 208 / 248 E ASH ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NEWSOME	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 09:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-033PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:13
1022	COPPER, FREE	200.8		0.0443 ppm	1.3 ppm	DP	2017-10-24 19:13

Comments: 6M2 2017 / SITE 178 / 355 MCKEE ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MASES OWENS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 08:14
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-034PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:17
1022	COPPER, FREE	200.8	0.0254 ppm	1.3 ppm	DP	2017-10-24 19:17

Comments: 6M2 2017 / SITE 161 / 237 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN RUSSUM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-035PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:33
1022	COPPER, FREE	200.8		0.0066 ppm	1.3 ppm	DP	2017-10-24 19:33

Comments: 6M2 2017 / SITE 171 / 310 MCKEE ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DWANNA LAURY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-036PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:37
1022	COPPER, FREE	200.8		0.0093 ppm	1.3 ppm	DP	2017-10-24 19:37

Comments: 6M2 2017 / SITE 177 / 353 MCKEE ST - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAISSA SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-037PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:41
1022	COPPER, FREE	200.8		0.0132 ppm	1.3 ppm	DP	2017-10-24 19:41

Comments: 6M2 2017 / SITE 179 / 361 MCKEE ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHEN JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 11:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-038PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2017-10-24 19:45
1022	COPPER, FREE	200.8	0.0264 ppm	1.3 ppm	DP	2017-10-24 19:45

Comments: 6M2 2017 / SITE 283 / 6663 LYNDON B JOHNSON DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BOBBY BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-039PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	DP	2017-10-24 20:01
1022	COPPER, FREE	200.8	0.5508 ppm	1.3 ppm	DP	2017-10-24 20:01

Comments: 6M2 2017 / SITE 350 / 104 COLONY SQAURE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TANICIA BURKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 09:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-040PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 20:05
1022	COPPER, FREE	200.8		0.2571 ppm	1.3 ppm	DP	2017-10-24 20:05

Comments: 6M2 2017 / SITE 154 / 200 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	C SCOTT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 07:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-041PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2017-10-24 20:09
1022	COPPER, FREE	200.8	0.015 ppm	1.3 ppm	DP	2017-10-24 20:09

Comments: 6M2 2017 / SITE 155 / 204 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN A. FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-042PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0157** ppm	0.015 ppm	DP	2017-10-24 20:25
1022	COPPER, FREE	200.8	0.1862 ppm	1.3 ppm	DP	2017-10-24 20:25

Comments: 6M2/2017 / SITE 330 / 6010 WHITESTONE RD - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	# Samples	Copper 90th	# Samples
07/01/2017-12/31/2017 (6 Month)	0.015 mg/L	110	0.2 mg/L	110
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	SMITH		
COUNTY	HINDS	**LAB**	MSDH LAB	**SAMPLE TYPE**	PBCU
SAMPLE POINT	DS000	**WORKORDER**		**COLLECTED**	2017-10-18 07:15
COMPLIANCE	YES	**LAB ID**	171023-001PB	**RECEIVED**	2017-10-23
		PURPOSE	RT	**COMPOSITED**	NO
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 14:24
1022	COPPER, FREE	200.8		0.0152 ppm	1.3 ppm	DP	2017-10-24 14:24

Comments: 6M2 2017 / SITE 135 / 129 W COHEA STR. - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANNETTE BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 05:31
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 15:20
1022	COPPER, FREE	200.8		0.0085 ppm	1.3 ppm	DP	2017-10-24 15:20

Comments: 6M2 2017 / SITE 123 / 330 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	H. HUDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-003PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	DP	2017-10-24 15:24
1022	COPPER, FREE	200.8	0.0138 ppm	1.3 ppm	DP	2017-10-24 15:24

Comments: 6M2 2017 / SITE 124 / 338 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VALERIE GLASS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 18:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-004PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 15:40
1022	COPPER, FREE	200.8		0.0059	ppm	1.3	ppm	DP	2017-10-24 15:40

Comments: 6M2 2017 / SITE 182 / 325 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARNER BRISTER JR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 20:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-005PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 15:44
1022	COPPER, FREE	200.8		0.0067 ppm	1.3 ppm	DP	2017-10-24 15:44

Comments: 6M2 2017 / SITE 125 / 340 E DAVIS STR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAREK ASHLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 17:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-006PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0023 ppm	0.015 ppm	DP	2017-10-24 15:48
1022	COPPER, FREE	200.8	0.0648 ppm	1.3 ppm	DP	2017-10-24 15:48

Comments: 6M2 2017 / SITE 289 / 6306 AMBLEWOOD COURT - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARICE PENQUITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-007PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0269** ppm	0.015 ppm	DP	2017-10-24 16:04
1022	COPPER, FREE	200.8	0.1795 ppm	1.3 ppm	DP	2017-10-24 16:04

Comments: 6M2/2017 / SITE 355 / 282 WOODY DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENE AMOS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-008PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 16:08
1022	COPPER, FREE	200.8		0.132	ppm	1.3	ppm	DP	2017-10-24 16:08

Comments: 6M2 2017 / SITE 159 / 334 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-009PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 16:12
1022	COPPER, FREE	200.8		0.0908	ppm	1.3	ppm	DP	2017-10-24 16:12

Comments: 6M2 2017 / SITE 131 / 303 SPANISH COURT - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN YOUND	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 16:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-010PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 16:16
1022	COPPER, FREE	200.8		0.0982 ppm	1.3 ppm	DP	2017-10-24 16:16

Comments: 6M2 2017 / SITE 158 / 344 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHELLIE MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-011PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 16:32
1022	COPPER, FREE	200.8		0.0182	ppm	1.3	ppm	DP	2017-10-24 16:32

Comments: 6M2 2017 / SITE 27 / 5477 BROOKHOLLOW DR - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CALVIN HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 05:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-012PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0083 ppm	0.015 ppm	DP	2017-10-24 16:36
1022	COPPER, FREE	200.8	0.0922 ppm	1.3 ppm	DP	2017-10-24 16:36

Comments: 6M2 2017 / SITE 292 / 6239 AMBLEWOOD DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELONIE HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 15:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-013PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0031 ppm	0.015 ppm	DP	2017-10-24 16:40
1022	COPPER, FREE	200.8	0.0802 ppm	1.3 ppm	DP	2017-10-24 16:40

Comments: 6M2 2017 / SITE 300 / 6418 CEDARWOOD DRIVE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TECORA OLIVER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-014PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0064 ppm	0.015 ppm	DP	2017-10-24 16:56
1022	COPPER, FREE	200.8	0.08 ppm	1.3 ppm	DP	2017-10-24 16:56

Comments: 6M2 2017 / SITE 285 / 6756 GEORGE WASHINGTON DRIVE - BATHTUB

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STACEY PARISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-015PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.2199** ppm	0.015 ppm	DP	2017-10-24 17:00
1022	COPPER, FREE	200.8	0.5421 ppm	1.3 ppm	DP	2017-10-24 17:00

Comments: 6M2/2017 / SITE 302 / 5911 FLORAL DRIVE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JEANETTE ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 05:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-016PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0114 ppm	0.015 ppm	DP	2017-10-24 17:04
1022	COPPER, FREE	200.8	0.4812 ppm	1.3 ppm	DP	2017-10-24 17:04

Comments: 6M2 2017 / SITE 352 / 136 COLONY SQAURE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRANKLIN KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 05:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-017PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 17:08
1022	COPPER, FREE	200.8		0.0974 ppm	1.3 ppm	DP	2017-10-24 17:08

Comments: 6M2 2017 / SITE 109 / 1111 N LAMAR ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DOUG HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 14:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-018PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 17:24
1022	COPPER, FREE	200.8		0.025 ppm	1.3 ppm	DP	2017-10-24 17:24

Comments: 6M2 2017 / SITE 28 / 1704 BROOKHOLLOW CR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARLEN BECKLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 19:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-019PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	DP	2017-10-24 17:28
1022	COPPER, FREE	200.8	0.0126 ppm	1.3 ppm	DP	2017-10-24 17:28

Comments: 6M2 2017 / SITE 288 / 6306 AMBLEWOOD COURT - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-020PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0026 ppm	0.015 ppm	DP	2017-10-24 17:32
1022	COPPER, FREE	200.8	0.0891 ppm	1.3 ppm	DP	2017-10-24 17:32

Comments: 6M2 2017 / SITE 56 / 206 SUNDOWN TRAIL - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE PHILLIS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-021PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2017-10-24 17:49
1022	COPPER, FREE	200.8	0.0459 ppm	1.3 ppm	DP	2017-10-24 17:49

Comments: 6M2 2017 / SITE 229 / 142 GLENMARY ST - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 05:18
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-022PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.105** ppm	0.015 ppm	DP	2017-10-24 17:53
1022	COPPER, FREE	200.8	0.3266 ppm	1.3 ppm	DP	2017-10-24 17:53

Comments: 6M2/2017 / SITE 333 / 6203 WHITESTONE RD - MASTER BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHANNON HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-023PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 17:57
1022	COPPER, FREE	200.8		0.0377 ppm	1.3 ppm	DP	2017-10-24 17:57

Comments: 6M2 2017 / SITE 227 / 1178 HORSESHOE CIRCLE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARTHA VANCE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-024PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 18:01
1022	COPPER, FREE	200.8		0.0196 ppm	1.3 ppm	DP	2017-10-24 18:01

Comments: 6M2 2017 / SITE 238 / 5481 KAYWOOD DRIVE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RESA WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-025PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2017-10-24 18:17
1022	COPPER, FREE	200.8	0.0209 ppm	1.3 ppm	DP	2017-10-24 18:17

Comments: 6M2 2017 / SITE 213 / 263 E ASH STREET - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MATT THORNTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 04:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-026PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0044 ppm	0.015 ppm	DP	2017-10-24 18:21
1022	COPPER, FREE	200.8	0.0513 ppm	1.3 ppm	DP	2017-10-24 18:21

Comments: 6M2 2017 / SITE 244 / 950 NEWLAND STREET - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-027PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2017-10-24 18:25
1022	COPPER, FREE	200.8		0.0101	ppm	1.3	ppm	DP	2017-10-24 18:25

Comments: 6M2 2017 / SITE 187 / 184 WHITFIELD ST - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	YOLANDA BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 14:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-028PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0118 ppm	0.015 ppm	DP	2017-10-24 18:41
1022	COPPER, FREE	200.8	0.1626 ppm	1.3 ppm	DP	2017-10-24 18:41

Comments: 6M2 2017 / SITE 331 / 6064 WHITESTON RD - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIM JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-029PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0147 ppm	0.015 ppm	DP	2017-10-24 18:45
1022	COPPER, FREE	200.8	0.3074 ppm	1.3 ppm	DP	2017-10-24 18:45

Comments: 6M2 2017 / SITE 332 / 6143 WHITESTON RD - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 06:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-030PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0203** ppm	0.015 ppm	DP	2017-10-24 18:49
1022	COPPER, FREE	200.8	0.2277 ppm	1.3 ppm	DP	2017-10-24 18:49

Comments: 6M2/2017 / SITE 240 / 2030 SHEFFIELD DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AP AUCHUS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 16:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-031PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2017-10-24 18:53
1022	COPPER, FREE	200.8	0.0799 ppm	1.3 ppm	DP	2017-10-24 18:53

Comments: 6M2 2017 / SITE 272 / 16 ST ANDREWS DR - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GAVALIN JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 06:02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-032PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:09
1022	COPPER, FREE	200.8		0.0198 ppm	1.3 ppm	DP	2017-10-24 19:09

Comments: 6M2 2017 / SITE 208 / 248 E ASH ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NEWSOME	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 09:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-033PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:13
1022	COPPER, FREE	200.8		0.0443 ppm	1.3 ppm	DP	2017-10-24 19:13

Comments: 6M2 2017 / SITE 178 / 355 MCKEE ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MASES OWENS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 08:14
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-034PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:17
1022	COPPER, FREE	200.8	0.0254 ppm	1.3 ppm	DP	2017-10-24 19:17

Comments: 6M2 2017 / SITE 161 / 237 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN RUSSUM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-035PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:33
1022	COPPER, FREE	200.8		0.0066 ppm	1.3 ppm	DP	2017-10-24 19:33

Comments: 6M2 2017 / SITE 171 / 310 MCKEE ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DWANNA LAURY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-19 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-036PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:37
1022	COPPER, FREE	200.8		0.0093 ppm	1.3 ppm	DP	2017-10-24 19:37

Comments: 6M2 2017 / SITE 177 / 353 MCKEE ST - BATHROOM

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAISSA SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-037PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 19:41
1022	COPPER, FREE	200.8		0.0132 ppm	1.3 ppm	DP	2017-10-24 19:41

Comments: 6M2 2017 / SITE 179 / 361 MCKEE ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEPHEN JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-17 11:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-038PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2017-10-24 19:45
1022	COPPER, FREE	200.8	0.0264 ppm	1.3 ppm	DP	2017-10-24 19:45

Comments: 6M2 2017 / SITE 283 / 6663 LYNDON B JOHNSON DR - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BOBBY BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-16 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-039PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	DP	2017-10-24 20:01
1022	COPPER, FREE	200.8	0.5508 ppm	1.3 ppm	DP	2017-10-24 20:01

Comments: 6M2 2017 / SITE 350 / 104 COLONY SQAURE - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TANICIA BURKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 09:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-040PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2017-10-24 20:05
1022	COPPER, FREE	200.8		0.2571 ppm	1.3 ppm	DP	2017-10-24 20:05

Comments: 6M2 2017 / SITE 154 / 200 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	C SCOTT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-20 07:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-041PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2017-10-24 20:09
1022	COPPER, FREE	200.8	0.015 ppm	1.3 ppm	DP	2017-10-24 20:09

Comments: 6M2 2017 / SITE 155 / 204 BELL ST - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN A. FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2017-10-18 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2017-10-23
SAMPLE POINT	DS000	**LAB ID**	171023-042PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0157** ppm	0.015 ppm	DP	2017-10-24 20:25
1022	COPPER, FREE	200.8	0.1862 ppm	1.3 ppm	DP	2017-10-24 20:25

Comments: 6M2/2017 / SITE 330 / 6010 WHITESTONE RD - KITCHEN

Generated 2017-11-09

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	**# Samples**	**Copper 90th**	**# Samples**
01/01/2018-06/30/2018 (6 Month)	0.006 mg/L	101	0.1 mg/L	101
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SONYA BARNETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-06-28 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-07-05
SAMPLE POINT	DS000	**LAB ID**	180705-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	DP	2018-07-06 12:42
1022	COPPER, FREE	200.8	0.0119 ppm	1.3 ppm	DP	2018-07-06 12:42

Comments: 6M12018/ 200 Sundown Trail/ site 56./ kitchen

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	M. BROWN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-05-31 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-06-01
SAMPLE POINT	DS000	**LAB ID**	180601-002PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2018-06-04 12:31
1022	COPPER, FREE	200.8	0.0321 ppm	1.3 ppm	DP	2018-06-04 12:31

Comments: 6M12018 / SITE 55 / 269 SUNDOWN TRAIL - KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-05-31 05:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-06-01
SAMPLE POINT	DS000	**LAB ID**	180601-001PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	DP	2018-06-04 12:23
1022	COPPER, FREE	200.8	0.0635 ppm	1.3 ppm	DP	2018-06-04 12:23

Comments: 6M12018 / SITE 56 / 206 SUNDOWN TRAIL - KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 09:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-147PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 20:42
1022	COPPER, FREE	200.8		0.0087	ppm	1.3	ppm	DP	2018-05-08 20:42

Comments: 6M12018 / SITE 241 / 3951 EASTWOOD DR / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-146PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 20:38
1022	COPPER, FREE	200.8		0.0051 ppm	1.3 ppm	DP	2018-05-08 20:38

Comments: 6M12018 / SITE 160 / 235 E BELL ST / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-145PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	DP	2018-05-08 20:34
1022	COPPER, FREE	200.8	0.028 ppm	1.3 ppm	DP	2018-05-08 20:34

Comments: 6M12018 / SITE 331 / 6064 WHITESTONE / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE PHILLY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-144PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	DP	2018-05-08 20:26
1022	COPPER, FREE	200.8	0.022 ppm	1.3 ppm	DP	2018-05-08 20:26

Comments: 6M12018 / SITE 229 / 142 GLEMNARY ST / BATH

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:49
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-143PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.006 ppm	0.015 ppm	DP	2018-05-08 20:18
1022	COPPER, FREE	200.8	0.0569 ppm	1.3 ppm	DP	2018-05-08 20:18

Comments: 6M12018 / SITE 240 / 2030 SHEFFEILD DR / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PINE RANDLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 08:38
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-142PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0139 ppm	0.015 ppm	DP	2018-05-08 20:14
1022	COPPER, FREE	200.8	0.0241 ppm	1.3 ppm	DP	2018-05-08 20:14

Comments: 6M12018 / SITE 328 / 5907 WOODHAVEN / KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-141PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0067 ppm	0.015 ppm	DP	2018-05-08 19:58
1022	COPPER, FREE	200.8	0.0242 ppm	1.3 ppm	DP	2018-05-08 19:58

Comments: 6M12018 / SITE 330 / 6010 WHITESTONE RD / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENA AMOS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-140PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 19:54
1022	COPPER, FREE	200.8		0.1027 ppm	1.3 ppm	DP	2018-05-08 19:54

Comments: 6M12018 / SITE 159 / 334 BELL ST / FAUCET

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TIMOTHY BOOKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-23 21:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-139PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 19:50
1022	COPPER, FREE	200.8		0.0056 ppm	1.3 ppm	DP	2018-05-08 19:50

Comments: 6M12018 / SITE 235 / 408 EASTVIEW / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE RAWLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-138PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2018-05-08 19:46
1022	COPPER, FREE	200.8	0.0066 ppm	1.3 ppm	DP	2018-05-08 19:46

Comments: 6M12018 / SITE 149 / 187 EAST BELL ST / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THEO GOURNS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-137PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0027 ppm	0.015 ppm	DP	2018-05-08 19:42
1022	COPPER, FREE	200.8	0.0113 ppm	1.3 ppm	DP	2018-05-08 19:42

Comments: 6M12018 / SITE 274 / 36 SAINT ANDREWS DR / BATHROOM

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-136PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	DP	2018-05-08 19:34
1022	COPPER, FREE	200.8	0.0171 ppm	1.3 ppm	DP	2018-05-08 19:34

Comments: 6M12018 / SITE 231 / 174 DELAWARE ST / BR

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN YOUND	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:21
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-135PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	DP	2018-05-08 19:26
1022	COPPER, FREE	200.8	0.7826 ppm	1.3 ppm	DP	2018-05-08 19:26

Comments: 6M12018 / SITE 158 / 344 E BELL ST / M BATHROOM

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TRACY WESTEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-23 23:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-134PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 19:22
1022	COPPER, FREE	200.8		0.0492	ppm	1.3	ppm	DP	2018-05-08 19:22

Comments: 6M12018 / SITE 30 / 1716 BROOKHOLLOW CIRCLE / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RACHEAL GIBSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-133PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2018-05-08 19:06
1022	COPPER, FREE	200.8	0.0443 ppm	1.3 ppm	DP	2018-05-08 19:06

Comments: 6M12018 / SITE 19 / 5014 KAY BROOK DR / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STACY PAPAS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-132PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0417** ppm	0.015 ppm	DP	2018-05-08 19:02
1022	COPPER, FREE	200.8	0.1298 ppm	1.3 ppm	DP	2018-05-08 19:02

Comments: 6MONTH / SITE#302 - KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GUINER BRISTER JR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 10:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-131PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 18:58
1022	COPPER, FREE	200.8		0.0118	ppm	1.3	ppm	DP	2018-05-08 18:58

Comments: 6M12018 / SITE 125 / 340 EAST DAVIS ST / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-130PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	DP	2018-05-08 18:54
1022	COPPER, FREE	200.8	0.0833 ppm	1.3 ppm	DP	2018-05-08 18:54

Comments: 6M12018 / SITE 350 / 104 COLONY SQAURE / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 12:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-129PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	DP	2018-05-08 18:50
1022	COPPER, FREE	200.8	0.0257 ppm	1.3 ppm	DP	2018-05-08 18:50

Comments: 6M12018 / SITE 29 / 1720 BROOKHOLLOW DR / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAMATH HAND	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 10:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-128PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.025** ppm	0.015 ppm	DP	2018-05-08 18:42
1022	COPPER, FREE	200.8	0.1785 ppm	1.3 ppm	DP	2018-05-08 18:42

Comments: SITE 349 BATHROOM 6M12018

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BARBARA CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-127PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	DP	2018-05-08 18:34
1022	COPPER, FREE	200.8	0.0362 ppm	1.3 ppm	DP	2018-05-08 18:34

Comments: 6M12018 / SITE 107 / 1120 N LAMAR STR / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ARLESSA JENKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-126PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	DP	2018-05-08 18:30
1022	COPPER, FREE	200.8	0.1535 ppm	1.3 ppm	DP	2018-05-08 18:30

Comments: 6M12018 / SITE 33 / 4270 WILL O RUN DR / BATHROOM

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RCHARD MCNAIR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 10:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-125PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	DP	2018-05-08 18:14
1022	COPPER, FREE	200.8	0.0493 ppm	1.3 ppm	DP	2018-05-08 18:14

Comments: 6M12018 / SITE 121 / 312 EAST DAVIS STREET / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE BERRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 12:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-124PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 18:10
1022	COPPER, FREE	200.8		0.0098 ppm	1.3 ppm	DP	2018-05-08 18:10

Comments: 6M12018 / SITE 150 / 161 EAST BELL ST / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CYNTHIA HINTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-123PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 18:06
1022	COPPER, FREE	200.8		0.0026 ppm	1.3 ppm	DP	2018-05-08 18:06

Comments: 6M12018 / SITE 150 / 175 EAST BELL ST / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-122PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.005 ppm	0.015 ppm	DP	2018-05-08 18:02
1022	COPPER, FREE	200.8	0.0416 ppm	1.3 ppm	DP	2018-05-08 18:02

Comments: 6M12018 / SITE 77 / 164 DURANVILLE ST / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE COLLINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 03:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-121PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	DP	2018-05-08 17:58
1022	COPPER, FREE	200.8	0.0363 ppm	1.3 ppm	DP	2018-05-08 17:58

Comments: 6M12018 / SITE 290 / 6319 AMBLEWOOD CT / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHEAL MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-120PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 17:50
1022	COPPER, FREE	200.8		0.0193 ppm	1.3 ppm	DP	2018-05-08 17:50

Comments: 6M12018 /BATHROOM / SITE 27

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY POTTS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-119PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 17:42
1022	COPPER, FREE	200.8		0.0049 ppm	1.3 ppm	DP	2018-05-08 17:42

Comments: 6M12018 /BATHROOM / SITE 202

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	UNREADABLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-118PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2018-05-08 17:38
1022	COPPER, FREE	200.8	0.0337 ppm	1.3 ppm	DP	2018-05-08 17:38

Comments: 6M12018 /KITCHEN / SITE 203

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VICTOR COLEMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 12:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-117PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 17:22
1022	COPPER, FREE	200.8		0.0199 ppm	1.3 ppm	DP	2018-05-08 17:22

Comments: 6M12018 /KITCHEN / SITE 237

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SOPHIA NEWSOME	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 05:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-116PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	DP	2018-05-08 17:18
1022	COPPER, FREE	200.8	0.0282 ppm	1.3 ppm	DP	2018-05-08 17:18

Comments: 6M12018 / KITCHEN / SITE 204

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SOPHIA NEWSOME	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-23 09:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-115PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	DP	2018-05-08 17:14
1022	COPPER, FREE	200.8	0.0496 ppm	1.3 ppm	DP	2018-05-08 17:14

Comments: 6M12018 / KITCHEN / SITE 178

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VERETA INGRAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 07:36
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-114PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0188** ppm	0.015 ppm	DP	2018-05-08 17:10
1022	COPPER, FREE	200.8	0.017 ppm	1.3 ppm	DP	2018-05-08 17:10

Comments: SITE 327 KITCHEN 6M12018

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELINDA HORNE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-113PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 17:06
1022	COPPER, FREE	200.8		0.108 ppm	1.3 ppm	DP	2018-05-08 17:06

Comments: 6M12018 / KITCHEN / SITE 154

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY RICHARDS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-112PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0019 ppm	0.015 ppm	DP	2018-05-08 16:58
1022	COPPER, FREE	200.8	0.0084 ppm	1.3 ppm	DP	2018-05-08 16:58

Comments: 6M12018 / BATHROOM / SITE 326

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LUCILLE BUCK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 04:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-111PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 16:50
1022	COPPER, FREE	200.8		0.0028 ppm	1.3 ppm	DP	2018-05-08 16:50

Comments: 6M12018 / SINK / SITE 185

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATRICIA BLUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-110PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 16:46
1022	COPPER, FREE	200.8		0.01	ppm	1.3	ppm	DP	2018-05-08 16:46

Comments: 6M12018 /KITCHEN / SITE 173

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAMES BANKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-109PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 16:30
1022	COPPER, FREE	200.8		0.0331 ppm	1.3 ppm	DP	2018-05-08 16:30

Comments: 6M12018/ KITCHEN / SITE 72

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-108PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 16:26
1022	COPPER, FREE	200.8		0.0103 ppm	1.3 ppm	DP	2018-05-08 16:26

Comments: 6M12018 /KITCHEN / SITE 131

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBORAH JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-107PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 16:22
1022	COPPER, FREE	200.8		0.0019 ppm	1.3 ppm	DP	2018-05-08 16:22

Comments: 6M12018/ KITCHEN / SITE 130

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THOMAS MORTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 07:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-106PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 16:18
1022	COPPER, FREE	200.8		0.01 ppm	1.3 ppm	DP	2018-05-08 16:18

Comments: 6M12018/ BATHROOM / SITE 71

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	C SCOTT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-105PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2018-05-08 16:14
1022	COPPER, FREE	200.8	0.0079 ppm	1.3 ppm	DP	2018-05-08 16:14

Comments: 6M12018/ KITCHEN / SITE 155

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HENDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 09:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-104PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 16:06
1022	COPPER, FREE	200.8		0.0304 ppm	1.3 ppm	DP	2018-05-08 16:06

Comments: 6M12018/ KITCHEN / SITE 73

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JASMINE SINGLETON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 16:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-103PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 15:58
1022	COPPER, FREE	200.8		0.0076 ppm	1.3 ppm	DP	2018-05-08 15:58

Comments: 6M12018/KITCHEN / SITE 108

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHAWN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 11:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-101PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	DP	2018-05-08 15:38
1022	COPPER, FREE	200.8	0.0572 ppm	1.3 ppm	DP	2018-05-08 15:38

Comments: 6M12018/KITCHEN / SITE 69

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KEITH FERGUSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-04-28
SAMPLE POINT	DS000	**LAB ID**	180503-100PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	DP	2018-05-08 15:34
1022	COPPER, FREE	200.8	0.0545 ppm	1.3 ppm	DP	2018-05-08 15:34

Comments: 6MONTH1 2018 / 4345 WILL-O-WILL / KITCHEN - OUT OF COMPLIANCE ADDRESS NOT ON SITE PLAN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATSY MINER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-099PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 15:30
1022	COPPER, FREE	200.8		0.005 ppm	1.3 ppm	DP	2018-05-08 15:30

Comments: 6M12018/KITCHEN / SITE 206

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DONNA LOUWRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-098PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 15:26
1022	COPPER, FREE	200.8		0.004 ppm	1.3 ppm	DP	2018-05-08 15:26

Comments: 6M12018/ BATHTUB / SITE 177

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LETHA DISHMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-23 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-097PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0915** ppm	0.015 ppm	DP	2018-05-08 15:21
1022	COPPER, FREE	200.8	0.0509 ppm	1.3 ppm	DP	2018-05-08 15:21

Comments: SITE 212 BATHROOM 6M12018

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DON WELLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-096PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 15:13
1022	COPPER, FREE	200.8		0.0069	ppm	1.3	ppm	DP	2018-05-08 15:13

Comments: 6MONTH1 2018 / 225 TAFT STREET / KITCHEN - OUT OF COMPLIANCE ADDRESS NOT ON SITE PLAN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAY NORALS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 17:22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-095PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0045 ppm	0.015 ppm	DP	2018-05-08 15:05
1022	COPPER, FREE	200.8	0.0741 ppm	1.3 ppm	DP	2018-05-08 15:05

Comments: 6M12018/ KITCHEN / SITE 296

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WINSTON JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 11:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-094PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 15:01
1022	COPPER, FREE	200.8		0.0036 ppm	1.3 ppm	DP	2018-05-08 15:01

Comments: 6M12018/ KITCHEN / SITE 208

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA TUCKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-093PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0025 ppm	0.015 ppm	DP	2018-05-08 14:45
1022	COPPER, FREE	200.8	0.0145 ppm	1.3 ppm	DP	2018-05-08 14:45

Comments: 6M12018/ BATHROOM / SITE 278

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIMBERLY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 07:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-092PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	DP	2018-05-08 14:41
1022	COPPER, FREE	200.8	0.0097 ppm	1.3 ppm	DP	2018-05-08 14:41

Comments: 6M12018/ BATHROOM / SITE 332

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MOSES OWEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-091PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.004 ppm	0.015 ppm	DP	2018-05-08 14:37
1022	COPPER, FREE	200.8	0.037 ppm	1.3 ppm	DP	2018-05-08 14:37

Comments: 6M12018/ KITCHEN / SITE 161

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAMES BALL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 06:35
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-090PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0034 ppm	0.015 ppm	DP	2018-05-08 14:33
1022	COPPER, FREE	200.8	0.0246 ppm	1.3 ppm	DP	2018-05-08 14:33

Comments: 6M12018/ KITCHEN / SITE 275

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 05:03
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-089PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	DP	2018-05-08 14:29
1022	COPPER, FREE	200.8	0.0253 ppm	1.3 ppm	DP	2018-05-08 14:29

Comments: 6M12018/ BATHRONNM / SITE 333

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHERYL ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-088PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0041 ppm	0.015 ppm	DP	2018-05-08 14:21
1022	COPPER, FREE	200.8	0.0191 ppm	1.3 ppm	DP	2018-05-08 14:21

Comments: 6M12018/ KITCHEN / SITE 329

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EMILY THORNTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-087PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	DP	2018-05-08 14:13
1022	COPPER, FREE	200.8	0.0168 ppm	1.3 ppm	DP	2018-05-08 14:13

Comments: 6M12018/ KITCHEN / SITE 244

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RENEA WILLIAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 10:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-086PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 14:09
1022	COPPER, FREE	200.8		0.0064 ppm	1.3 ppm	DP	2018-05-08 14:09

Comments: 6M12018/BATHROOM/ SITE 192 925 N. BLAIR STREET

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VERSEL FLEMING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-085PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-08 13:53
1022	COPPER, FREE	200.8		0.0045 ppm	1.3 ppm	DP	2018-05-08 13:53

Comments: 6M12018/BATHROOM/ SITE 191 221 WHITFIELD STREET

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBBIE PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-084PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 13:49
1022	COPPER, FREE	200.8		0.0161	ppm	1.3	ppm	DP	2018-05-08 13:49

Comments: 6M12018/BATHROOM/ SITE 242

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:27
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-083PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	DP	2018-05-08 13:45
1022	COPPER, FREE	200.8	0.1659 ppm	1.3 ppm	DP	2018-05-08 13:45

Comments: 6M12018/ KITCHEN / SITE 239

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MATHEW JOVANCE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-082PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 13:41
1022	COPPER, FREE	200.8		0.0073	ppm	1.3	ppm	DP	2018-05-08 13:41

Comments: 6M12018/ KITCHEN / SITE 238

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRED BANKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 16:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-081PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0085 ppm	0.015 ppm	DP	2018-05-08 13:37
1022	COPPER, FREE	200.8	0.1346 ppm	1.3 ppm	DP	2018-05-08 13:37

Comments: 6M12018/ KITCHEN BAR / SITE 273

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	N P AKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 16:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-080PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 13:33
1022	COPPER, FREE	200.8		0.0383	ppm	1.3	ppm	DP	2018-05-08 13:33

Comments: 6M12018/ BATHROOM / SITE 272

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 10:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-079PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 13:25
1022	COPPER, FREE	200.8		0.007	ppm	1.3	ppm	DP	2018-05-08 13:25

Comments: 6M12018/ KITCHEN / SITE 279

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAPHNE WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 10:56
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-078PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-08 13:17
1022	COPPER, FREE	200.8		0.0067	ppm	1.3	ppm	DP	2018-05-08 13:17

Comments: 6M12018/ KITCHEN / SITE 186

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NONE GIVEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 11:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-077PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	DP	2018-05-07 20:10
1022	COPPER, FREE	200.8	0.0042 ppm	1.3 ppm	DP	2018-05-07 20:10

Comments: 6M12018/ KITCHEN / SITE 187

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHARRON HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-076PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-07 20:06
1022	COPPER, FREE	200.8		0.0324	ppm	1.3	ppm	DP	2018-05-07 20:06

Comments: 6M12018/ KITCHEN / SITE 227

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MALISSA SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-075PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-07 19:50
1022	COPPER, FREE	200.8		0.0048 ppm	1.3 ppm	DP	2018-05-07 19:50

Comments: 6M12018/ KITCHEN / SITE 179

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ESTHER J	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 06:35
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-074PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-07 19:46
1022	COPPER, FREE	200.8		0.0078	ppm	1.3	ppm	DP	2018-05-07 19:46

Comments: 6M12018/ KITCHEN / SITE 209

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	EVELYN FRANKLIN	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:30
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	2018-05-03
COMPLIANCE	YES	**LAB ID**	180503-073PB	**COMPOSITED**	NO
		PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-07 19:42
1022	COPPER, FREE	200.8		0.0043	ppm	1.3	ppm	DP	2018-05-07 19:42

Comments: 6M12018/ KITCHEN / SITE 174

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SUSAN HARDEE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-072PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-07 19:38
1022	COPPER, FREE	200.8		0.0051 ppm	1.3 ppm	DP	2018-05-07 19:38

Comments: 6M12018/ KITCHEN / SITE 281

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SUSAN HARDEE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-071PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	DP	2018-05-07 19:34
1022	COPPER, FREE	200.8	0.0265 ppm	1.3 ppm	DP	2018-05-07 19:34

Comments: 6M12018/ KITCHEN / SITE 277

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN RUSSOM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-070PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-07 19:26
1022	COPPER, FREE	200.8		0.0111	ppm	1.3	ppm	DP	2018-05-07 19:26

Comments: 6M12018/ BATHROOM / SITE 171

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ATHELIA KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 16:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-069PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0187** ppm	0.015 ppm	DP	2018-05-07 19:18
1022	COPPER, FREE	200.8	0.1837 ppm	1.3 ppm	DP	2018-05-07 19:18

Comments: SITE 293 1ST FLOOR BATHROOM 6M12018

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARTHA JOHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-05-02 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-068PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	DP	2018-05-07 19:14
1022	COPPER, FREE	200.8	0.0451 ppm	1.3 ppm	DP	2018-05-07 19:14

Comments: 6MONTH12018 / 6646 FDR / KITCHEN - OUT OF COMPLIANCE ADDRESS NOT ON SITE PLAN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELISSA R	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-067PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	DP	2018-05-07 18:58
1022	COPPER, FREE	200.8	0.0121 ppm	1.3 ppm	DP	2018-05-07 18:58

Comments: 6MONTH1 2018 / SITE23 5026 KAYBROOK DRIVE / KITCHEN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GERTRUDE KELLY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-066PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-07 18:54
1022	COPPER, FREE	200.8		0.0067 ppm	1.3 ppm	DP	2018-05-07 18:54

Comments: 6MONONTH1 2018 / 4306 WILLOWWOOD / KITCHEN - OUT OF COMPLIACE ADDRESS NOT ON SITE PLAN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KEAN CAVERT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 05:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-065PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	DP	2018-05-07 18:50
1022	COPPER, FREE	200.8	0.0238 ppm	1.3 ppm	DP	2018-05-07 18:50

Comments: 6M12018/ KITCHEN / SITE 282

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	PATRICIA ROBINSON	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2018-04-23 08:00
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	2018-05-03
COMPLIANCE	NO	**LAB ID**	180503-064PB	**COMPOSITED**	NO
		PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	DP	2018-05-07 18:46
1022	COPPER, FREE	200.8	0.0099 ppm	1.3 ppm	DP	2018-05-07 18:46

Comments: 6MONTH12018 / 5035 KOY BROOK DRIVE / BATHROOM - OUT OF COMPLIANCE ADDRESS NOT ON SITE PLAN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALICE HUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-063PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-07 18:42
1022	COPPER, FREE	200.8		0.0208	ppm	1.3	ppm	DP	2018-05-07 18:42

Comments: 6M12018/ KITCHEN / SITE 282

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MONICA SMITH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-062PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-07 18:34
1022	COPPER, FREE	200.8		0.011 ppm	1.3 ppm	DP	2018-05-07 18:34

Comments: 6MONTH1 2018 / 157 TAFT STREET - KTICHEN OUT OF COMPLIANCE ADDRESS NOT ON SITE PLAN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMBER S	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-061PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	DP	2018-05-07 18:26
1022	COPPER, FREE	200.8	0.0284 ppm	1.3 ppm	DP	2018-05-07 18:26

Comments: 6MONTH1 2018 / 1740 BROOKHOLLOW / KITCHEN - OUT OF COMPLIANCE ADDRESS NOT ON SITE PLAN

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	A JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 07:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-060PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	DP	2018-05-07 18:22
1022	COPPER, FREE	200.8	0.0811 ppm	1.3 ppm	DP	2018-05-07 18:22

Comments: 6M12018/ KITCHEN / SITE 70

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	XAVIER HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-059PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	DP	2018-05-07 18:06
1022	COPPER, FREE	200.8	0.0592 ppm	1.3 ppm	DP	2018-05-07 18:06

Comments: 6M12018/ KITCHEN / SITE 163

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WALTER CATHCINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-058PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	DP	2018-05-07 18:02
1022	COPPER, FREE	200.8	0.031 ppm	1.3 ppm	DP	2018-05-07 18:02

Comments: 6M12018/ KITCHEN / SITE 296

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARLON BARKLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 08:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-057PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	DP	2018-05-07 17:58
1022	COPPER, FREE	200.8	0.0151 ppm	1.3 ppm	DP	2018-05-07 17:58

Comments: 6M12018/ BATHROOM /SITE 288

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JACUELINE MIDDLETON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 11:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-056PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	DP	2018-05-07 17:54
1022	COPPER, FREE	200.8	0.079 ppm	1.3 ppm	DP	2018-05-07 17:54

Comments: 6MONTH1 2018 / 416 SHARON HILLS DRIVE/ BATHROOM - OUT OF COMPLIANCE ADDRESS NOT ON SITE PLAN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA HUTSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-055PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-07 17:50
1022	COPPER, FREE	200.8		0.0172	ppm	1.3	ppm	DP	2018-05-07 17:50

Comments: 6M12018/ KITCHEN /SITE 127

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RUBY MAYES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 21:42
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-054PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0134 ppm	0.015 ppm	DP	2018-05-07 17:42
1022	COPPER, FREE	200.8	0.0408 ppm	1.3 ppm	DP	2018-05-07 17:42

Comments: 6M12018/ KITCHEN /SITE 76

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DOUG HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 05:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-053PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	DP	2018-05-07 17:34
1022	COPPER, FREE	200.8	0.0223 ppm	1.3 ppm	DP	2018-05-07 17:34

Comments: 6M12018/ KITCHEN /SITE 28

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MINNIE BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 08:11
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-052PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	DP	2018-05-07 17:30
1022	COPPER, FREE	200.8	0.0197 ppm	1.3 ppm	DP	2018-05-07 17:30

Comments: 6M12018/ KITCHEN /SITE 123

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MINNIE BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-051PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	DP	2018-05-07 17:14
1022	COPPER, FREE	200.8	0.0215 ppm	1.3 ppm	DP	2018-05-07 17:14

Comments: 6M12018/ KITCHEN /SITE 123

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE PENQUITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-050PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0041 ppm	0.015 ppm	DP	2018-05-07 17:10
1022	COPPER, FREE	200.8	0.0303 ppm	1.3 ppm	DP	2018-05-07 17:10

Comments: 6M12018/ KITCHEN /SITE 356

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	BRENDA LAMPKIN	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 06:00
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	2018-05-03
COMPLIANCE	YES	**LAB ID**	180503-049PB	**COMPOSITED**	NO
		PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	DP	2018-05-07 17:06
1022	COPPER, FREE	200.8		0.0226 ppm	1.3 ppm	DP	2018-05-07 17:06

Comments: 6M12018/ KITCHEN /SITE 126 346 E DAVIS STREET

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CALVIN HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-26 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-048PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	DP	2018-05-07 17:02
1022	COPPER, FREE	200.8	0.0117 ppm	1.3 ppm	DP	2018-05-07 17:02

Comments: 6M12018/KITCHEN/SITE 292

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HELEN HUDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	180503-047PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	DP	2018-05-07 16:58
1022	COPPER, FREE	200.8	0.0377 ppm	1.3 ppm	DP	2018-05-07 16:58

Comments: 6M12018/KITCHEN/SITE124 338 E DAVIS STREET

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE CHAPPELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-24 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-046PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	DP	2018-05-07 16:50
1022	COPPER, FREE	200.8	0.0218 ppm	1.3 ppm	DP	2018-05-07 16:50

Comments: 6M12018/KITCHEN/SITE22 5061 KAY BROOK DRIVE

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DOUGLAS MCGUIRE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-045PB	**COMPOSITED**	NO
COMPLIANCE	NO	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0029 ppm	0.015 ppm	DP	2018-05-07 16:42
1022	COPPER, FREE	200.8	0.0516 ppm	1.3 ppm	DP	2018-05-07 16:42

Comments: 6M12018/KITCHEN/ SITE 236 / NOT IN COMPLIANCE ADDRESS NOT ON SITE PLAN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STEDHAM JOHNS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-28 12:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-044PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0339** ppm	0.015 ppm	DP	2018-05-07 16:38
1022	COPPER, FREE	200.8	0.1078 ppm	1.3 ppm	DP	2018-05-07 16:38

Comments: SITE 283 KITCHEN SINK 6M12018

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	180503-043PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	DP	2018-05-07 16:22
1022	COPPER, FREE	200.8	0.2534 ppm	1.3 ppm	DP	2018-05-07 16:22

Comments: 6M12018/KITCHEN/SITE109 1111 N. LAMAR STREET

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBRA MILLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-27 05:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-042PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	DP	2018-05-07 16:18
1022	COPPER, FREE	200.8	0.0203 ppm	1.3 ppm	DP	2018-05-07 16:18

Comments: 6M12018/KITCHEN/SITE 291

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-05-03
SAMPLE POINT	DS000	**LAB ID**	180503-041PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	DP	2018-05-07 16:14
1022	COPPER, FREE	200.8	0.0452 ppm	1.3 ppm	DP	2018-05-07 16:14

Comments: 6M12018/KITCHEN/SITE #122 316 E.. DAVIS STREET

Generated 2018-07-23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WEST	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-04-25 07:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	180503-040PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	DP	2018-05-07 16:10
1022	COPPER, FREE	200.8		0.0037	ppm	1.3	ppm	DP	2018-05-07 16:10

Comments: 6M12018/KITCHEN/SITE 181 265 E DAVIS STREET

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	# Samples	Copper 90th	# Samples
07/01/2018-12/31/2018 (6 Month)	0.008 mg/L	102	0.1 mg/L	102
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EDDIE LAURY JR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 05:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-081PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm		2018-12-06 12:14
1022	COPPER, FREE	200.8	0.026 ppm	1.3 ppm		2018-12-06 12:14

Comments: 6M22018/353 MCKEE ST/ SITE 177/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHAMAYA MILLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 09:11
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-082PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-12-06 12:18
1022	COPPER, FREE	200.8		0.2881 ppm	1.3 ppm		2018-12-06 12:18

Comments: 6M22018/ 200 E BELL ST / SITE 154/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VESEL FLEMMING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 04:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-083PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-12-06 12:22
1022	COPPER, FREE	200.8		0.0568	ppm	1.3	ppm		2018-12-06 12:22

Comments: 6M22018/221 WHITFIELD ST/ SITE 191/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATSY MINER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-084PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-12-06 12:27
1022	COPPER, FREE	200.8		0.0071 ppm	1.3 ppm		2018-12-06 12:27

Comments: 6M22018/ 238 E ASH ST/ SITE 206/ BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN POTTS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-085PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-12-06 12:31
1022	COPPER, FREE	200.8		0.0094 ppm	1.3 ppm		2018-12-06 12:31

Comments: 6M22018/ 141 E ASH ST/ SITE 202/ BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROY FRANKLIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-086PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-12-06 12:35
1022	COPPER, FREE	200.8		0.0089 ppm	1.3 ppm		2018-12-06 12:35

Comments: 6M22018/332 MCKEE ST / SITE 174/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA TUCKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 22:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-087PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm		2018-12-06 12:52
1022	COPPER, FREE	200.8	0.0305 ppm	1.3 ppm		2018-12-06 12:52

Comments: 6M22018/212 ST ANDREWS DR / SITE 278/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GAVIN JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-088PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm		2018-12-06 13:00
1022	COPPER, FREE	200.8	0.0124 ppm	1.3 ppm		2018-12-06 13:00

Comments: 6M22018/248 E ASH ST / SITE 208/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TIM BOOKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-089PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm		2018-12-06 13:09
1022	COPPER, FREE	200.8	0.026 ppm	1.3 ppm		2018-12-06 13:09

Comments: 6M22018/408 EASTVIEW ST / SITE 235/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA ALLEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-090PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-12-06 13:13
1022	COPPER, FREE	200.8		0.0055 ppm	1.3 ppm		2018-12-06 13:13

Comments: 6M22018/227 E ASH ST/ SITE 203/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-24 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-091PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0028 ppm	0.015 ppm		2018-12-06 13:17
1022	COPPER, FREE	200.8	0.0283 ppm	1.3 ppm		2018-12-06 13:17

Comments: 6M22018/ 3951 EASTWOOD DRIVE/ SITE 241/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RICHARD MCNAIR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 21:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-092PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-12-06 13:21
1022	COPPER, FREE	200.8		0.0132 ppm	1.3 ppm		2018-12-06 13:21

Comments: 6M22018/312 E DAVIS STREET / SITE 121/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE FARELS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 23:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-093PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-12-06 13:25
1022	COPPER, FREE	200.8		0.0216 ppm	1.3 ppm		2018-12-06 13:25

Comments: 6M22018/187 EAST BELL STREET / SITE 149/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TAMARA STUBBS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 01:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-094PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-12-06 13:30
1022	COPPER, FREE	200.8	0.013 ppm	1.3 ppm		2018-12-06 13:30

Comments: 6M22018/137 COLONY SQUARE / SITE 354/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 08:53
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-095PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0039 ppm	0.015 ppm		2018-12-06 13:46
1022	COPPER, FREE	200.8	0.0336 ppm	1.3 ppm		2018-12-06 13:46

Comments: 6M22018/ 6010 WHITESTONE / SITE 330/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	A KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-096PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0248** ppm	0.015 ppm		2018-12-06 13:55
1022	COPPER, FREE	200.8	0.1104 ppm	1.3 ppm		2018-12-06 13:55

Comments: 6M22018/ 6252 AMBLEWOOD / SITE 293/ LAUNDRY ROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DANA VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-097PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0084 ppm	0.015 ppm		2018-12-06 14:03
1022	COPPER, FREE	200.8	0.0314 ppm	1.3 ppm		2018-12-06 14:03

Comments: 6M22018/ 6018 FLORAL DRIVE/ SITE 303/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARICE PEARLITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-098PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0049 ppm	0.015 ppm		2018-12-06 14:07
1022	COPPER, FREE	200.8	0.0554 ppm	1.3 ppm		2018-12-06 14:07

Comments: 6M22018/ 282 WOODY DR./ SITE 282/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NO NAME GIVEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 00:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-099PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0287** ppm	0.015 ppm		2018-12-06 14:11
1022	COPPER, FREE	200.8	0.1414 ppm	1.3 ppm		2018-12-06 14:11

Comments: 6M22018/ 6663 LBJ DR/ SITE 283/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIM BROWN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:44
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-100PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0043 ppm	0.015 ppm		2018-12-06 14:16
1022	COPPER, FREE	200.8	0.0501 ppm	1.3 ppm		2018-12-06 14:16

Comments: 6M22018/ 6512 CEDARWOOD DR/ SITE 301/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LISAREE WEST	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-24 08:09
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-101PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-12-06 14:20
1022	COPPER, FREE	200.8		0.0078	ppm	1.3	ppm		2018-12-06 14:20

Comments: 6M22018/265 EAST DAVIS / SITE 181 / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-24 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-102PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm		2018-11-19 19:50
1022	COPPER, FREE	200.8	0.0591 ppm	1.3 ppm		2018-11-19 19:50

Comments: 6M22018/206 SUNDOWN TRAIL / SITE 56 / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	B JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-24 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-103PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm		2018-11-19 19:59
1022	COPPER, FREE	200.8	0.0791 ppm	1.3 ppm		2018-11-19 19:59

Comments: 6M22018/4314 NEW POST ROAD / SITE 070 / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EDDIE CAVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-24 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-104PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-11-19 20:07
1022	COPPER, FREE	200.8	0.0361 ppm	1.3 ppm		2018-11-19 20:07

Comments: 6M22018/1110 NORTH LAMAR ST / SITE 105 /SINK

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE COLLINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-24 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-105PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0053 ppm	0.015 ppm		2018-11-19 20:11
1022	COPPER, FREE	200.8	0.0227 ppm	1.3 ppm		2018-11-19 20:11

Comments: 6M22018/6319 AMBLEWOOD CT/ SITE 290/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-24 05:39
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-106PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-19 20:15
1022	COPPER, FREE	200.8		0.0232 ppm	1.3 ppm		2018-11-19 20:15

Comments: 6M22018/303 SPANISH COURT / SITE 131/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PINKIE JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-24 00:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-107PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0046 ppm	0.015 ppm		2018-11-19 20:19
1022	COPPER, FREE	200.8	0.0239 ppm	1.3 ppm		2018-11-19 20:19

Comments: 6M22018/229 EAST ST / SITE 204/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RONALD ROBINSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 10:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-108PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-19 20:24
1022	COPPER, FREE	200.8		0.0196 ppm	1.3 ppm		2018-11-19 20:24

Comments: 6M22018/2336 CASTLE HILL / SITE 204/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ESTHER JILES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-109PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm		2018-11-19 20:28
1022	COPPER, FREE	200.8	0.0236 ppm	1.3 ppm		2018-11-19 20:28

Comments: 6M22018/241 E. ASH ST / SITE 209/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 17:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-110PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0267** ppm	0.015 ppm		2018-11-19 20:45
1022	COPPER, FREE	200.8	0.126 ppm	1.3 ppm		2018-11-19 20:45

Comments: 6M22018/164 DURANVILLE ST / SITE 77/ BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ERRENCE WILSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-111PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm		2018-11-19 20:53
1022	COPPER, FREE	200.8	0.0668 ppm	1.3 ppm		2018-11-19 20:53

Comments: 6M22018/5039 KEY BROOK / SITE 24/ BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 18:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-112PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0024 ppm	0.015 ppm		2018-11-19 21:01
1022	COPPER, FREE	200.8	0.0097 ppm	1.3 ppm		2018-11-19 21:01

Comments: 6M22108/248 E ASH ST/ SITE 208

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DISHMORE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-113PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0498** ppm	0.015 ppm		2018-11-19 21:06
1022	COPPER, FREE	200.8	0.0375 ppm	1.3 ppm		2018-11-19 21:06

Comments: 6M22108/257 E ASH ST/ SITE 212

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DOUG HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-114PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm		2018-11-19 21:10
1022	COPPER, FREE	200.8	0.0293 ppm	1.3 ppm		2018-11-19 21:10

Comments: 6M22108/1704 BROOKHOLLOW CIRCLE/ SITE 28/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	B. BROADWATER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 07:44
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-115PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0809** ppm	0.015 ppm		2018-11-19 21:14
1022	COPPER, FREE	200.8	0.102 ppm	1.3 ppm		2018-11-19 21:14

Comments: 6M22108/135 COLONY SQUARE / SITE 28/ KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LUCILLE BUCK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 06:58
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-116PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-19 21:18
1022	COPPER, FREE	200.8		0.0096	ppm	1.3	ppm		2018-11-19 21:18

Comments: 6M22108/156 WHITFIELD ST/ SITE 185/ BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBBIE PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 06:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-117PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm		2018-11-19 21:22
1022	COPPER, FREE	200.8	0.0226 ppm	1.3 ppm		2018-11-19 21:22

Comments: 6M22108/908 NEWLAND ST/ SITE 242/ BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KELONA CAVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 05:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-118PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.002 ppm	0.015 ppm		2018-11-19 21:39
1022	COPPER, FREE	200.8	0.153 ppm	1.3 ppm		2018-11-19 21:39

Comments: 6M22108/108 COLONY SQUARE/ SITE 351/ KITCHEN SINK

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBRA MILLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 04:42
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-119PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm		2018-11-19 21:48
1022	COPPER, FREE	200.8	0.0362 ppm	1.3 ppm		2018-11-19 21:48

Comments: 6M22108/1930 AMBLEWOOD DR/ SITE 291/ KITCHEN SINK

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-08-25 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-120PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm		2018-11-19 21:56
1022	COPPER, FREE	200.8	0.0502 ppm	1.3 ppm		2018-11-19 21:56

Comments: 6M2/2018 / Site 159 / 334 East Bell St / Bath Siink

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LUTHER HOLMES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 08:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-121PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-19 22:00
1022	COPPER, FREE	200.8		0.0049 ppm	·1.3 ppm		2018-11-19 22:00

Comments: 6M2/2018 / Site 238 / 5481 Kaywood Dr / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MA WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 08:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-122PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm		2018-11-19 22:04
1022	COPPER, FREE	200.8	0.0093 ppm	1.3 ppm		2018-11-19 22:04

Comments: 6M2/2018 / Site 279 / 6223 Waterford Dr / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-123PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-19 22:08
1022	COPPER, FREE	200.8		0.0079	ppm	1.3	ppm		2018-11-19 22:08

Comments: 6M2/2018 / Site 160 / 235 Bell St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THEO GOURAS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-124PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.008 ppm	0.015 ppm		2018-11-19 22:13
1022	COPPER, FREE	200.8	0.0527 ppm	1.3 ppm		2018-11-19 22:13

Comments: 6M2/2018 / Site 274 / 36 Saint Andrews Dr / Up Stairs

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RASOUL SPRAGINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-125PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-19 22:17
1022	COPPER, FREE	200.8		0.0116	ppm	1.3	ppm		2018-11-19 22:17

Comments: 6M2/2018 / Site 173 / 320 McKee St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIMBERLY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-126PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-11-19 22:34
1022	COPPER, FREE	200.8	0.0327 ppm	1.3 ppm		2018-11-19 22:34

Comments: 6M2/2018 / Site 332 / 6143 Whitestone Rd / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-127PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-19 22:42
1022	COPPER, FREE	200.8		0.1172 ppm	1.3 ppm		2018-11-19 22:42

Comments: 6M2/2018 / Site 158 / 344 E.Bell St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 12:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-128PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm		2018-11-19 22:50
1022	COPPER, FREE	200.8	0.0364 ppm	1.3 ppm		2018-11-19 22:50

Comments: 6M2/2018 / Site 331 / 6064 Whitestone Rd / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENA AMOS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 09:31
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-129PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-19 22:54
1022	COPPER, FREE	200.8		0.1084	ppm	1.3	ppm		2018-11-19 22:54

Comments: 6M2/2018 / Site 159 / 334 East Bell St / Sink-Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-130PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0772** ppm	0.015 ppm		2018-11-19 22:59
1022	COPPER, FREE	200.8	0.035 ppm	1.3 ppm		2018-11-19 22:59

Comments: 6M2/2018 / Site 239 / 1709 Sheffield Dr / Powder Room

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ILETHA DISHMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-21 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-131PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0331** ppm	0.015 ppm		2018-11-19 23:03
1022	COPPER, FREE	200.8	0.0267 ppm	1.3 ppm		2018-11-19 23:03

Comments: 6M2/2018 / Site 212 / 257 E Ash St / Bathroom

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ESTHER TILES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 05:39
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-132PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-11-19 23:07
1022	COPPER, FREE	200.8	0.0238 ppm	1.3 ppm		2018-11-19 23:07

Comments: 6M2/2018 / Site 209 / 241 E Ash St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAPHNE WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-133PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm		2018-11-19 23:11
1022	COPPER, FREE	200.8	0.0085 ppm	1.3 ppm		2018-11-19 23:11

Comments: 6M2/2018 / Site 186 / 188 Whitfield St / Bathroom

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MITZI HOFFMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-134PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-19 23:28
1022	COPPER, FREE	200.8		0.021 ppm	1.3 ppm		2018-11-19 23:28

Comments: 6M2/2018 / Site 253 / 36 Moss Forest Cir / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARISTA SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-135PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-19 23:36
1022	COPPER, FREE	200.8		0.0151	ppm	1.3	ppm		2018-11-19 23:36

Comments: 6M2/2018 / Site 179 / 361 McKee St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-136PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-19 23:45
1022	COPPER, FREE	200.8		0.0052	ppm	1.3	ppm		2018-11-19 23:45

Comments: 6M2/2018 / Site 187 / 184 Whitfield St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	JOHN BOLEL	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 10:00
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	
COMPLIANCE	YES	**LAB ID**	181026-137PB	**COMPOSITED**	NO
LOCATION		**PURPOSE**	RT		

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-11-19 23:49
1022	COPPER, FREE	200.8	0.0245 ppm	1.3 ppm		2018-11-19 23:49

Comments: 6M2/2018 / Site 237 / 414 Eastview St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHARON HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:47
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-138PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-19 23:53
1022	COPPER, FREE	200.8		0.0509	ppm	1.3	ppm		2018-11-19 23:53

Comments: 6M2/2018 / Site 227 / 117 Horeshoe Cir / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRED L BANKS JR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-21 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-139PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-19 23:57
1022	COPPER, FREE	200.8		0.0114 ppm	1.3 ppm		2018-11-19 23:57

Comments: 6M2/2018 / Site 273 / 25 St Andrews / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MOSES OWEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-140PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm		2018-11-20 00:01
1022	COPPER, FREE	200.8	0.0422 ppm	1.3 ppm		2018-11-20 00:01

Comments: 6M2/2018 / Site 161 / 237 Bell St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHERYL ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-141PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0061 ppm	0.015 ppm		2018-11-20 00:06
1022	COPPER, FREE	200.8	0.0277 ppm	1.3 ppm		2018-11-20 00:06

Comments: 6M2/2018 / Site 329 / 5942 Whitestone Rd / Bathroom

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANA BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-142PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0047 ppm	0.015 ppm		2018-11-20 00:22
1022	COPPER, FREE	200.8	0.0264 ppm	1.3 ppm		2018-11-20 00:22

Comments: 6M2/2018 / Site 275 / 51 St Andres Dr / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-21 07:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-143PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm		2018-11-20 00:31
1022	COPPER, FREE	200.8	0.0165 ppm	1.3 ppm		2018-11-20 00:31

Comments: 6M2/2018 / Site 231 / 174 Delaware Ave / Bathroom

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE BRACEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-144PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 00:39
1022	COPPER, FREE	200.8		0.0285 ppm	1.3 ppm		2018-11-20 00:39

Comments: 6M2/2018 / Site 151 / 161 E Bell St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MATT THORNTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-145PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm		2018-11-20 00:43
1022	COPPER, FREE	200.8	0.0131 ppm	1.3 ppm		2018-11-20 00:43

Comments: 6M2/2018 / Site 244 / 950 Newland St / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SUSAN HARDEE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-146PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm		2018-11-20 00:47
1022	COPPER, FREE	200.8	0.0329 ppm	1.3 ppm		2018-11-20 00:47

Comments: 6M2/2018 / Site 277 / 169 Saint Andrews / Kitchen

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN RUSSUM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	
SAMPLE POINT	DS000	**LAB ID**	181026-147PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 00:52
1022	COPPER, FREE	200.8		0.0152 ppm	1.3 ppm		2018-11-20 00:52

Comments: 6M2/2018 / Site 171 / 310 McKee St / Bathroom

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY RICHARDSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-148PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm		2018-11-20 00:56
1022	COPPER, FREE	200.8	0.0235 ppm	1.3 ppm		2018-11-20 00:56

Comments: 6M2/2018 / SITE 326 / 513 WITSELL RD / 2 BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VERNESTER INGRAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:28
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-149PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0224** ppm	0.015 ppm		2018-11-20 01:00
1022	COPPER, FREE	200.8	0.0582 ppm	1.3 ppm		2018-11-20 01:00

Comments: 6M2/2018 / SITE 327 / 546 WITSELL RD / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 07:22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-150PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0034 ppm	0.015 ppm		2018-11-20 01:17
1022	COPPER, FREE	200.8	0.0593 ppm	1.3 ppm		2018-11-20 01:17

Comments: 6M2/2018 / SITE 248 / 2030 SHEFFIELD DR / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SEAL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 14:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-151PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 01:25
1022	COPPER, FREE	200.8		0.011 ppm	1.3 ppm		2018-11-20 01:25

Comments: 6M2/2018 / SITE 155 / 204 BELL ST / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 05:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-152PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0072 ppm	0.015 ppm		2018-11-20 01:33
1022	COPPER, FREE	200.8	0.0844 ppm	1.3 ppm		2018-11-20 01:33

Comments: 6M2/2018 / SITE 333 / 6203 WHITESTONE / 2 BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 07:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-153PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0175** ppm	0.015 ppm		2018-11-20 01:38
1022	COPPER, FREE	200.8	0.0648 ppm	1.3 ppm		2018-11-20 01:38

Comments: 6M2/2018 / SITE 328 / 5907 WOODHAVEN RD / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008				
PWS NAME	CITY OF JACKSON	**COLLECTOR**	CLARENCE A PHILLIPS	**SAMPLE TYPE**	PBCU
COUNTY	HINDS	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 10:00
SAMPLE POINT	DS000	**WORKORDER**		**RECEIVED**	2018-10-26
COMPLIANCE	YES	**LAB ID**	181026-154PB	**COMPOSITED**	NO
		PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm		2018-11-20 01:42
1022	COPPER, FREE	200.8	0.0405 ppm	1.3 ppm		2018-11-20 01:42

Comments: 6M2/2018 / SITE 229 / 142 GLENMARY ST / TUB

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HUDA GRAYER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-24 12:26
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-155PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 01:46
1022	COPPER, FREE	200.8		0.0163 ppm	1.3 ppm		2018-11-20 01:46

Comments: 6M2/2018 / SITE 029 / 1220 BROOKEHOLLOW DR / SINK

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARDEDRA JACKSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-156PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm		2018-11-20 01:50
1022	COPPER, FREE	200.8	0.0508 ppm	1.3 ppm		2018-11-20 01:50

Comments: 6M2/2018 / SITE 026 / 5479 BROOKHOLLOW DR / BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-24 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-157PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-20 01:54
1022	COPPER, FREE	200.8		0.0063	ppm	1.3	ppm		2018-11-20 01:54

Comments: 6M2/2018 / SITE 125 / 340 E DAVIS ST / KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA HUTSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:57
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-158PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 02:11
1022	COPPER, FREE	200.8		0.0249 ppm	1.3 ppm		2018-11-20 02:11

Comments: 6M2/2018 / SITE 127 / 352 E DAVIS ST / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HUBIE NELSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-159PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-20 02:19
1022	COPPER, FREE	200.8		0.0243	ppm	1.3	ppm		2018-11-20 02:19

Comments: 6M2/2018 / SITE 295 / 6424 ABLEWOOD / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BOBBY BLACKMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-160PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm		2018-11-20 02:28
1022	COPPER, FREE	200.8	0.1413 ppm	1.3 ppm		2018-11-20 02:28

Comments: 6M2/2018 / SITE 350 / 104 COLONY SQAURE / KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RESAC WILLIAMNS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-25 08:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-161PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 02:32
1022	COPPER, FREE	200.8		0.0029 ppm	1.3 ppm		2018-11-20 02:32

Comments: 6M2/2018 / SITE 213 / 263 EAST ASH ST / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L HAGGARD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 12:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-162PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0053 ppm	0.015 ppm		2018-11-20 02:36
1022	COPPER, FREE	200.8	0.107 ppm	1.3 ppm		2018-11-20 02:36

Comments: 6M2/2018 / SITE 297 / 1615 FAIRWOOD DR / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAREK ASHLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-163PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm		2018-11-20 02:40
1022	COPPER, FREE	200.8	0.065 ppm	1.3 ppm		2018-11-20 02:40

Comments: 6M2/2018 / SITE 289 / 6313 AMBLEWOOD CT / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STACEY PARISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:56
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-164PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0671** ppm	0.015 ppm		2018-11-20 02:45
1022	COPPER, FREE	200.8	0.2044 ppm	1.3 ppm		2018-11-20 02:45

Comments: 6M2/2018 / SITE 302 / 5411 FLORAL DRIVE / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALICE R HUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:16
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-165PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 02:49
1022	COPPER, FREE	200.8		0.043 ppm	1.3 ppm		2018-11-20 02:49

Comments: 6M2/2018 / SITE 282 / 6570 LBR DR / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TECORA OLIVER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-166PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm		2018-11-20 03:06
1022	COPPER, FREE	200.8	0.0384 ppm	1.3 ppm		2018-11-20 03:06

Comments: 6M2/2018 / SITE 285 / 5756 GEORGE WASHINGTON / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L TUTH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-167PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm		2018-11-20 03:14
1022	COPPER, FREE	200.8	0.0552 ppm	1.3 ppm		2018-11-20 03:14

Comments: 6M2/2018 / SITE 22 / 5020 KAYBROOK DR / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELONIE HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-168PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm		2018-11-20 03:22
1022	COPPER, FREE	200.8	0.0749 ppm	1.3 ppm		2018-11-20 03:22

Comments: 6M2/2018 / SITE 300 / 6418 CEDARWOOD DR / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE CHAPPELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-169PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm		2018-11-20 03:26
1022	COPPER, FREE	200.8	0.0254 ppm	1.3 ppm		2018-11-20 03:26

Comments: 6M2/2018 / SITE 23 / 5061 KAY BROOK DR / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHEAL MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 04:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-170PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm		2018-11-20 03:31
1022	COPPER, FREE	200.8	0.0406 ppm	1.3 ppm		2018-11-20 03:31

Comments: 6M2/2018 / SITE 27 / 5477 BROOKHOLLOW DR / BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	COLLECTOR	THOMAS J MONSON	SAMPLE TYPE	PBCU
PWS NAME	CITY OF JACKSON	LAB	MSDH LAB	COLLECTED	2018-10-23 05:38
COUNTY	HINDS	WORKORDER		RECEIVED	2018-10-26
SAMPLE POINT	DS000	LAB ID	181026-171PB	COMPOSITED	NO
COMPLIANCE	YES	PURPOSE	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm		2018-11-20 03:35
1022	COPPER, FREE	200.8		0.0198 ppm	1.3 ppm		2018-11-20 03:35

Comments: 6M2/2018 / SITE 71 / 4316 NEW POST RD / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WALTER CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 07:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-172PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm		2018-11-20 03:39
1022	COPPER, FREE	200.8	0.0477 ppm	1.3 ppm		2018-11-20 03:39

Comments: 6M2/2018 / SITE 296 / 1609 FAIRWOOD DR / KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MB	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-173PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm		2018-11-20 03:43
1022	COPPER, FREE	200.8	0.0089 ppm	1.3 ppm		2018-11-20 03:43

Comments: 6M2/2018 / SITE 288 / 6306 AMBELWOOD COURT / BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BARBARA CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-23 07:08
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-174PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm		2018-11-20 04:00
1022	COPPER, FREE	200.8	0.1278 ppm	1.3 ppm		2018-11-20 04:00

Comments: 6M2/2018 / SITE 107 / 1120 N LAMAR ST / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ARLESSA JENKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:23
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-175PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-20 04:08
1022	COPPER, FREE	200.8		0.0564	ppm	1.3	ppm		2018-11-20 04:08

Comments: 6M2/2018 / SITE 33 / 4270 WILLOW RUN DR / KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAMAR JACKSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 11:35
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-176PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0075 ppm	0.015 ppm		2018-11-20 04:17
1022	COPPER, FREE	200.8	0.0393 ppm	1.3 ppm		2018-11-20 04:17

Comments: 6M2/2018 / SITE 349 / 101 COLONY ST / BATHROOM

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-177PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-20 04:21
1022	COPPER, FREE	200.8		0.0095	ppm	1.3	ppm		2018-11-20 04:21

Comments: 6M2/2018 / SITE 122 / 31 E DAYES ST

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	COLLECTOR	M BROWN	SAMPLE TYPE	PBCU
PWS NAME	CITY OF JACKSON	LAB	MSDH LAB	COLLECTED	2018-10-22 13:00
COUNTY	HINDS	WORKORDER		RECEIVED	2018-10-26
SAMPLE POINT	DS000	LAB ID	181026-178PB	COMPOSITED	NO
COMPLIANCE	YES	PURPOSE	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-11-20 04:25
1022	COPPER, FREE	200.8	0.0238 ppm	1.3 ppm		2018-11-20 04:25

Comments: 6M2/2018 / SITE 55 / 269 SUNDOWN TR / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRANKIE KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-179PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-11-20 04:29
1022	COPPER, FREE	200.8	0.1167 ppm	1.3 ppm		2018-11-20 04:29

Comments: 6M2/2018 / SITE 109 / 1111 LAMAR ST / SINK

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHARON YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 08:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-180PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm		2018-11-20 04:33
1022	COPPER, FREE	200.8	0.0215 ppm	1.3 ppm		2018-11-20 04:33

Comments: 6M2/2018 / SITE 69 / 4310 NEW POST RD / BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PINKIE JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 05:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-181PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0028 ppm	0.015 ppm		2018-11-20 04:38
1022	COPPER, FREE	200.8	0.0247 ppm	1.3 ppm		2018-11-20 04:38

Comments: 6M2/2018 / SITE 204 / 229 E ASH / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CYNTHIA HINTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2018-10-22 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2018-10-26
SAMPLE POINT	DS000	**LAB ID**	181026-182PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm		2018-11-20 04:54
1022	COPPER, FREE	200.8		0.0051	ppm	1.3	ppm		2018-11-20 04:54

Comments: 6M2/2018 / SITE 150 / 175 EAST BELL ST / KITCHEN

Generated 2018-12-14

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	**# Samples**	**Copper 90th**	**# Samples**
01/01/2019-06/30/2019 (6 Month)	0.007 mg/L	100	0.1 mg/L	100
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SUSAN HARDEE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-062PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 15:55
1022	COPPER, FREE	200.8		0.0155	ppm	1.3	ppm	shelton.cole	2019-06-11 15:55

Comments: 6MONTH/ 169 ST. ANDREWS DRIVE SITE#277 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MITZI HOFFMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-063PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 16:02
1022	COPPER, FREE	200.8		0.017	ppm	1.3	ppm	shelton.cole	2019-06-11 16:02

Comments: 6MONTH/ 36 MOSS FOREST CIRCLE SITE#253 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEARL RANDLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:58
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-064PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	shelton.cole	2019-06-11 16:09
1022	COPPER, FREE	200.8	0.019 ppm	1.3 ppm	shelton.cole	2019-06-11 16:09

Comments: 6MONTH/ 5907 WOODHAVEN ROAD SITE#328 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE LUKE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-065PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 16:13
1022	COPPER, FREE	200.8		0.0073	ppm	1.3	ppm	shelton.cole	2019-06-11 16:13

Comments: 6MONTH/ 1709 SHEFFIELD DRIVE SITE#239 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AUCHUS ALEXANDER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-066PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0103 ppm	0.015 ppm	shelton.cole	2019-06-11 16:17
1022	COPPER, FREE	200.8	0.0236 ppm	1.3 ppm	shelton.cole	2019-06-11 16:17

Comments: 6MONTH/ 16 ST. ANDREWS DRIVE SITE#272 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY COLBERT RICHARD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-067PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0022 ppm	0.015 ppm	shelton.cole	2019-06-11 16:20
1022	COPPER, FREE	200.8	0.0143 ppm	1.3 ppm	shelton.cole	2019-06-11 16:20

Comments: 6MONTH/ 513 WITSELL ROAD SITE#326 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MA WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-04-29
SAMPLE POINT	DS000	**LAB ID**	190503-068PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0077 ppm	0.015 ppm	shelton.cole	2019-06-11 16:24
1022	COPPER, FREE	200.8	0.0345 ppm	1.3 ppm	shelton.cole	2019-06-11 16:24

Comments: 6MONTH/ 6223 WATERFORD DRIVE SITE#279

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANET HOLMES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-069PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0044 ppm	0.015 ppm	shelton.cole	2019-06-11 16:27
1022	COPPER, FREE	200.8	0.1293 ppm	1.3 ppm	shelton.cole	2019-06-11 16:27

Comments: 6MONTH/ 5481 KAYWOOD DRIVE SITE#238 - LAUNDRY ROOM SINK

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THEO G.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-070PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0089 ppm	0.015 ppm	shelton.cole	2019-06-11 16:45
1022	COPPER, FREE	200.8	0.0517 ppm	1.3 ppm	shelton.cole	2019-06-11 16:45

Comments: 6MONTH/ 36 ST. ANDREWS DRIVE SITE#274 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE COLLINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-071PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0051 ppm	0.015 ppm	shelton.cole	2019-06-11 16:52
1022	COPPER, FREE	200.8	0.012 ppm	1.3 ppm	shelton.cole	2019-06-11 16:52

Comments: 6MONTH/ 6319 AMBLEOOD COURT SITE#290 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-072PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	shelton.cole	2019-06-11 16:59
1022	COPPER, FREE	200.8	0.0103 ppm	1.3 ppm	shelton.cole	2019-06-11 16:59

Comments: 6MONTH/ 6252 AMBLEWOOD DRIVE SITE#293 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VANESSA BANKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 10:43
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-073PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	shelton.cole	2019-06-11 17:03
1022	COPPER, FREE	200.8	0.0202 ppm	1.3 ppm	shelton.cole	2019-06-11 17:03

Comments: 6MONTH/ 4318 NEW POST ROAD SITE#72-BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	OLIVER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-074PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 17:06
1022	COPPER, FREE	200.8		0.0048	ppm	1.3	ppm	shelton.cole	2019-06-11 17:06

Comments: 6MONTH/ 6757 GEORGE WASHINGTON SITE#285 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LARRY HAGGARD	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:59
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-075PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0047 ppm	0.015 ppm	shelton.cole	2019-06-11 17:10
1022	COPPER, FREE	200.8	0.0712 ppm	1.3 ppm	shelton.cole	2019-06-11 17:10

Comments: 6MONTH/ 1615 FARRWOOD DRIVE SITE#297 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-02 04:07
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-076PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 17:13
1022	COPPER, FREE	200.8		0.0183	ppm	1.3	ppm	shelton.cole	2019-06-11 17:13

Comments: 6MONTH/ 1720 BROOKHOLLOW CIRCLE SITE#29 - BATHROOM

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AMANDA ADAMS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-077PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	shelton.cole	2019-06-11 17:17
1022	COPPER, FREE	200.8	0.0363 ppm	1.3 ppm	shelton.cole	2019-06-11 17:17

Comments: 6MONTH/ 2030 SHEFFIELD DRIVE SITE#240 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:47
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-078PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	shelton.cole	2019-06-11 17:35
1022	COPPER, FREE	200.8	0.0166 ppm	1.3 ppm	shelton.cole	2019-06-11 17:35

Comments: 6MONTH/ 6010 WHITESTONE ROAD SITE#330 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MANESSA BROWN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 02:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-079PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	shelton.cole	2019-06-11 17:42
1022	COPPER, FREE	200.8	0.0567 ppm	1.3 ppm	shelton.cole	2019-06-11 17:42

Comments: 6MONTH/ 269 SUNDOWN TRAIL SITE#55 - BATHROOM

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ARTESIA JENKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-080PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 17:49
1022	COPPER, FREE	200.8		0.0553	ppm	1.3	ppm	shelton.cole	2019-06-11 17:49

Comments: 6MONTH/ 4270 WILL-O-RUN DRIVE SITE#33 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DARRYL ERVIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-081PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0024 ppm	0.015 ppm	shelton.cole	2019-06-11 17:53
1022	COPPER, FREE	200.8	0.0253 ppm	1.3 ppm	shelton.cole	2019-06-11 17:53

Comments: 6MONTH/ 2329 CASTLE HILL DRIVE SITE#356

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELISSA RESTER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 11:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-082PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	shelton.cole	2019-06-11 17:57
1022	COPPER, FREE	200.8	0.0125 ppm	1.3 ppm	shelton.cole	2019-06-11 17:57

Comments: 6MONTH/ 5026 KAY BROOK DRIVE SITE#23

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEGGY STANSELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-083PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 18:00
1022	COPPER, FREE	200.8		0.0129	ppm	1.3	ppm	shelton.cole	2019-06-11 18:00

Comments: 6MONTH/ 5022 KAY BROOK DRIVE SITE#21 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:32
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-084PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	shelton.cole	2019-06-11 18:04
1022	COPPER, FREE	200.8	0.0094 ppm	1.3 ppm	shelton.cole	2019-06-11 18:04

Comments: 6MONTH/ 174 DELAWARE AVENUE SITE#231

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE CHAPPELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-085PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0018 ppm	0.015 ppm	shelton.cole	2019-06-11 18:07
1022	COPPER, FREE	200.8	0.0127 ppm	1.3 ppm	shelton.cole	2019-06-11 18:07

Comments: 6MONTH/ 5061 KAY BROOK DRIVE SITE#22 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-086PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 18:26
1022	COPPER, FREE	200.8		0.0105	ppm	1.3	ppm	shelton.cole	2019-06-11 18:26

Comments: 6MONTH/ 206 SUNDOWN TRAIL SITE#56 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHERRY COLEMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-087PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 18:31
1022	COPPER, FREE	200.8		0.0042	ppm	1.3	ppm	shelton.cole	2019-06-11 18:31

Comments: 6MONTH/ 414 EASTVIEW STREET SITE#235

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PAMELA BANKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:13
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-088PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	shelton.cole	2019-06-11 18:37
1022	COPPER, FREE	200.8	0.0158 ppm	1.3 ppm	shelton.cole	2019-06-11 18:37

Comments: 6MONTH/ 25 ST. ANDREWS DRIVE SITE#273 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAREK ASHLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-089PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0123 ppm	0.015 ppm	shelton.cole	2019-06-11 18:39
1022	COPPER, FREE	200.8	0.0372 ppm	1.3 ppm	shelton.cole	2019-06-11 18:39

Comments: 6MONTH/ 6313 AMBLEWOOD COURT SITE#289 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 18:07
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-090PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	shelton.cole	2019-06-11 18:42
1022	COPPER, FREE	200.8	0.0103 ppm	1.3 ppm	shelton.cole	2019-06-11 18:42

Comments: 6MONTH/ 51 ANDREWS DRIVE SITE#275 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-091PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 18:44
1022	COPPER, FREE	200.8		0.0059	ppm	1.3	ppm	shelton.cole	2019-06-11 18:44

Comments: 6MONTH/ 6203 WHITESTONE ROAD SITE#333 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WALTER CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-092PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	shelton.cole	2019-06-11 18:47
1022	COPPER, FREE	200.8	0.0312 ppm	1.3 ppm	shelton.cole	2019-06-11 18:47

Comments: 6MONTH/ 1609 FAIRWOOD DRIVE SITE#296 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROSLIN BURNS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-093PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0086 ppm	0.015 ppm	shelton.cole	2019-06-11 18:49
1022	COPPER, FREE	200.8	0.0499 ppm	1.3 ppm	shelton.cole	2019-06-11 18:49

Comments: 6MONTH/ 6512 CEDARWOOD DRIVE SITE#301 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA TUCKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-094PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0081 ppm	0.015 ppm	shelton.cole	2019-06-11 19:05
1022	COPPER, FREE	200.8	0.0427 ppm	1.3 ppm	shelton.cole	2019-06-11 19:05

Comments: 6MONTH/ 212 ST. ANDREWS DRIVE SITE#278 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHERYL ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-095PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0052 ppm	0.015 ppm	shelton.cole	2019-06-11 19:10
1022	COPPER, FREE	200.8	0.0206 ppm	1.3 ppm	shelton.cole	2019-06-11 19:10

Comments: 6MONTH/ 5942 WHITESTONE ROAD SITE#329

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARICE PENQUITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-096PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0024 ppm	0.015 ppm	shelton.cole	2019-06-11 19:14
1022	COPPER, FREE	200.8	0.0208 ppm	1.3 ppm	shelton.cole	2019-06-11 19:14

Comments: 6MONTH/282 WOODY DRIVE SITE#355 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TIMOTHY BODLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-097PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-11 19:17
1022	COPPER, FREE	200.8		0.0077 ppm	1.3 ppm	shelton.cole	2019-06-11 19:17

Comments: 6MONTH/ 408 EASTVIEW STREET SITE#235 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	XAVIER HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-098PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0066 ppm	0.015 ppm	shelton.cole	2019-06-11 19:19
1022	COPPER, FREE	200.8	0.3571 ppm	1.3 ppm	shelton.cole	2019-06-11 19:19

Comments: 6MONTH/ 227 BELLL STREET SITE#163 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VALERIE GLASS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-099PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 19:21
1022	COPPER, FREE	200.8		0.0105	ppm	1.3	ppm	shelton.cole	2019-06-11 19:21

Comments: 6MONTH/ 356 EAST DAVIS STREET SITE#182 - BATH TUB

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELONIE HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-04-30
SAMPLE POINT	DS000	**LAB ID**	190503-100PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	shelton.cole	2019-06-11 19:24
1022	COPPER, FREE	200.8	0.0246 ppm	1.3 ppm	shelton.cole	2019-06-11 19:24

Comments: 6MONTH/ 6418 CEDARWOOD DRIVE SITE#300 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANTONIO JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-101PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0093 ppm	0.015 ppm	shelton.cole	2019-06-11 19:26
1022	COPPER, FREE	200.8	0.0275 ppm	1.3 ppm	shelton.cole	2019-06-11 19:26

Comments: 6MONTH/ 6143 WHITESTONE ROAD SITE#332 - BATHROOM

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LUCILLE BUCK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-102PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 19:43
1022	COPPER, FREE	200.8		0.0058	ppm	1.3	ppm	shelton.cole	2019-06-11 19:43

Comments: 6MONTH/ 156 WHITFIELD STREET SITE#185 - BATHROOM SINK

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RICHARD MCNAIR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-103PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	shelton.cole	2019-06-11 19:47
1022	COPPER, FREE	200.8	0.0368 ppm	1.3 ppm	shelton.cole	2019-06-11 19:47

Comments: 6MONTH/ 312 EAST DAVIS STREET SITE#121 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN POTTS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-104PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 19:52
1022	COPPER, FREE	200.8		0.0118	ppm	1.3	ppm	shelton.cole	2019-06-11 19:52

Comments: 6MONTH/ 141 ASH STREET SITE#202 - BATHROOM

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DISHMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-105PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	shelton.cole	2019-06-11 19:55
1022	COPPER, FREE	200.8	0.0843 ppm	1.3 ppm	shelton.cole	2019-06-11 19:55

Comments: 6MONTH/ 257 EAST AH STREET SITE#212 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONNIE JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 04:34
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-106PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 19:57
1022	COPPER, FREE	200.8		0.0128	ppm	1.3	ppm	shelton.cole	2019-06-11 19:57

Comments: 6MONTH/ 303 SPANISH COURT SITE#131 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATSY MINER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-107PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 19:59
1022	COPPER, FREE	200.8		0.0042	ppm	1.3	ppm	shelton.cole	2019-06-11 19:59

Comments: 6MONTH/ 238 EAST ASH STREET SITE#206 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE BRACEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-108PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 20:02
1022	COPPER, FREE	200.8		0.0242	ppm	1.3	ppm	shelton.cole	2019-06-11 20:02

Comments: 6MONTH/ 161 BELL STREET SITE#151 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MOSES OWENS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-109PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.007 ppm	0.015 ppm	shelton.cole	2019-06-11 20:04
1022	COPPER, FREE	200.8	0.1483 ppm	1.3 ppm	shelton.cole	2019-06-11 20:04

Comments: 6MONTH/ 237 BELL STREET SITE#161 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TUNICIA BURKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-110PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 20:22
1022	COPPER, FREE	200.8		0.1159	ppm	1.3	ppm	shelton.cole	2019-06-11 20:22

Comments: 6MONTH/ 200 BELL STREET SITE#154 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 04:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-111PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 20:27
1022	COPPER, FREE	200.8		0.0071	ppm	1.3	ppm	shelton.cole	2019-06-11 20:27

Comments: 6MONTH/ 340 EAST DAVIS STREET SITE#125-BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN RUSSUM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-112PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-11 20:32
1022	COPPER, FREE	200.8		0.0023 ppm	1.3 ppm	shelton.cole	2019-06-11 20:32

Comments: 6MONTH/ 310 MCKEE STREET SITE#171 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JUDY HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-113PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 20:34
1022	COPPER, FREE	200.8		0.012	ppm	1.3	ppm	shelton.cole	2019-06-11 20:34

Comments: 6MONTH/ 1704 BROOKHOLLOW CIRCLE SITE#28- KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	K CAVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 05:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-114PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	shelton.cole	2019-06-11 20:37
1022	COPPER, FREE	200.8	0.0189 ppm	1.3 ppm	shelton.cole	2019-06-11 20:37

Comments: 6MONTH/ 108 COLONY SQUARE SITE#351 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALICE HUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:41
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-115PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 20:39
1022	COPPER, FREE	200.8		0.0188	ppm	1.3	ppm	shelton.cole	2019-06-11 20:39

Comments: 6MONTH/ 6570 LYNDON B JOHNSON DRIVE SITE#282 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARENCE PHILLIPS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-02 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-116PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	shelton.cole	2019-06-11 20:41
1022	COPPER, FREE	200.8	0.0189 ppm	1.3 ppm	shelton.cole	2019-06-11 20:41

Comments: 6MONTH/ 142 GLENMARY STREET SITE#229

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MICHAEL MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 04:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-30
SAMPLE POINT	DS000	**LAB ID**	190503-117PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 20:44
1022	COPPER, FREE	200.8		0.0108	ppm	1.3	ppm	shelton.cole	2019-06-11 20:44

Comments: 6MONTH/ 5477 BROOKHOLLOW SITE#27 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLENE AMOS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-118PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	shelton.cole	2019-06-11 21:00
1022	COPPER, FREE	200.8	0.0976 ppm	1.3 ppm	shelton.cole	2019-06-11 21:00

Comments: 6MONTH/ 334 BELL STREET SITE#159 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-119PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0021 ppm	0.015 ppm	shelton.cole	2019-06-11 21:05
1022	COPPER, FREE	200.8	0.0861 ppm	1.3 ppm	shelton.cole	2019-06-11 21:05

Comments: 6MONTH/ 4282 WILLORUN DRIVE SITE#34 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DARRELL HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-02 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-120PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	shelton.cole	2019-06-11 21:09
1022	COPPER, FREE	200.8	0.0102 ppm	1.3 ppm	shelton.cole	2019-06-11 21:09

Comments: 6MONTH/ 4333 REDWOOD CIRCLE SITE#80 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CAROLTON HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-121PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	shelton.cole	2019-06-11 21:12
1022	COPPER, FREE	200.8	0.0046 ppm	1.3 ppm	shelton.cole	2019-06-11 21:12

Comments: 6MONTH/ 184 WHITFIELD STREET SITE#187 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBORAH JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-122PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 21:14
1022	COPPER, FREE	200.8		0.0013	ppm	1.3	ppm	shelton.cole	2019-06-11 21:14

Comments: 6MONTH/ 314 NEARVIEW STREET SITE#130 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 03:57
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-123PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 21:16
1022	COPPER, FREE	200.8		0.0132	ppm	1.3	ppm	shelton.cole	2019-06-11 21:16

Comments: 6MONTH/ 2336 CASTLE HILL DRIVE SITE#357

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BOBBY BLACK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-124PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	shelton.cole	2019-06-11 21:19
1022	COPPER, FREE	200.8	0.1191 ppm	1.3 ppm	shelton.cole	2019-06-11 21:19

Comments: 6MONTH/ 104 COLONY SQUARE SITE#350 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	R. SPRAGGINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 11:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-125PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-11 21:21
1022	COPPER, FREE	200.8		0.006	ppm	1.3	ppm	shelton.cole	2019-06-11 21:21

Comments: 6MONTH/ 320 MCKEE STREET SITE#173 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JOSEPH JILES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-126PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-13 12:07
1022	COPPER, FREE	200.8		0.0159	ppm	1.3	ppm	shelton.cole	2019-06-13 12:07

Comments: 6MONTH/ 241 EAST ASH STREET SITE#209 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE RAWLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-127PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-13 12:12
1022	COPPER, FREE	200.8		0.0093 ppm	1.3 ppm	shelton.cole	2019-06-13 12:12

Comments: 6MONTH/ 187 BELL STREET SITE#149 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEON THOMAS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-128PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-13 12:16
1022	COPPER, FREE	200.8		0.013	ppm	1.3	ppm	shelton.cole	2019-06-13 12:16

Comments: 6MONTH/ 235 BELL STREET SITE#160 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA ALLEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-129PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	shelton.cole	2019-06-13 12:19
1022	COPPER, FREE	200.8	0.043 ppm	1.3 ppm	shelton.cole	2019-06-13 12:19

Comments: 6MONTH/ 227 EAST ASH STREET SITE#203 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAPHNE WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 11:54
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-130PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	shelton.cole	2019-06-13 12:21
1022	COPPER, FREE	200.8	0.007 ppm	1.3 ppm	shelton.cole	2019-06-13 12:21

Comments: 6MONTH/ 188 WHITFIELD STREET SITE#186 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GAVALIN JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:39
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-131PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-13 12:23
1022	COPPER, FREE	200.8		0.0087	ppm	1.3	ppm	shelton.cole	2019-06-13 12:23

Comments: 6MONTH/ 248 EAST ASH STREET SITE#208 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-132PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	shelton.cole	2019-06-13 12:26
1022	COPPER, FREE	200.8	0.0701 ppm	1.3 ppm	shelton.cole	2019-06-13 12:26

Comments: 6MONTH/316 EAST DAVIS STREET SITE#122 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA HUTSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 07:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-133PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-13 12:28
1022	COPPER, FREE	200.8		0.0145 ppm	1.3 ppm	shelton.cole	2019-06-13 12:28

Comments: 6MONTH/ 352 EAST DAVIS STREET SITE#127 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAURY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-134PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	shelton.cole	2019-06-13 12:45
1022	COPPER, FREE	200.8	0.0541 ppm	1.3 ppm	shelton.cole	2019-06-13 12:45

Comments: 6MONTH/ 353 MCKEE STREET SITE#177 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-135PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	shelton.cole	2019-06-13 12:49
1022	COPPER, FREE	200.8	0.1198 ppm	1.3 ppm	shelton.cole	2019-06-13 12:49

Comments: 6MONTH/ 344 BELL STREET SITE#158 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRANKIE KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 05:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-136PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-13 12:54
1022	COPPER, FREE	200.8	0.1417 ppm	1.3 ppm	shelton.cole	2019-06-13 12:54

Comments: 6MONTH/ 1111 NORTH LAMAR SITE#109 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JOYCE CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-137PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	shelton.cole	2019-06-13 12:56
1022	COPPER, FREE	200.8	0.05 ppm	1.3 ppm	shelton.cole	2019-06-13 12:56

Comments: 6MONTH/ 132 WOODCLIFF DRIVE SITE#67 - BATHROOM

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PINKIE JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 04:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-138PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0064 ppm	0.015 ppm	shelton.cole	2019-06-13 12:59
1022	COPPER, FREE	200.8	0.0313 ppm	1.3 ppm	shelton.cole	2019-06-13 12:59

Comments: 6MONTH/ 229 EAST ASH STREET SITE#204- KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHAWN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-139PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-13 13:01
1022	COPPER, FREE	200.8	0.0252 ppm	1.3 ppm	shelton.cole	2019-06-13 13:01

Comments: 6MONTH/ 4310 NEW POST ROAD SITE#69 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIMBERLY RUCKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 12:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-140PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-13 13:03
1022	COPPER, FREE	200.8		0.0169 ppm	1.3 ppm	shelton.cole	2019-06-13 13:03

Comments: 6MONTH/ 138 COLONY SITE#353 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHARON COBBINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 08:02
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-141PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-13 13:06
1022	COPPER, FREE	200.8		0.0206 ppm	1.3 ppm	shelton.cole	2019-06-13 13:06

Comments: 6MONTH/ 4341 REDWOOD CIRCLE SITE#83 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAMAR JACKSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 09:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-142PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0059 ppm	0.015 ppm	shelton.cole	2019-06-13 13:24
1022	COPPER, FREE	200.8	0.0426 ppm	1.3 ppm	shelton.cole	2019-06-13 13:24

Comments: 6MONTH/ 101 COLONY SQUARE SITE#349 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CYNTHIA HINTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-143PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-13 13:29
1022	COPPER, FREE	200.8		0.0068	ppm	1.3	ppm	shelton.cole	2019-06-13 13:29

Comments: 6MONTH/ 175 BELL STREET SITE#150 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-144PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-13 13:34
1022	COPPER, FREE	200.8		0.006	ppm	1.3	ppm	shelton.cole	2019-06-13 13:34

Comments: 6MONTH/ 361 MCKEE STREET SITE#179 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN FRANKLIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-145PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-13 13:36
1022	COPPER, FREE	200.8		0.0094	ppm	1.3	ppm	shelton.cole	2019-06-13 13:36

Comments: 6MONTH/ 332 MCKEE STREET SITE#174 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VERSEL FLEMMING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-146PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-13 13:38
1022	COPPER, FREE	200.8		0.0041	ppm	1.3	ppm	shelton.cole	2019-06-13 13:38

Comments: 6MONTH/ 221 WHITFIELD STREET SITE#191 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BARBARA CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 05:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-147PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	shelton.cole	2019-06-13 13:41
1022	COPPER, FREE	200.8	0.1881 ppm	1.3 ppm	shelton.cole	2019-06-13 13:41

Comments: 6MONTH/ 1120 NORTH LAMAR STREET SITE#107 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVE PERKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 09:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-148PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	shelton.cole	2019-06-13 13:43
1022	COPPER, FREE	200.8	0.0119 ppm	1.3 ppm	shelton.cole	2019-06-13 13:43

Comments: 6MONTH/ 6248 WATERFORD DRIVE SITE#281 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MATT THORTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-149PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-13 13:46
1022	COPPER, FREE	200.8	0.0098 ppm	1.3 ppm	shelton.cole	2019-06-13 13:46

Comments: 6MONTH/ 950 NEWLAND STREET SITE#244 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-150PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	shelton.cole	2019-06-17 11:32
1022	COPPER, FREE	200.8	0.0153 ppm	1.3 ppm	shelton.cole	2019-06-17 11:32

Comments: 6MONTH/ 6064 WHITESTONE ROAD SITE#331 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HUBIE NELSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-151PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	shelton.cole	2019-06-17 11:39
1022	COPPER, FREE	200.8		0.0165 ppm	1.3 ppm	shelton.cole	2019-06-17 11:39

Comments: 6MONTH/ 6424 AMBLEWOOD PLACE SITE#295 - KITCHEN

Generated: 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THOMAS MONSOON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 03:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-152PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-17 11:46
1022	COPPER, FREE	200.8		0.0478	ppm	1.3	ppm	shelton.cole	2019-06-17 11:46

mments: 6MONTH/ 4316 NEW POST ROAD SITE#71 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STACEY PARISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-153PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.1199** ppm	0.015 ppm	shelton.cole	2019-06-17 11:50
1022	COPPER, FREE	200.8	0.283 ppm	1.3 ppm	shelton.cole	2019-06-17 11:50

omments: 6MONTH/ 5911 FLORAL DRIVE SITE#302 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WARNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-29 09:10
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-154PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0112 ppm	0.015 ppm	shelton.cole	2019-06-17 11:54
1022	COPPER, FREE	200.8	0.061 ppm	1.3 ppm	shelton.cole	2019-06-17 11:54

Comments: 6MONTH/ 138 COLONY SQUARE SITE#353 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ERRENCE WILSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-155PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.002 ppm	0.015 ppm	shelton.cole	2019-06-17 11:57
1022	COPPER, FREE	200.8	0.1165 ppm	1.3 ppm	shelton.cole	2019-06-17 11:57

Comments: 6MONTH/ 5039 KAYBROOK DRIVE SITE#24 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VERNESTER INGRAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-03 06:52
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-156PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0042 ppm	0.015 ppm	shelton.cole	2019-06-17 12:01
1022	COPPER, FREE	200.8	0.0182 ppm	1.3 ppm	shelton.cole	2019-06-17 12:01

omments: 6MONTH/ 546 WITSELL ROAD SITE#327 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CALVIN HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-02 05:25
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-157PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	shelton.cole	2019-06-17 12:04
1022	COPPER, FREE	200.8	0.0097 ppm	1.3 ppm	shelton.cole	2019-06-17 12:04

omments: 6MONTH/ 6239 AMBLEWOOD DRIVE SITE#292 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TAMARA STUBBS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-158PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-17 12:21
1022	COPPER, FREE	200.8		0.0034	ppm	1.3	ppm	shelton.cole	2019-06-17 12:21

omments: 6MONTH/ 137 COLONY SQUARE SITE#354 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBRA MILLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-05-01 04:38
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-159PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	shelton.cole	2019-06-17 12:25
1022	COPPER, FREE	200.8	0.0119 ppm	1.3 ppm	shelton.cole	2019-06-17 12:25

Comments: 6MONTH/ 1930 AMBLEWOOD DRIVE SITE#291 - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEXREL JAMES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-160PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	shelton.cole	2019-06-17 12:30
1022	COPPER, FREE	200.8	0.0785 ppm	1.3 ppm	shelton.cole	2019-06-17 12:30

Comments: 6MONTH/ 5479 BROOKHOLLOW DRIVE SITE#26 - KITCHEN

Generated 2019-06-26

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBBIE PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-04-30 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-05-03
SAMPLE POINT	DS000	**LAB ID**	190503-161PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	shelton.cole	2019-06-17 12:33
1022	COPPER, FREE	200.8		0.0103	ppm	1.3	ppm	shelton.cole	2019-06-17 12:33

Comments: 6MONTH/ 908 NEWLAND STREET SITE#242

MSDH BUREAU OF PUBLIC WATER SUPPLY
LEAD/COPPER 90TH PERCENTILE

PWS ID	MS0250008	**RESULT TYPE**	PB90/CU90
SYSTEM NAME	CITY OF JACKSON	**SAMPLE POINT**	DS000
COUNTY	HINDS		

	Lead 90th	# Samples	Copper 90th	# Samples
07/01/2019-12/31/2019 (6 Month)	0.007 mg/L	102	0.1 mg/L	102
Action Level	0.015 mg/L		1.3 mg/L	

* = Action Level Exceeded

Generated 2019-12-10

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CLARICE PENQUITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-061PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0078 ppm	0.015 ppm	AS	2019-11-06 14:04
1022	COPPER, FREE	200.8	0.0889 ppm	1.3 ppm	AS	2019-11-06 14:04

Comments: 6M2 / SITE 355 / 282M WOODY DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIMBERLY HALL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 09:35
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-062PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2019-11-06 14:22
1022	COPPER, FREE	200.8	0.0314 ppm	1.3 ppm	AS	2019-11-06 14:22

Comments: 6M2/ SITE 80 / 4333 REDWOOD DR- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HOWARD JENKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-063PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2019-11-06 14:31
1022	COPPER, FREE	200.8	0.1002 ppm	1.3 ppm	AS	2019-11-06 14:31

Comments: 6M2 / SITE 37 / 4270 WILL O RUN - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHERRY COLEMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-064PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2019-11-06 14:39
1022	COPPER, FREE	200.8	0.0245 ppm	1.3 ppm	AS	2019-11-06 14:39

Comments: 6M2 / SITE 237 / 414 EASTVIEW ST

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA HENDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 20:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-065PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 14:43
1022	COPPER, FREE	200.8		0.0142 ppm	1.3 ppm	AS	2019-11-06 14:43

Comments: 6M2 / SITE 74 / 4315 NEWPOST RD - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHAUN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-066PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2019-11-06 14:47
1022	COPPER, FREE	200.8	0.072 ppm	1.3 ppm	AS	2019-11-06 14:47

Comments: 6M2 / SITE 69 / 4310 NEW POST RD - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GREER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-067PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2019-11-06 14:51
1022	COPPER, FREE	200.8	0.1168 ppm	1.3 ppm	AS	2019-11-06 14:51

Comments: 6M2 / SITE 362 / 3900 LOST LAKE CIR- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	C.B	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-068PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2019-11-06 14:55
1022	COPPER, FREE	200.8	0.0251 ppm	1.3 ppm	AS	2019-11-06 14:55

Comments: 6M2 / SITE 331 / 6064 WHITESTONE RD

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLA WASHINGTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-069PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 14:59
1022	COPPER, FREE	200.8		0.0124 ppm	1.3 ppm	AS	2019-11-06 14:59

Comments: 6M2 / SITE 85 / 4355 REDWOOD DR

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ODELL WALLACE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-070PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	AS	2019-11-06 15:17
1022	COPPER, FREE	200.8	0.0542 ppm	1.3 ppm	AS	2019-11-06 15:17

Comments: 6M2 / SITE 56 / 206 SUNDOWN TRAIL DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KEIONA CAVETT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-071PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0019 ppm	0.015 ppm	AS	2019-11-06 15:25
1022	COPPER, FREE	200.8	0.0397 ppm	1.3 ppm	AS	2019-11-06 15:25

Comments: 6M2 / SITE 351 / 108 COLONY SQUARE - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LINDA ALLEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-072PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0042 ppm	0.015 ppm	AS	2019-11-06 15:33
1022	COPPER, FREE	200.8	0.0754 ppm	1.3 ppm	AS	2019-11-06 15:33

Comments: 6M2 / SITE 203 / 227 EAST ASH ST - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JARREL HARPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 09:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-073PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0104 ppm	0.015 ppm	AS	2019-11-06 15:37
1022	COPPER, FREE	200.8	0.0377 ppm	1.3 ppm	AS	2019-11-06 15:37

Comments: 6M2 / SITE 353 / 138 COLONY SQUARE - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NOT LISTED	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 11:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-074PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 15:41
1022	COPPER, FREE	200.8		0.0107 ppm	1.3 ppm	AS	2019-11-06 15:41

Comments: 6M2 / SITE 131 / 303 SPANISH CT - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LAMAR JACKSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 17:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-075PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0251** ppm	0.015 ppm	AS	2019-11-06 15:45
1022	COPPER, FREE	200.8	0.078 ppm	1.3 ppm	AS	2019-11-06 15:45

Comments: 6M2 / SITE 349 / 101 COLONY SQUARE - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MALISSA SAMUEL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-076PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 15:49
1022	COPPER, FREE	200.8		0.0067 ppm	1.3 ppm	AS	2019-11-06 15:49

Comments: 6M2 / SITE 179 / 361 MCKEE ST

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATRICIA BLUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 09:03
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-077PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 15:53
1022	COPPER, FREE	200.8		0.0057 ppm	1.3 ppm	AS	2019-11-06 15:53

Comments: 6M2 / SITE 173 / 320 MCKEE ST- KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CYNTHIA HINTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-078PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 13:42
1022	COPPER, FREE	200.8		0.0031 ppm	1.3 ppm	AS	2019-11-14 13:42

Comments: 6M2 / SITE 150 / 175 EAST BELL ST- KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MOSES OWEN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-079PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 13:50
1022	COPPER, FREE	200.8		0.0209 ppm	1.3 ppm	AS	2019-11-14 13:50

Comments: 6M2 / SITE 161 / 237 BELL ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRANKIE KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:22
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-080PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2019-11-14 13:58
1022	COPPER, FREE	200.8		0.0721	ppm	1.3	ppm	AS	2019-11-14 13:58

Comments: 6M2 / SITE 109 / 1111 N LAMAR ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WALTER CATCHING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 12:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-081PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0023 ppm	0.015 ppm	AS	2019-11-14 14:02
1022	COPPER, FREE	200.8	0.0505 ppm	1.3 ppm	AS	2019-11-14 14:02

Comments: 6M2 / SITE 296 / 1609 FAIRWOOD DR - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	HUBIE NELSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-082PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 14:06
1022	COPPER, FREE	200.8		0.0306 ppm	1.3 ppm	AS	2019-11-14 14:06

Comments: 6M2 / SITE 295 / 6424 AMBLEWOOD PLACE- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANE COLLINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 03:37
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-083PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0046 ppm	0.015 ppm	AS	2019-11-14 14:10
1022	COPPER, FREE	200.8	0.0311 ppm	1.3 ppm	AS	2019-11-14 14:10

Comments: 6M2 / SITE 290 / 6319 AMBLEWOOD - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBRA MILLER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:12
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-084PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 14:14
1022	COPPER, FREE	200.8		0.0005 ppm	1.3 ppm	AS	2019-11-14 14:14

Comments: 6M2 / SITE 291 / 1930 AMBLEWOOD DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VERNESTER INGRAM	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:52
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-085PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.007 ppm	0.015 ppm	AS	2019-11-14 14:18
1022	COPPER, FREE	200.8	0.0539 ppm	1.3 ppm	AS	2019-11-14 14:18

Comments: 6M2 / SITE 327 / 546 WITSELL RD - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	RICHARD M	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 09:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-086PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 14:37
1022	COPPER, FREE	200.8		0.0134 ppm	1.3 ppm	AS	2019-11-14 14:37

Comments: 6M2 / SITE 121 / 312 E. DAVIS ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GATHALIA KING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 06:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-087PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 14:45
1022	COPPER, FREE	200.8		0.0182 ppm	1.3 ppm	AS	2019-11-14 14:45

Comments: 6M2 / SITE 293 / 6252 AMBLEWOOD DR - KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAVE PERKINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-088PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 14:53
1022	COPPER, FREE	200.8		0.006 ppm	1.3 ppm	AS	2019-11-14 14:53

Comments: 6M2 / SITE 281 / 6248 WATERFORD DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIAM HUGHES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-089PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0011 ppm	0.015 ppm	AS	2019-11-14 14:57
1022	COPPER, FREE	200.8	0.0315 ppm	1.3 ppm	AS	2019-11-14 14:57

Comments: 6M2 / SITE 241 / 3951 EASTWOOD DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MATT THORNTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-090PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0019 ppm	0.015 ppm	AS	2019-11-14 15:01
1022	COPPER, FREE	200.8	0.0148 ppm	1.3 ppm	AS	2019-11-14 15:01

Comments: 6M2 / SITE 244 / 950 NEWLAND ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D. LAURY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:06
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-091PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2019-11-14 15:05
1022	COPPER, FREE	200.8	0.0857 ppm	1.3 ppm	AS	2019-11-14 15:05

Comments: 6M2 / SITE 177 / 353 MCKEE ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN YOUNG	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 06:45
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-092PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2019-11-14 15:09
1022	COPPER, FREE	200.8	0.1548 ppm	1.3 ppm	AS	2019-11-14 15:09

Comments: 6M2 / SITE 158 / 344 E. BELL ST- BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	D. JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 11:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-093PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 15:13
1022	COPPER, FREE	200.8		0.005 ppm	1.3 ppm	AS	2019-11-14 15:13

Comments: 6M2 / SITE 130 / 314 NEARVIEW ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	V. FLEMING	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-094PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 17:58
1022	COPPER, FREE	200.8		0.0032 ppm	1.3 ppm	AS	2019-11-06 17:58

Comments: 6M2 / SITE 191 / 221 WHITFIELD ST

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAPHNE WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 11:48
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-095PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 18:06
1022	COPPER, FREE	200.8		0.0034 ppm	1.3 ppm	AS	2019-11-06 18:06

Comments: 6M2 / SITE 186 / 188 WHITFIELD ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BOBBY BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 09:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-096PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2019-11-06 18:14
1022	COPPER, FREE	200.8	0.2071 ppm	1.3 ppm	AS	2019-11-06 18:14

Comments: 6M2 / SITE 350 / 104 COLONY SQUARE- KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	NOT LEGIBLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-097PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.002 ppm	0.015 ppm	AS	2019-11-06 18:18
1022	COPPER, FREE	200.8	0.081 ppm	1.3 ppm	AS	2019-11-06 18:18

Comments: 6M2 / SITE 363 / 3912 LOST LAKE CIRCLE - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BABARA CATCHINGS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:48
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-098PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2019-11-06 18:22
1022	COPPER, FREE	200.8	0.09 ppm	1.3 ppm	AS	2019-11-06 18:22

Comments: 6M2 / SITE 107 / 1120 N. LAMAR ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**		**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-099PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 18:26
1022	COPPER, FREE	200.8		0.0101 ppm	1.3 ppm	AS	2019-11-06 18:26

Comments: 6M2 / SITE 160 / 235 E. BELL ST

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	T VAUGHN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-100PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2019-11-06 18:30
1022	COPPER, FREE	200.8	0.0206 ppm	1.3 ppm	AS	2019-11-06 18:30

Comments: 6M2 / SITE 122 / 237 E. DAVIS ST

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BOOKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 20:40
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-101PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0009 ppm	0.015 ppm	AS	2019-11-06 18:34
1022	COPPER, FREE	200.8	0.0237 ppm	1.3 ppm	AS	2019-11-06 18:34

Comments: 6M2 / SITE 122 / 408 EASTVIEW ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KENNETH BROWN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 10:51
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-102PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.001 ppm	0.015 ppm	AS	2019-11-14 15:32
1022	COPPER, FREE	200.8	0.0473 ppm	1.3 ppm	AS	2019-11-14 15:32

Comments: 6M2 / SITE 361/ 5479 BROOKHOLLOW DR- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VANESSA B	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 08:21
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-103PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0019 ppm	0.015 ppm	AS	2019-11-14 15:40
1022	COPPER, FREE	200.8	0.0359 ppm	1.3 ppm	AS	2019-11-14 15:40

Comments: 6M2 / SITE 72 / 4318 NEW PORT RD - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CARLISA COOPER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-104PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.005 ppm	0.015 ppm	AS	2019-11-14 15:48
1022	COPPER, FREE	200.8	0.1606 ppm	1.3 ppm	AS	2019-11-14 15:48

Comments: 6M2 / SITE 34 / 4282 WILL O RUN- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MONSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-105PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 15:52
1022	COPPER, FREE	200.8		0.0178 ppm	1.3 ppm	AS	2019-11-14 15:52

Comments: 6M2 / SITE 71 / 4316 NEW POST RD - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DISHMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 19:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-106PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 15:56
1022	COPPER, FREE	200.8		0.0105 ppm	1.3 ppm	AS	2019-11-14 15:56

Comments: 6M2 / SITE 212 / 257 E ASH ST - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GARY BURKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 11:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-107PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 16:00
1022	COPPER, FREE	200.8		0.03 ppm	1.3 ppm	AS	2019-11-14 16:00

Comments: 6M2 / SITE 154 / 200 E. BELL ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN POTTS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-108PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 16:04
1022	COPPER, FREE	200.8		0.0104 ppm	1.3 ppm	AS	2019-11-14 16:04

Comments: 6M2 / SITE 202 / 141 E. ASH ST- BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	TRINEE ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 04:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-109PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2019-11-14 16:08
1022	COPPER, FREE	200.8	0.0776 ppm	1.3 ppm	AS	2019-11-14 16:08

Comments: 6M2 / SITE 86 / 4388 REDWOOD CIRCLE - KITCHEN SINK

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHARON COBBINS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:59
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-110PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2019-11-14 16:25
1022	COPPER, FREE	200.8	0.0244 ppm	1.3 ppm	AS	2019-11-14 16:25

Comments: 6M2 / SITE 83 / 4341 REDWOOD CIRCLE - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	XAVIER HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 08:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-111PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2019-11-14 16:33
1022	COPPER, FREE	200.8	0.3678 ppm	1.3 ppm	AS	2019-11-14 16:33

Comments: 6M2 / SITE 163 / 227 E. BELL ST - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PINKRE JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 08:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-112PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0104 ppm	0.015 ppm	AS	2019-11-14 16:41
1022	COPPER, FREE	200.8	0.0948 ppm	1.3 ppm	AS	2019-11-14 16:41

Comments: 6M2 / SITE 204 / 229 E ASH ST - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LUCILLE BUCK	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-113PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 16:45
1022	COPPER, FREE	200.8		0.003 ppm	1.3 ppm	AS	2019-11-14 16:45

Comments: 6M2 / SITE 185 / 156 WHITFIELD ST - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARILYN RUSS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-114PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2019-11-14 16:49
1022	COPPER, FREE	200.8		0.0031	ppm	1.3	ppm	AS	2019-11-14 16:49

Comments: 6M2 / SITE 171/ 310 MCKEE ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE RAWLS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-115PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 16:53
1022	COPPER, FREE	200.8		0.0194 ppm	1.3 ppm	AS	2019-11-14 16:53

Comments: 6M2 / SITE 149 / 187 EAST BELL ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	C. SCOTT (HOME OWNER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 08:54
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-116PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	AS	2019-11-14 16:57
1022	COPPER, FREE	200.8	0.0419 ppm	1.3 ppm	AS	2019-11-14 16:57

Comments: 6M2 / SITE 367 / 3715 MEADOW LANE - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHARLIE MARTIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-117PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2019-11-14 17:01
1022	COPPER, FREE	200.8	0.027 ppm	1.3 ppm	AS	2019-11-14 17:01

Comments: 6M2 / SITE 285 / 6756 GEORGE WASHINGTON DR- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	C. PHILLIP	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 09:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-118PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-14 17:19
1022	COPPER, FREE	200.8		0.0169 ppm	1.3 ppm	AS	2019-11-14 17:19

Comments: 6M2 / SITE 229 / 142 GERMAY ST- BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CONSTANCE WASHINGTON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 17:19
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-119PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2019-11-14 17:27
1022	COPPER, FREE	200.8	0.0934 ppm	1.3 ppm	AS	2019-11-14 17:27

Comments: 6M2 / SITE 352 / 135 COLONY SQ- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JOSEPH JILES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-120PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2019-11-14 17:35
1022	COPPER, FREE	200.8		0.0139	ppm	1.3	ppm	AS	2019-11-14 17:35

Comments: 6M2 / SITE 209 / 241 E. ASH ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EMILEA DUPREE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 08:05
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-121PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2019-11-14 17:39
1022	COPPER, FREE	200.8	0.0287 ppm	1.3 ppm	AS	2019-11-14 17:39

Comments: 6M2 / SITE 354 / 139 COLONY SQ- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	WILLIE BLACKMON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-122PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0014 ppm	0.015 ppm	AS	2019-11-14 17:43
1022	COPPER, FREE	200.8	0.0183 ppm	1.3 ppm	AS	2019-11-14 17:43

Comments: 6M2 / SITE 231/ 174 DELAWARE AVE -BATH

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	QUINCY WEST JR	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 13:56
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-123PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0015 ppm	0.015 ppm	AS	2019-11-14 17:47
1022	COPPER, FREE	200.8	0.0669 ppm	1.3 ppm	AS	2019-11-14 17:47

Comments: 6M2 / SITE 364/ 3924 LOST LAKE CIR -KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SHEQUINTA EDWARDS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 14:04
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-124PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0063 ppm	0.015 ppm	AS	2019-11-14 17:51
1022	COPPER, FREE	200.8	0.0543 ppm	1.3 ppm	AS	2019-11-14 17:51

Comments: 6M2 / SITE 364/ 3936 LOST LAKE CIR -KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JIM FISHER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-125PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0012 ppm	0.015 ppm	AS	2019-11-14 17:55
1022	COPPER, FREE	200.8	0.024 ppm	1.3 ppm	AS	2019-11-14 17:55

Comments: 6M2 / SITE 22 / 5061 KAY BROOK RD -KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KUMARI	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-126PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0032 ppm	0.015 ppm	AS	2019-11-06 21:31
1022	COPPER, FREE	200.8	0.0637 ppm	1.3 ppm	AS	2019-11-06 21:31

Comments: 6M2 / SITE 240 / 2030 SHEFFIELD DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DEBBIE PARKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 06:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-127PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0007 ppm	0.015 ppm	AS	2019-11-06 21:39
1022	COPPER, FREE	200.8	0.0148 ppm	1.3 ppm	AS	2019-11-06 21:39

Comments: 6M2 / SITE 242 / 908 NEWLAND ST - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	FRED BANKS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 08:24
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-128PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2019-11-06 21:47
1022	COPPER, FREE	200.8	0.0098 ppm	1.3 ppm	AS	2019-11-06 21:47

Comments: 6M2 / SITE 273 / 25 ST ANDREWS - KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PEARL RANDLE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-129PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0016 ppm	0.015 ppm	AS	2019-11-06 21:51
1022	COPPER, FREE	200.8	0.0126 ppm	1.3 ppm	AS	2019-11-06 21:51

Comments: 6M2 / SITE 328 / 5907 WOODHAVEN RD - KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANA BELL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-130PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.003 ppm	0.015 ppm	AS	2019-11-06 21:55
1022	COPPER, FREE	200.8	0.023 ppm	1.3 ppm	AS	2019-11-06 21:55

Comments: 6M2 / SITE 275 / 51ST. ANDREWS DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	THEO	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 09:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-131PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0066 ppm	0.015 ppm	AS	2019-11-06 21:59
1022	COPPER, FREE	200.8	0.0228 ppm	1.3 ppm	AS	2019-11-06 21:59

Comments: 6M2 / SITE 274 / 36 ST. ANDREWS DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	AUCHUS ALEXANDER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-17 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-132PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2019-11-06 22:03
1022	COPPER, FREE	200.8	0.0111 ppm	1.3 ppm	AS	2019-11-06 22:03

Comments: 6M2 / SITE 272 / 16 ST. ANDREWS DR - KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY E. COLBERT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-133PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0031 ppm	0.015 ppm	AS	2019-11-06 22:07
1022	COPPER, FREE	200.8	0.0134 ppm	1.3 ppm	AS	2019-11-06 22:07

Comments: 6M2 / SITE 326 / 513 WTSEHH RD - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MITZI HOFFMAN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-134PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2019-11-06 22:25
1022	COPPER, FREE	200.8		0.0086	ppm	1.3	ppm	AS	2019-11-06 22:25

Comments: 6M2 / SITE 253 / 36 MOSS FORREST CIR

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CALVIN HILL	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-135PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0024 ppm	0.015 ppm	AS	2019-11-06 22:33
1022	COPPER, FREE	200.8	0.0318 ppm	1.3 ppm	AS	2019-11-06 22:33

Comments: 6M2 / SITE 292 / 6239 AMBLEWOOD DR

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JANET HOLMES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 04:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-136PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 22:41
1022	COPPER, FREE	200.8		0.0096 ppm	1.3 ppm	AS	2019-11-06 22:41

Comments: 6M2 / SITE 238 / 5481 KAYWOOD DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	STACEY PARISH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-137PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.0695** ppm	0.015 ppm	AS	2019-11-06 22:45
1022	COPPER, FREE	200.8	0.2203 ppm	1.3 ppm	AS	2019-11-06 22:45

Comments: 6M2 / SITE 302 / 5911 FLORAL DRIVE - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ROSLIN BURNS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 06:15
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-138PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0126 ppm	0.015 ppm	AS	2019-11-06 22:49
1022	COPPER, FREE	200.8	0.087 ppm	1.3 ppm	AS	2019-11-06 22:49

Comments: 6M2 / SITE 301 / 6512 CEDARWOOD DR- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA TUCKER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 10:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-139PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0019 ppm	0.015 ppm	AS	2019-11-06 22:53
1022	COPPER, FREE	200.8	0.0177 ppm	1.3 ppm	AS	2019-11-06 22:53

Comments: 6M2 / SITE 278 / 212 ST ANDREWS DR - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CRYSTAL JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-140PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0082 ppm	0.015 ppm	AS	2019-11-06 22:57
1022	COPPER, FREE	200.8	0.0898 ppm	1.3 ppm	AS	2019-11-06 22:57

Comments: 6M2 / SITE 333 / 6203 WHITESTONE RD - BEDROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	PATSY MINER	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 08:29
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-141PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2019-11-06 23:01
1022	COPPER, FREE	200.8	0.0042 ppm	1.3 ppm	AS	2019-11-06 23:01

Comments: 6M2 / SITE 206 / 238 E. ASH ST - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	L.H.	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-18 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-142PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 23:18
1022	COPPER, FREE	200.8		0.135 ppm	1.3 ppm	AS	2019-11-06 23:18

Comments: 6M2 / SITE 297 / 1615 FAIRWOOD DR

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	CHERYL ANDERSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-144PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0077 ppm	0.015 ppm	AS	2019-11-06 23:34
1022	COPPER, FREE	200.8	0.0359 ppm	1.3 ppm	AS	2019-11-06 23:34

Comments: 6M2 / SITE 329 / 5942 WHITESTONE RD

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	KIMBERLY JONES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 06:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-145PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0048 ppm	0.015 ppm	AS	2019-11-06 23:38
1022	COPPER, FREE	200.8	0.0449 ppm	1.3 ppm	AS	2019-11-06 23:38

Comments: 6M2 / SITE 332 / 6143 WHITESTONE RD JACKSON - BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	LISAREE WEST	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-146PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2019-11-06 23:42
1022	COPPER, FREE	200.8		0.0016	ppm	1.3	ppm	AS	2019-11-06 23:42

Comments: 6M2 / SITE 181 / 265 E. DAVIS ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	GAVALIN JOHNSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:55
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-147PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	AS	2019-11-06 23:46
1022	COPPER, FREE	200.8	0.0221 ppm	1.3 ppm	AS	2019-11-06 23:46

Comments: 6M2 / SITE 208/ 248 E. ASH ST- BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ANDREW BRACY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 06:04
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-148PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-06 23:50
1022	COPPER, FREE	200.8		0.0128 ppm	1.3 ppm	AS	2019-11-06 23:50

Comments: 6M2 / SITE 151/ 161 E. BELL ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EVELYN FRANKLIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 05:50
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-149PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0006 ppm	0.015 ppm	AS	2019-11-06 23:54
1022	COPPER, FREE	200.8	0.0074 ppm	1.3 ppm	AS	2019-11-06 23:54

Comments: 6M2 / SITE 174 / 332 MCKEE ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SANDRA BARNES	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 22:01
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-150PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2019-11-07 00:11
1022	COPPER, FREE	200.8		0.0107	ppm	1.3	ppm	AS	2019-11-07 00:11

Comments: 6M2 / SITE 125 / 340 E. DAVIS ST- BATHROOM

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	VALERIE GLASS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 13:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-151PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-07 00:19
1022	COPPER, FREE	200.8		0.0075 ppm	1.3 ppm	AS	2019-11-07 00:19

Comments: 6M2 / SITE 182 / 326 E. DAVIS ST

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	BRENDA HUTSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:32
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-152PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005 ppm	0.015 ppm	AS	2019-11-07 00:27
1022	COPPER, FREE	200.8		0.0199 ppm	1.3 ppm	AS	2019-11-07 00:27

Comments: 6M2 / SITE 127 / 352 E. DAVIS ST- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DAREK ASHLEY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-17 05:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-153PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2019-11-07 00:31
1022	COPPER, FREE	200.8	0.0211 ppm	1.3 ppm	AS	2019-11-07 00:31

Comments: 6M2 / SITE 289 / 6313 AMBLEWOOD CT- KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JAY NORALS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-17
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-154PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0093 ppm	0.015 ppm	AS	2019-11-07 00:35
1022	COPPER, FREE	200.8	0.0546 ppm	1.3 ppm	AS	2019-11-07 00:35

Comments: 6M2 / SITE 294/ 6412 AMBLEWOOD PLACE - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MELONIE HENRY	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 08:00
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-155PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0013 ppm	0.015 ppm	AS	2019-11-07 00:39
1022	COPPER, FREE	200.8	0.0353 ppm	1.3 ppm	AS	2019-11-07 00:39

Comments: 6M2 / SITE 300/ 6418 CEDARWOOD DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MAE WHITE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-156PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		

LOCATION

ID	ANALYTE NAME	METHOD		RESULT		ACL		ANALYST	ANALYSIS
1030	LEAD	200.8	<	0.0005	ppm	0.015	ppm	AS	2019-11-07 00:43
1022	COPPER, FREE	200.8		0.0035	ppm	1.3	ppm	AS	2019-11-07 00:43

Comments: 6M2 / SITE 239 / 1709 SHEFFIELD DR - KITCHEN

Generated 2019-12-05

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	MARY WELCH	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14 10:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-157PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0043 ppm	0.015 ppm	AS	2019-11-07 00:47
1022	COPPER, FREE	200.8	0.0274 ppm	1.3 ppm	AS	2019-11-07 00:47

Comments: 6M2 / SITE 279 / 6223 WATERFORD DR - KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	ALICE HUNT	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-14
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-158PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0008 ppm	0.015 ppm	AS	2019-11-14 18:12
1022	COPPER, FREE	200.8	0.073 ppm	1.3 ppm	AS	2019-11-14 18:12

Comments: 6M2 / SITE 282 / 6570 LBJ DR - KITCHEN

Generated 2019-12-11

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	DARYL ERVIN	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-16 09:19
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-159PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	AS	2019-11-14 18:20
1022	COPPER, FREE	200.8	0.0173 ppm	1.3 ppm	AS	2019-11-14 18:20

Comments: 6M2 / SITE 356 / 2329 CASTLE HILL DR- KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	JERELEAN FUNCHESS	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 09:16
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-160PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0017 ppm	0.015 ppm	AS	2019-11-14 18:28
1022	COPPER, FREE	200.8	0.0268 ppm	1.3 ppm	AS	2019-11-14 18:28

Comments: 6M2 / SITE 330 / 6010 WHITESTONE RD KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	SUSAN HARDEE	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:30
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-161PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	0.0005 ppm	0.015 ppm	AS	2019-11-14 18:32
1022	COPPER, FREE	200.8	0.0267 ppm	1.3 ppm	AS	2019-11-14 18:32

Comments: 6M2 / SITE 277/ 169 ST ANDREWS DR - KITCHEN

MSDH BUREAU OF PUBLIC WATER SUPPLY
SAMPLE RESULTS

PWS ID	0250008	**COLLECTOR**	EARNESTINE WILSON	**SAMPLE TYPE**	PBCU
PWS NAME	CITY OF JACKSON	**LAB**	MSDH LAB	**COLLECTED**	2019-10-15 07:20
COUNTY	HINDS	**WORKORDER**		**RECEIVED**	2019-10-17
SAMPLE POINT	DS000	**LAB ID**	191018-162PB	**COMPOSITED**	NO
COMPLIANCE	YES	**PURPOSE**	RT		
LOCATION					

ID	ANALYTE NAME	METHOD	RESULT	ACL	ANALYST	ANALYSIS
1030	LEAD	200.8	**0.042** ppm	0.015 ppm	AS	2019-11-14 18:36
1022	COPPER, FREE	200.8	0.0237 ppm	1.3 ppm	AS	2019-11-14 18:36

Comments: 6M2 / SITE 304/ 6150 FLORAL DRIVE - BATHROOM