4-28-14 616 W Locust called about sewer backup at 11:00 am arrived at 11:20 am checked manholes they were running good problem in there service line left at 12:45 am. (BA SW)

4-24-2014 912 E locust at 1:30 pm of a well in backyard turned out to be septic tank we dye tested the line and found out they do not go to city sewer they go to septic home owner was notified and has 60 days to hook up to city sewer. (BA SW)

5-2-14 540 E Freeman recieved a call of toilet Backup at 5:00 pm arrived at 5:30 pm checked manhole, Manhole did have standing water jetted line and unclogged was full of grease needs jetted again at later date left at 6:00 pm. (ER)

5-5-14 Assembly of god church at 9:30 am of sewer backup arrived at 10:00 am checked manholes one was full jetted line and pulled firewood out of manhole and big rocks line is open now left at 3:00 pm. (BA - SW)

5-20-14 1329 S Oakland recieved a call of sewer backup at 9:00 am arrived at 9:30 am saw main was flowing just in case went and got camer truck. Cameraed the line looked at their Tap and it was clear Showed pictures to resident left at 11:00 am. (SW)