TITLE V READINGS CTO

	A	B	C	D	E	F	G	H	I	J
1										
2		**Week of:**	7/27/2015							
3										
5							**SCR Catalyst**			
6					**Inlet Temp. F (930-990)**	**Outlet Temp. (830-930)**	**Inlet Temp. F (650-900)**	**Title V Outlet Temp. F >650**	**Inlet NOx (0-8000)**	**Outlet NOx (< 200)**
8		**Shift**	**Oper**	**Time**						
9	Monday	Night	SS	3AM	NOP	NOP	NOP	NOP	NOP	NOP
10		Day	JRC	2pm	NOP	NOP	NOP	NOP	NOP	NOP
11	7/27/2015	Afternoon	SHILL	9PM	NOP	NOP	NOP	NOP	NOP	NOP
12	Tuesday	Night	SS	3AM	NOP	NOP	NOP	NOP	NOP	NOP
13		Day	JRC	9am	NOP	NOP	NOP	NOP	NOP	NOP
14	7/28/2015	Afternoon	SHILL	9PM	NOP	NOP	NOP	NOP	NOP	NOP
15	Wednesday	Night	SS	3AM	NOP	NOP	NOP	NOP	NOP	NOP
16		Day	BG	1PM	NOP	NOP	NOP	NOP	NOP	NOP
17	7/29/2015	Afternoon	SHIIL	9PM	NOP	NOP	NOP	NOP	NOP	NOP
18	Thursday	Night	SS	4AM	NOP	NOP	NOP	NOP	NOP	NOP
19		Day	SH	1PM	NOP	NOP	NOP	NOP	NOP	NOP
20	7/30/2015	Afternoon	JRC	4pm	NOP	NOP	NOP	NOP	NOP	NOP
21	Friday	Night	CB	11:30PM	NOP	NOP	NOP	NOP	NOP	NOP
22		Day	SH	11AM	NOP	NOP	NOP	NOP	NOP	NOP
23	7/31/2015	Afternoon	CB	3:45PM	NOP	NOP	NOP	NOP	NOP	NOP
24	Saturday	Night	SHILL	12AM	NOP	NOP	NOP	NOP	NOP	NOP
25		Day	SH	11AM	NOP	NOP	NOP	NOP	NOP	NOP
26	8/1/2015	Afternoon	CB	6PM	NOP	NOP	NOP	NOP	NOP	NOP
27	Sunday	Night	SHILL	3AM	899	862	834	785	250	0
28		Day	SH	12:30	899	861	832	782	250	0
29	8/2/2015	Afternoon	JRC	5pm	900	863	832	781	250	0
31										
32										

TITLE V READINGS CTO

	K	L	M	N	O
1		**SCR/CTO U N I T L O G S H E E T (P092)**			
2					
3					
5	**Ammonia % valve opening (0-100)**	**% Fan speed (0-100)**	**CTO Suction (-3")-(-5")**	**Ammonia Flow Rate (0.01-0.15gpm)**	**Ammonia Tank Level (60-80)**
6					
8					
9	NOP	NOP	NOP	NOP	NOP
10	NOP	NOP	NOP	NOP	NOP
11	NOP	NOP	NOP	NOP	NOP
12	NOP	NOP	NOP	NOP	NOP
13	NOP	NOP	NOP	NOP	NOP
14	NOP	NOP	NOP	NOP	NOP
15	NOP	NOP	NOP	NOP	NOP
16	NOP	NOP	NOP	NOP	NOP
17	NOP	NOP	NOP	NOP	NOP
18	NOP	NOP	NOP	NOP	NOP
19	NOP	NOP	NOP	NOP	NOP
20	NOP	NOP	NOP	NOP	NOP
21	NOP	NOP	NOP	NOP	NOP
22	NOP	NOP	NOP	NOP	NOP
23	NOP	NOP	NOP	NOP	NOP
24	NOP	NOP	NOP	NOP	NOP
25	NOP	NOP	NOP	NOP	NOP
26	NOP	NOP	NOP	NOP	NOP
27	33	50	-4.9	0.02	80
28	33	50	-4.9	0.07	65
29	33	45	-4.9	0.02	73
31					
32					

TITLE V READINGS CTO

	P	Q	R	S	T	U
1						
2						
3						
5	**Inlet Baghouse Temp (90-140)**	**Pressure Drop Information**				**Comments/ Problems**
6		**Title V DP Baghouse >1"**	**DP SCR (2-7)**	**DP Burner (0.5-1.5)**	**HEPA (<1.5)**	
8						
9	NOP	NOP	NOP	NOP	NOP	
10	NOP	NOP	NOP	NOP	NOP	
11	NOP	NOP	NOP	NOP	NOP	
12	NOP	NOP	NOP	NOP	NOP	
13	NOP	NOP	NOP	NOP	NOP	
14	NOP	NOP	NOP	NOP	NOP	
15	NOP	NOP	NOP	NOP	NOP	
16	NOP	NOP	NOP	NOP	NOP	
17	NOP	NOP	NOP	NOP	NOP	
18	NOP	NOP	NOP	NOP	NOP	
19	NOP	NOP	NOP	NOP	NOP	
20	NOP	NOP	NOP	NOP	NOP	
21	NOP	NOP	NOP	NOP	NOP	
22	NOP	NOP	NOP	NOP	NOP	
23	NOP	NOP	NOP	NOP	NOP	
24	NOP	NOP	NOP	NOP	NOP	
25	NOP	NOP	NOP	NOP	NOP	
26	NOP	NOP	NOP	NOP	NOP	
27	112	2.6	2	0.95	1	
28	111	3	2.5	0.95	1	
29	113	3	2	0.75	0.5	
31					cto unit log sheet.xls	
32					Revised 2 - 4/30/13	

TITLE V READINGS Tri-Mer

	A	B	C	D
1	SHIFT TRI-MER / VIRON SCRUBBER READINGS			
3	**Week of:**	7/27/2015		
4				
5				
6				
7				
8				
9		**Shift**	**Oper**	**Time**
10	Monday	Night	SS	3AM
11		Day	JRC	2PM
12	7/27/2015	Afternoon	SHILL	9PM
13	Tuesday	Night	SS	3AM
14		Day	JRC	9am
15	7/28/2015	Afternoon	SHILL	9PM
16	Wednesday	Night	SS	3AM
17		Day	BG	1PM
18	7/29/2015	Afternoon	SHILL	9PM
19	Thursday	Night	SS	4AM
20		Day	SH	1PM
21	7/30/2015	Afternoon	JRC	4pm
22	Friday	Night	CB	11:20
23		Day	SH	11AM
24	7/31/2015	Afternoon	CB	3:30P
25	Saturday	Night	SHILL	12AM
26		Day	SH	11AM
27	8/1/2015	Afternoon	CB	6PM
28	Sunday	Night	SHILL	3AM
29		Day	SH	12:30
30	8/2/2015	Afternoon	JRC	5pm
32		***	Any condition outside of the prescribed parameters needs to be reported via voice mail to	
33			Ext. 2568 with an email followup to Tim Anglin, Group Leaders, and Superintendents ASAP ***	
34			All Equipment operation outside of parameters must be repaired as soon as possible	
35			Mark section NOP if equipment is Not Operating	

TITLE V READINGS Tri-Mer

	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V
1																		
3																	RC #1	P010
4	Viron PH		Tri-mer PH			Trimer Pressure Drop			Trimer Flow Rates			Check (X)					RC #2	P102
5												Calciners					RC #3	P103
6	Viron #2	Viron #3	Tank 1	Tank 2	Tank 3	Stage1	Stage 2	Stage 3	Stage 1	Stage 2	Stage 3	Routed to					RC #4	P009
7	Range	Range	Range	Range	Range	Range	Range	Range	Range	Range	Range	Trimer					RC #5	P080
8	(6-11)	(6-11)	(10-13)	(10-13)	(10-13)	0"-1.5"	1"-4"	3"-6"	50 MIN	50 MIN	50 MIN	1	2	3	4	5	Comments/ Problems	
9																		
10	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
11	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
12	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
13	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
14	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
15	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
16	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
17	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
18	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
19	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
20	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
21	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
22	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
23	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
24	8.2	7.5	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
25	8.1	7.4	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
26	8	7.6	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
27	8	7.6	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
28	8.1	7.4	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
29	NOP	7.5	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
30	NOP	7.4	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP	NOP							
32																		
33																		
34																		
35																		

TITLE V READINGS Bldg 16

	A	B	C	D
1	South Side Daily Title V Readings Bldg. 16			
4	Week of __7/20/15_____	7/27/2015		
5	Midnight shift readings			
7	Day	Operator	Time	RC #4 (P009)
8				Building 16
9				Baghouse 4a
10				Pressure Drop:
11				0.3-4.5 inches H_2O
12	MONDAY	SS	3AM	2.3
13	TUESDAY	SS	3AM	2.5
14	WEDNESDAY	SS	3AM	NOP
15	THURSDAY	SS	3AM	3.9
16	FRIDAY	CB	11:30P	2.8
17	SATURDAY	SHILL	12AM	3.1
18	SUNDAY	SHILL	3AM	3
21	*NOP = Not Operating*			
22	***Any condition outside of the prescribed parameters need to be reported via voice mail to***			
23	***Tim Anglin ext. 2568, with an email followup to Group Leaders, and Superintendent ASAP*** ***			
24	***The equipment operating outside of parameters must be repaired as soon as possible.***			

TITLE V READINGS Bldg 16

	E	F	G	H	I	J	K	L	M
1									
4									
5									
7	**RC #4 (P009)**	**Viron 2 (P086)**	**Viron 2 (P086)**	**Viron 3 (P086)**	**Viron 3 (P086)**	**National Dryer**	**National Dryer**	**CTO/SCR Stack**	**RC# 5 (P080)**
8	**Building 16**	**Building 16**	**Building 16**	**Building 16**	**Building 16**	**P106**	**P106**	**P092, P102 & P103**	**Dust Collectors 5a & 5b**
9	**Baghouse 4b**	**Scrubber**	**Scrubber**	**Scrubber**	**Scrubber**	**Roof Building 16**	**Baghouse**	**Roof Building 16**	**Roof Building 16**
10	**Pressure Drop:**	**Pressure Drop:**	**Water Flow Rate**	**Pressure Drop:**	**Water Flow Rate**	**Visible Emissions**	**Pressure Drop**	**Visible Emissions**	**Visible Emissions**
11	**0.3-4.5 inches H_2O**	**>1 inch H_2O**	**> 2 GPM**	**>1 inch H_2O**	**> 2 GPM**	**Y/N**	**1-4 inches H_2O**	**Y/N**	**Y/N**
12	**4.4**	**NOP**	**NOP**	**NOP**	**NOP**	**NO**	**NOP**	**NO**	NO
13	**4.1**	**NOP**	**NOP**	**NOP**	**NOP**	**NO**	**NOP**	**NO**	NO
14	**NOP**	**NOP**	**NOP**	**NOP**	**NOP**	**NO**	**NOP**	**NO**	NO
15	**4.3**	**NOP**	**NOP**	**NOP**	**NOP**	**NO**	**3.2**	**NO**	NO
16	**3.8**	**NOP**	**NOP**	**NOP**	**NOP**	**NO**	**1.5**	**NO**	NO
17	**3.8**	**2.5**	**2**	**3.4**	**2**	**NO**	**1.25**	**NO**	NO
18	**3.8**	**2.5**	**2**	**3.5**	**2**	**NO**	**1,26**	**NO**	NO
21									
22									
23									
24									

	A	B	C	D
1	South Side Daily Title V Readings Bldg. 11			
4	7/27/2015			
5	Afternoon Shift Readings			
7	**Day**	**Operator**	**Time**	**Powder Room**
8				**Building 11**
9				**Baghouse**
10				**Pressure Drop:**
11				**>1 inch H_2O**
12	**MONDAY**	**SS**	**3AM**	**NOP**
13	**TUESDAY**	**SS**	**3AM**	**NOP**
14	**WEDNESDAY**	**SS**	**3AM**	**NOP**
15	**THURSDAY**	**JRC**	**4pm**	**NOP**
16	**FRIDAY**	**SH**	**3AM**	**NOP**
17	**SATURDAY**	**SHILL**	**12AM**	**NOP**
18	**SUNDAY**	**SHILL**	**3AM**	**NOP**
21	***NOP = Not Operating***			
22	***Any condition outside of the prescribed parameters need to be reported via voice mail to***			
23	***Tim Anglin ext. 2568, with an email followup to Group Leaders, and Superintendent ASAP*** ***			
24	***The equipment operating outside of parameters must be repaired as soon as possible.***			

	E	F	G
1			
4			
5			
7	**Powder Room**	**Powder Room**	**Powder Room**
8	**Building 11**	**Building 11**	**Building 11**
9	**50 lb. Bag Area Filter Fabric**	**Baghouse**	**50 lb. Bag Area Filter Fabric**
10	**Pressure Drop:**	**Visible Emissions**	**Visible Emissions**
11	**>1 inch H_2O**	**Y/N**	**Y/N**
12	**NOP**	**NO**	**NO**
13	**NOP**	**NO**	**NO**
14	**NOP**	**NO**	**NO**
15	**NOP**	**NO**	**NO**
16	**NOP**	**NO**	**NO**
17	**NOP**	**NO**	**NO**
18	**NOP**	**NO**	**NO**
21			
22			
23			
24			

TITLE V READINGS Bldg 31

	A	B	C	D
1	South Side Daily Title V Readings Bldgs. 31			
4	7/27/2015			
5	Afternoon Shift Reading			
7	**Day**	**Operator**	**Time**	**F 2 Scrubber**
8				**P024 & P026**
9				**Building 31 Roof**
10				**Visible Emissions**
11				**Y/N**
12	**MONDAY**	**SS**	**3AM**	**NO**
13	**TUESDAY**	**SS**	**3AM**	**NO**
14	**WEDNESDAY**	**SS**	**3AM**	**NO**
15	**THURSDAY**	**JRC**	**4pm**	**NO**
16	**FRIDAY**	**SH**	**3AM**	**NO**
17	**Saturday**	**SHILL**	**12AM**	**NO**
18	**Sunday**	**SHILL**	**3AM**	**NO**
21	***NOP = Not Operating***			
22	***Any condition outside of the prescribed parameters need to be reported via voice mail to***			
23	***Tim Anglin ext. 2568, with an email followup to Group Leaders, and Superintendent ASAP ******			
24	***The equipment operating outside of parameters must be repaired as soon as possible.***			

TITLE V READINGS Bldg 31

	E	F	G	H
1				
4				
5				
7	**F 1 Scrubber**	**TriMer Stack**	**Roof Dust Collectors**	**Action Taken**
8	**P010 & P028**	**P010, P026 &P080**	**P026, P028 & P010**	
9	**Building 31 Roof**	**Building 31 Roof**	**Building 31 Roof**	
10	**Visible Emissions**	**Visible Emissions**	**Visible Emissions**	
11	**Y/N**	**Y/N**	**Y/N**	
12	**NO**	**NO**	**NO**	
13	**NO**	**NO**	**NO**	
14	**NO**	**NO**	**NO**	
15	**NO**	**NO**	**NO**	
16	**NO**	**NO**	**NO**	
17	**NO**	**NO**	**NO**	
18	**NO**	**NO**	**NO**	
21				
22				
23				
24				

TITLE V READINGS Bldg 9

	A	B	C	D
1	South Side Daily Title V Readings Bldg. 9			
4	7/27/2015			
5	Midnight Shift Readings			
7	**Day**	**Operator**	**Time**	**PK Blender (P099)**
8				**Building 9**
9				**Baghouse**
10				**Pressure Drop:**
11				**3-5 inches H_2O**
12	**MONDAY**	**SS**	**3AM**	**NOP**
13	**TUESDAY**	**SS**	**3AM**	**NOP**
14	**WEDNESDAY**	**SS**	**3AM**	**NOP**
15	**THURSDAY**	**SS**	**3AM**	**NOP**
16	**FRIDAY**	**CB**	**11PM**	**4.45**
17	**SATURDAY**	**SHILL**	**12AM**	**3.4**
18	**SUNDAy**	**SHILL**	**3AM**	**NOP**
21	***NOP = Not Operating***			
22	***Any condition outside of the prescribed parameters need to be reported via voice mail to***			
23	***Tim Anglin ext. 2568, with an email followup to Group Leaders, and Superintendent ASAP ******			
24	***The equipment operating outside of parameters must be repaired as soon as possible.***			

TITLE V READINGS Bldg 9

	E	F	G	H
1				
4				
5				
7	**PK Blender (P099)**	**PK Blender (P099)**	**PK Blender (P099)**	**Action Taken**
8	**Building 9**	**Building 9**	**Building 9**	
9	**Scrubber**	**Scrubber**	**Visible**	
10	**Pressure Drop:**	**Water Flow**	**Emissions**	
11	**>/= 2 inches H_2O**	**Y/N**	**Y/N**	
12	**NOP**	**NO**	**NO**	
13	**NOP**	**NO**	**NO**	
14	**NOP**	**NO**	**NO**	
15	**NOP**	**NO**	**NO**	
16	**NOP**	**NO**	**NO**	
17	**NOP**	**NO**	**NO**	
18	**NOP**	**NO**	**NO**	
21				
22				
23				
24				

	A	B	C	D
1	South Side Daily Title V Readings Bldg. 27			
4	7/27/2015			
5	Afternoon Shift Readings			
7	**Day**	**Operator**	**Time**	**P&S Dryer / RC #6**
8				**P092 and P130**
9				**Sly Scrubber**
10				**Flow**
11				**> 2gpm**
12	**Monday**	**SS**	**3AM**	**N/A**
13	**Tuesday**	**SS**	**3AM**	**N/A**
14	**Wednesday**	**SS**	**3AM**	**N/A**
15	**Thursday**	**JRC**	**4pm**	**N/A**
16	**Friday**	**CB**	**3:45pm**	**N/A**
17	**Saturday**	**CB**	**3:45pm**	**N/A**
18	**Sunday**	**JRC**	**5pm**	**N/A**
21	***NOP = Not Operating***			
22	***Any condition outside of the prescribed parameters need to be reported via voice mail to***			
23	***Tim Anglin ext. 2568, with an email followup to Group Leaders, and Superintendent ASAP ******			
24	***The equipment operating outside of parameters must be repaired as soon as possible.***			

Bldg 27

	E	F	G	H	I
1					
4					
5					
7	**P&S Dryer / RC #6**	**P&S Dryer / RC #6**	**RC #6**	**Horne Tabletting**	**Action Taken**
8	**P092 and P130**	**P092 and P130**	**P092**	**P096**	
9	**Sly Scrubber**	**Sly Scrubber**	**Baghouse**	**Visible**	
10	**Demister Pressure**	**Visible Emissions**	**Pressure Drop**	**Emissions**	
11	**<1 inches H_2O**	**Y/N**	**<2 inches H_2O**	**Y/N**	
12	**NOP**	**NO**	**NOP**	**NO**	
13	**NOP**	**NO**	**NOP**	**NO**	
14	**NOP**	**NO**	**NOP**	**NO**	
15	**0.1**	**NO**	**0.5**	**NO**	
16	**0.1**	**NO**	**NOP**	**NO**	
17	**0.1**	**NO**	**NOP**	**NO**	
18	**0.1**	**NO**	**NOP**	**NO**	
21					
22					
23					
24					

Dust Coll

	B	C
4	week of 7/20/2015	
5		
6		
8	**Date**	**Shift**
9	#######	
11		
12	#######	
14		
15	#######	
17		
18	#######	
20		
21	#######	
23		
24	8/1/2015	
26		
27	8/2/2015	
29		
31	**If pressure drop across any of the dust collectors increases a large amount or is increasing day after day, this may indicate a problem is present. Alert engineer or group leader**	
32	***If drum level has not increased at all since the previous day, alert group leader/leadman to investigate. Change out drums as necessary and label.**	
33	****If rotolock is not turning, alert group leader/leadman immediately. Dust collector can fill up and pack if rotolock is not on**	

Dust Coll

	D	E	F	G	H	I	J	K
4		**Dust collectors - Return to GL once sheet complete**						
5		**#1**	**#1**	**#2**	**#2**	**#3**	**#3**	**#7**
6		Pressure drop ("H2O)	Drum Level*	Pressure drop ("H2O)	Drum Level*	Pressure drop ("H2O)	Drum Level*	Pressure drop ("H2O)
8	**Operator**							
9								
11	**Rotolock on?****	Y or N		Y or N		Y or N		Y or N
12								
14	**Rotolock on?****	Y or N		Y or N		Y or N		Y or N
15								
17	**Rotolock on?****	Y or N		Y or N		Y or N		Y or N
18								
20	**Rotolock on?****	Y or N		Y or N		Y or N		Y or N
21								
23	**Rotolock on?****	Y or N		Y or N		Y or N		Y or N
24								
26	**Rotolock on?****	Y or N		Y or N		Y or N		Y or N
27								
29	**Rotolock on?****	Y or N		Y or N		Y or N		Y or N
31								
32								
33								

Dust Coll

	M	O	P	Q	R	S	T	U	V	W
4										
5	**#7**	**#8**	**#8**	**Vertical**	**Vertical**	**CTO**	**CTO**	**National Dryer**	**National Dryer**	**PK Blender**
6	Drum Level*	Pressure drop ("H2O)	Drum Level*	Pressure drop ("H2O)	Drum Level*	Pressure drop ("H2O)	Drum Level*	Pressure drop ("H2O)	Drum Level*	Drum Level*
8										
9										
11		Y or N		Y or N		Y or N		Y or N		Y or N
12										
14		Y or N		Y or N		Y or N		Y or N		Y or N
15										
17		Y or N		Y or N		Y or N		Y or N		Y or N
18										
20		Y or N		Y or N		Y or N		Y or N		Y or N
21										
23		Y or N		Y or N		Y or N		Y or N		Y or N
24										
26		Y or N		Y or N		Y or N		Y or N		Y or N
27										
29		Y or N		Y or N		Y or N		Y or N		Y or N
31										
32										
33										

	B	C	D	E	H
2					
4				**F1/F2 Scrubber Checksheet - Return to GL once sheet complete**	
5				**F1 Demister**	**F1 Packing**
6				Pressure drop ("H2O)	Pressure drop ("H2O)
8	**Date**	**Shift**	**Operator**		
9	#######			0	10
10		11-7am	SAMS		
11	#######			0	10.5
12		11-7am	SAMS		
13	#######			0	NOP
14		11-7am	SAMS		
15	#######			0	NOP
17	#######			0	NOP
19	8/1/2015			0	NOP
21	8/2/2015			0	10
23	8/3/2015				
25	8/4/2015				
29	**If pressure drop across any of the three spots increase a large amount or is increasing week after week, this may indicate a problem is present. Alert engineer or group leader**				

F1 F2

	I	K	P	S	V
2	AFTERNOON SHIFT READINGS				
4					
5		**F1 Blower**	**F2 Demister**	**F2 Packing**	**F2 Blower**
6		Pressure drop ("H2O)	Pressure drop ("H2O)	Pressure drop ("H2O)	Pressure drop ("H2O)
8					
9		10.5	NOP	NOP	NOP
10					
11		11.5	NOP	NOP	NOP
12					
13		NOP	NOP	NOP	NOP
14					
15		NOP	NOP	NOP	NOP
17		NOP	0.01	0.21	3.46
19		NOP	NOP	NOP	NOP
21		12.5	0.2	0	3.8
23					
25					
29					