Soldotna Y Chevron
44024 Sterling Hwy.
Soldotna, AK, 99669

ANCHORAGE AK 9

03 NOV 2014 PM

RECEIVED
NOV - 6 2014
U.S. EPA REGION 10
OFFICE OF COMPLIANCE AND ENFORCEMENT

Anne Christopher
1200 6th Avenue (OCE-082)
Seattle, WA, 98101

98101$3123

3/5/14

-------- AUTOLEAK REPORT --------
WED MAR 05,14 12:00:00 AM
STATION NAME:
SOLDOTNA Y CHEVRON
44024 STERLING HWY
SOLDOTNA AK 99669

TANK 1 PRODUCT: KEROSENE

LEAK RATE: -0.001 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
SAT MAR 01,14 12:00:00 AM
TEST 1: -0.001 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: ?.??? gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
WED MAR 05,14 12:00:00 AM
- - - - - - - - - - - - - - - - - - -
TANK 2 PRODUCT: PREM UNLEAD

LEAK RATE: -0.006 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
SAT MAR 01,14 12:00:00 AM
TEST 1: -0.006 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: ?.??? gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
WED MAR 05,14 12:00:00 AM
- - - - - - - - - - - - - - - - - - -
TANK 3 PRODUCT: DIESEL 4

LEAK RATE: -0.043 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
SAT MAR 01,14 12:00:00 AM
TEST 1: -0.043 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: ?.??? gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
WED MAR 05,14 12:00:00 AM
- - - - - - - - - - - - - - - - - - -
TANK 4 PRODUCT: UNLEADED

LEAK RATE: -0.052 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
SAT MAR 01,14 12:00:00 AM
TEST 1: -0.052 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: ?.??? gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
WED MAR 05,14 12:00:00 AM

3/13/14

-------- AUTOLEAK REPORT --------
THU MAR 13,14 12:00:00 AM
STATION NAME:
SOLDOTNA Y CHEVRON
44024 STERLING HWY
SOLDOTNA AK 99669

TANK 1 PRODUCT: KEROSENE

LEAK RATE: -0.001 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
MON MAR 10,14 2:09:40 AM
TEST 1: -0.001 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: -0.001 gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
THU MAR 13,14 12:00:00 AM
- - - - - - - - - - - - - - - - - - -
TANK 2 PRODUCT: PREM UNLEAD

LEAK RATE: -0.005 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
MON MAR 10,14 2:09:40 AM
TEST 1: -0.006 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: -0.005 gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
THU MAR 13,14 12:00:00 AM
- - - - - - - - - - - - - - - - - - -
TANK 3 PRODUCT: DIESEL 4

LEAK RATE: -0.033 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
MON MAR 10,14 2:09:40 AM
TEST 1: -0.043 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: -0.023 gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
THU MAR 13,14 12:00:00 AM
- - - - - - - - - - - - - - - - - - -
TANK 4 PRODUCT: UNLEADED

LEAK RATE: -0.056 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
MON MAR 10,14 2:09:40 AM
TEST 1: -0.052 gal/hr
TEST 2: ?.??? gal/hr
TEST 3: -0.060 gal/hr
TEST 4: ?.??? gal/hr
TEST 5: ?.??? gal/hr
TEST 6: ?.??? gal/hr
LEAK TEST END:
THU MAR 13,14 12:00:00 AM