2nd print

CASINOMAHA[illegible]EL PLZ.
BLACKBIRD BEND
ONAWA, IA. 51040
712-423-3974
V004K

10-19-98 12:55:09

CURRENT TLM LEAK TEST STATUS:

TANK 1 DIESEL
NOT RUNNING

TANK 2 DIESEL
NOT RUNNING

TANK 3 DIESEL
NOT RUNNING

%%

LAST SUCCESSFUL TLM LEAK TEST:

TANK 1 DIESEL

0.1 GPH TEST
10-19-98 12:44:00
PRODUCT LEVEL: 36.51 "
PERCENT VOLUME: 34 %
PRODUCT TEMP: 67.79 °F
CALCULATED RATE OF CHANGE:
-0.025
(VOLUME IS INCREASING.)

0.2 GPH TEST
10-19-98 12:44:00
PRODUCT LEVEL: 36.51 "
PERCENT VOLUME: 34 %
PRODUCT TEMP: 67.79 °F
CALCULATED RATE OF CHANGE:
-0.025
(VOLUME IS INCREASING.)

TANK 2 DIESEL

0.2 GPH TEST
10-19-98 12:44:00
PRODUCT LEVEL: 25.39 "
PERCENT VOLUME: 21 %
PRODUCT TEMP: 67.28 °F
CALCULATED RATE OF CHANGE:
-0.060
(VOLUME IS INCREASING.)

TANK 3 DIESEL

0.1 GPH TEST
01-01-98 08:43:00
PRODUCT LEVEL: 82.02 "
PERCENT VOLUME: 91 %
PRODUCT TEMP: 48.95 °F
CALCULATED RATE OF CHANGE:
0.032
(VOLUME IS DECREASING.)

0.2 GPH TEST
10-19-98 11:18:00
PRODUCT LEVEL: 87.79 "
PERCENT VOLUME: 95 %
PRODUCT TEMP: 67.89 °F
CALCULATED RATE OF CHANGE:
-0.026
(VOLUME IS INCREASING.)

%%

TANK 1 DIESEL

PASSED 0.1 LEAK TESTS
01-04-98 06:33

PASSED 0.2 LEAK TESTS
10-01-98 10:30
09-24-98 21:55
08-01-98 03:20
07-20-98 04:27
04-01-98 [illegible]:42
03-01-98 08:28
02-01-98 04:57
01-02-98 22:56
12-01-97 05:23
11-01-97 [illegible]:18
10-01-97 [illegible]:17
09-01-97 01:01

TANK 2 DIESEL

PASSED 0.2 LEAK TESTS
10-01-98 05:09
09-24-98 21:55
08-01-98 03:20
07-20-98 04:27
04-01-98 00:42
03-01-98 08:28
02-01-98 04:57
01-04-98 16:47
12-01-97 05:23
11-01-97 00:18
10-01-97 05:17
09-01-97 01:01

TANK 3 DIESEL

PASSED 0.1 LEAK TESTS
01-01-98 08:43

PASSED 0.2 LEAK TESTS
10-01-98 00:39
09-01-98 01:31
08-01-98 00:51
07-10-98 10:34
06-01-98 00:46
05-01-98 00:28
04-01-98 01:20
03-01-98 02:08
02-01-98 01:44
01-01-98 00:39
12-01-97 01:34
11-01-97 00:34

%%

LEAK TEST REPORT
TANK 1 DIESEL

TEST TYPE: CONTINUOUS, 0.1 GPH
THRESHOLD: 0.05
CONFIDENCE LEVEL: 99/1
LAST DELIVERY: 09-29-98 13:13
TEST START DATE: 10-19-98
TEST START TIME: 02:22
TEST LENGTH: 10.37 HOUR(S)

TANK CAPACITY: 18049 US GAL
% FULL VOLUME: 34
PROD LEVEL CHANGE: 0.0010 "
PROD GROSS CHANGE: 0.232 US GAL
PROD NET CHANGE: 0.460 US GAL
PROD TEMP CHANGE: -0.08 °F
RTD 1 CHANGE: -0.08 °F
RTD 2 CHANGE: -0.08 °F
RTD 3 CHANGE: -0.12 °F
RTD 4 CHANGE: -0.15 °F
RTD 5 CHANGE: -0.17 °F
WAT LEVEL CHANGE: 0.0003 "
WAT VOLUME CHANGE: 0.007 US GAL
COEFF 1: 0.1162
COEFF 2: 0.0406

TEST RESULT: PASSED
LEAK RATE: -0.02 GPH
VOLUME IS INCREASING
%%

LEAK TEST REPORT
TANK 2 DIESEL

TEST TYPE: CONTINUOUS, 0.2 GPH
THRESHOLD: 0.1
CONFIDENCE LEVEL: 99/1
LAST DELIVERY: 09-29-98 13:13
TEST START DATE: 10-19-98
TEST START TIME: 02:22
TEST LENGTH: 10.37 HOUR(S)

TANK CAPACITY: 18049 US GAL
% FULL VOLUME: 21
PROD LEVEL CHANGE: -11.123 "
PROD GROSS CHANGE: -2481 US GAL
PROD NET CHANGE: -2472 US GAL
PROD TEMP CHANGE: -0.59 °F
RTD 1 CHANGE: -0.43 °F
RTD 2 CHANGE: -0.49 °F
RTD 3 CHANGE: -0.68 °F
RTD 4 CHANGE: -0.60 °F
RTD 5 CHANGE: -0.54 °F
WAT LEVEL CHANGE: -0.1913 "
WAT VOLUME CHANGE: -2.556 US GAL
COEFF 1: 0.1056
COEFF 2: 0.0609

TEST RESULT: PASSED
LEAK RATE: -0.06 GPH
VOLUME IS INCREASING
%%

LEAK TEST REPORT
TANK 3 DIESEL

TEST TYPE: CONTINUOUS, 0.2 GPH
THRESHOLD: 0.1
CONFIDENCE LEVEL: 99/1
LAST DELIVERY: 10-23-97 16:09
TEST START DATE: 10-19-98
TEST START TIME: 09:39
TEST LENGTH: 1.65 HOUR(S)
TANK CAPACITY: 10152 US GAL
% FULL VOLUME: 95
PROD LEVEL CHANGE: -0.0010 "
PROD GROSS CHANGE: -0.075 US GAL
PROD NET CHANGE: -0.031 US GAL
PROD TEMP CHANGE: -0.01 °F
RTD 1 CHANGE: -0.01 °F
RTD 2 CHANGE: -0.01 °F
RTD 3 CHANGE: -0.01 °F
RTD 4 CHANGE: -0.01 °F
RTD 5 CHANGE: -0.01 °F
WAT LEVEL CHANGE: -0.0002 "
WAT VOLUME CHANGE: -0.002 US GAL
COEFF 1: 0.0377
COEFF 2: 0.0085

TEST RESULT: PASSED
LEAK RATE: -0.03 GPH
VOLUME IS INCREASING
%%