1. File original in Complaint File
2. File copy in Vista Metals

California Regional Water Quality Control Board
Santa Ana Region

COMPLAINT AND SPILL REPORT FORM

SFUND RECORDS CTR
2389880

1. Person Reporting: Anonymous

Date: 7-12-83 Time: 4:00

2. Address: Phone No.

3. Regarding - Responsible Party (organization, address, phone, contact):
Vista Metals

4. Date of Occurrence: Ongoing Time:

5. Description (include material, volume, location, and predicted movement for spills): Periodic disch. of mineralized & acidic waste from cooling tower to unlined pit, from which it is pumped into scrap yard and adjacent rail yard. Waste flood-flows from pump outlet, and is acidic/odorous. H_2SO_4 is one of the acids in use.

6. Other Agencies Notified:

7. Report Taken By: WGA Mode of Report: (phone, letter, visit, etc.)

8. Referred To:

9. Findings of Investigation:
See 7/14/83 inspection report

10. Action Recommended: Routine monitoring

11. Action Taken: Inspection made. No further action at this time.

12. Results of Action:

13. Complainant Notified of Results By: N/A (name)

Date: N/A