SAMPLE_NAME	SAMPLE #	COLLECTDATE	TIME	RECEIVE_DATE	MEASUREDDATE	TIME
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	08-Feb-2017	11:30
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	07-Feb-2017	11:31
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	07-Feb-2017	11:31
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	07-Feb-2017	11:31
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	07-Feb-2017	11:31
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	08-Feb-2017	11:30
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	08-Feb-2017	11:30
Buikding 4455	AD41410	07-Feb-2017	11:31	02/08/2017	07-Feb-2017	11:31
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	22-Feb-2017	11:40
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	21-Feb-2017	12:39
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	21-Feb-2017	12:39
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	21-Feb-2017	12:39
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	21-Feb-2017	12:39
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	22-Feb-2017	11:40
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	22-Feb-2017	11:40
Building 4455	AD42777	21-Feb-2017	12:39	02/22/2017	21-Feb-2017	12:39
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	08-Feb-2017	11:30
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	07-Feb-2017	11:12
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	07-Feb-2017	11:12
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	07-Feb-2017	11:12
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	07-Feb-2017	11:12
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	08-Feb-2017	11:30
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	08-Feb-2017	11:30
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	07-Feb-2017	11:12
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	12:57
Building 4456	AD41411	07-Feb-2017	11:12	02/08/2017	09-Feb-2017	4:54
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	22-Feb-2017	11:40
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	21-Feb-2017	12:17
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	21-Feb-2017	12:17
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	21-Feb-2017	12:17
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	21-Feb-2017	12:17
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	22-Feb-2017	11:40
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	22-Feb-2017	11:40
Building 4456	AD42778	21-Feb-2017	12:17	02/22/2017	21-Feb-2017	12:17
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	08-Feb-2017	11:30
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	07-Feb-2017	10:49
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	07-Feb-2017	10:49
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	07-Feb-2017	10:49
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	07-Feb-2017	10:49
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	08-Feb-2017	11:30
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	08-Feb-2017	11:30
Building 50	AD41408	07-Feb-2017	10:49	02/08/2017	07-Feb-2017	10:49
Building 50	AD42775	21-Feb-2017	11:53	02/22/2017	22-Feb-2017	11:40
Building 50	AD42775	21-Feb-2017	11:53	02/22/2017	21-Feb-2017	11:53
Building 50	AD42775	21-Feb-2017	11:53	02/22/2017	21-Feb-2017	11:53
Building 50	AD42775	21-Feb-2017	11:53	02/22/2017	21-Feb-2017	11:53
Building 50	AD42775	21-Feb-2017	11:53	02/22/2017	21-Feb-2017	11:53
Building 50	AD42775	21-Feb-2017	11:53	02/22/2017	22-Feb-2017	11:40

Building 50	AD42775	21-Feb-2017 11:53	02/22/2017	22-Feb-2017 11:40
Building 50	AD42775	21-Feb-2017 11:53	02/22/2017	21-Feb-2017 11:53
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	08-Feb-2017 11:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	07-Feb-2017 10:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	07-Feb-2017 10:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	07-Feb-2017 10:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	07-Feb-2017 10:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	08-Feb-2017 11:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	08-Feb-2017 11:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	07-Feb-2017 10:30
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 12:32
Building 928	AD41409	07-Feb-2017 10:30	02/08/2017	09-Feb-2017 4:30
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	22-Feb-2017 11:40
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	21-Feb-2017 11:32
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	21-Feb-2017 11:32
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	21-Feb-2017 11:32
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	21-Feb-2017 11:32
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	22-Feb-2017 11:40
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	22-Feb-2017 11:40
Building 928	AD42776	21-Feb-2017 11:32	02/22/2017	21-Feb-2017 11:32
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	07-Feb-2017 11:57
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	07-Feb-2017 11:57
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	07-Feb-2017 11:57
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	07-Feb-2017 11:57
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	07-Feb-2017 11:57
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 13:48
Clinic Bldg 1300	AD41414	07-Feb-2017 11:57	02/08/2017	09-Feb-2017 5:42
Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13
Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13
Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13
Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13
Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13
Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13
Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13

Field Blank	AD41415	07-Feb-2017 9:27	02/08/2017	09-Feb-2017 14:13
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	07-Feb-2017 12:23
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	07-Feb-2017 12:23
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	07-Feb-2017 12:23
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	07-Feb-2017 12:23
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	07-Feb-2017 12:23
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 13:22
Honor Guard Bldg 47	AD41413	07-Feb-2017 12:23	02/08/2017	09-Feb-2017 5:18
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	08-Feb-2017 11:30
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	07-Feb-2017 13:11
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	07-Feb-2017 13:11
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	07-Feb-2017 13:11
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	07-Feb-2017 13:11
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	08-Feb-2017 11:30
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	08-Feb-2017 11:30
Moton Ct	AD41412	07-Feb-2017 13:11	02/08/2017	07-Feb-2017 13:11
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	22-Feb-2017 11:40
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	21-Feb-2017 13:05
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	21-Feb-2017 13:05
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	21-Feb-2017 13:05
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	21-Feb-2017 13:05
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	22-Feb-2017 11:40
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	22-Feb-2017 11:40
Moton Ct	AD42779	21-Feb-2017 13:05	02/22/2017	21-Feb-2017 13:05

PARAMETER	RESULT	UNIT	LOCATION	S	ANALYST
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Free Residual Chlorine	0.18	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.78	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	304	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	14.2	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	J.PENNELLA
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Total Residual Chlorine	3.2	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Free Residual Chlorine	0.18	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.92	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	357	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	14.7	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	B.HALL
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Total Residual Chlorine	1.93	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Bromoacetic Acid	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromochloroacetic Acid	3.56	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromodichloromethane	7.83	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromoform	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroacetic Acid	1.13	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroform	11.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromoacetic Acid	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromochloromethane	2.85	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dichloroacetic Acid	8.11	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Free Residual Chlorine	0.23	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Internal Standard	100	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Internal Standard	5.00	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
pH	7.78	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	305	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Surrogate	9.69	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate	4.55	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate1	4.76	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Temperature	13.3	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	J.PENNELLA
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Total Haloacetic Acids	18.45	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Total Residual Chlorine	3.1	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Total Trihalomethanes	21.7	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Trichloroacetic Acid	7.21	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Free Residual Chlorine	0.26	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.89	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	350	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	13.5	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	B.HALL
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Total Residual Chlorine	2.5	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Free Residual Chlorine	0.08	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.75	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	310	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	13.6	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	J.PENNELLA
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Total Residual Chlorine	1.87	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Free Residual Chlorine	0.28	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.84	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	344	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	14.6	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	B.HALL

Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Total Residual Chlorine	3.0	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Bromoacetic Acid	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromochloroacetic Acid	3.56	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromodichloromethane	8.05	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromoform	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroacetic Acid	1.03	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroform	11.4	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromoacetic Acid	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromochloromethane	2.70	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dichloroacetic Acid	8.21	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Free Residual Chlorine	0.14	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Internal Standard	100	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Internal Standard	5.00	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
pH	7.65	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	308	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Surrogate	9.83	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate	4.74	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate1	4.51	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Temperature	16.7	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	J.PENNELLA
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Total Haloacetic Acids	18.45	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Total Residual Chlorine	1.81	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Total Trihalomethanes	22.2	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Trichloroacetic Acid	7.21	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Free Residual Chlorine	0.10	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.84	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	358	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	16.4	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	B.HALL
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Total Residual Chlorine	1.83	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Bromoacetic Acid	6.91	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromochloroacetic Acid	3.43	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromodichloromethane	7.92	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromoform	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroacetic Acid	1.10	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroform	11.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromoacetic Acid	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromochloromethane	2.66	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dichloroacetic Acid	7.90	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Free Residual Chlorine	0.09	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Internal Standard	100	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Internal Standard	5.00	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
pH	7.78	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	305	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Surrogate	9.08	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate	4.76	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate1	4.40	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Temperature	11.6	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Total Haloacetic Acids	23.90	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Total Residual Chlorine	3.3	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Total Trihalomethanes	21.6	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Trichloroacetic Acid	6.99	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromodichloromethane	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromoform	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroform	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromochloromethane	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Internal Standard	5.00	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate	4.62	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate1	4.74	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR

Total Trihalomethanes	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromoacetic Acid	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromochloroacetic Acid	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromodichloromethane	9.39	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Bromoform	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroacetic Acid	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Chloroform	10.3	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromoacetic Acid	ND	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dibromochloromethane	4.70	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Dichloroacetic Acid	<1.0	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Free Residual Chlorine	0.01	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Internal Standard	100	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Internal Standard	5.00	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
pH	7.60	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	356	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Surrogate	9.71	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate	4.71	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Surrogate1	4.48	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Temperature	14.1	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Total Haloacetic Acids	2.11	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Total Residual Chlorine	0.10	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Total Trihalomethanes	25.4	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Trichloroacetic Acid	1.11	ug/L	Bioenviromental Engineering Element	C	M.INAMDAR
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Free Residual Chlorine	0.13	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.72	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	308	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	16.9	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	J.PENNELLA
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	J.PENNELLA
Total Residual Chlorine	2.6	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
Escherichia coli	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Free Residual Chlorine	0.05	mg/L	Bioenviromental Engineering Element	C	R.SIBERT
pH	7.94	unit	Bioenviromental Engineering Element	C	R.SIBERT
Specific Conductance	358	umhos/cm	Bioenviromental Engineering Element	C	R.SIBERT
Temperature	13.6	Degree C	Bioenviromental Engineering Element	C	R.SIBERT
Thiosulfate	P		Bioenviromental Engineering Element	C	B.HALL
Total Coliforms	A	/100 mL	Bioenviromental Engineering Element	C	B.HALL
Total Residual Chlorine	1.60	mg/L	Bioenviromental Engineering Element	C	R.SIBERT

METHOD
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE
SM 9223B,22nd ed
SM 4500-Cl G
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE
SM 9223B,22nd ed
SM 4500-Cl G
EPA 552.3 Rev 1.
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
SM 9223B,22nd ed
SM 4500-Cl G
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
SM 4500-H B
SM 2510B
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
SM 2550B
IODINE
SM 9223B,22nd ed
EPA 552.3 Rev 1.
SM 4500-Cl G
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE
SM 9223B,22nd ed
SM 4500-Cl G
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE
SM 9223B,22nd ed
SM 4500-Cl G
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE

SM 9223B,22nd ed
SM 4500-Cl G
EPA 552.3 Rev 1.
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
SM 9223B,22nd ed
SM 4500-Cl G
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
SM 4500-H B
SM 2510B
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
SM 2550B
IODINE
SM 9223B,22nd ed
EPA 552.3 Rev 1.
SM 4500-Cl G
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE
SM 9223B,22nd ed
SM 4500-Cl G
EPA 552.3 Rev 1.
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
SM 4500-Cl G
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
SM 4500-H B
SM 2510B
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
SM 2550B
EPA 552.3 Rev 1.
SM 4500-Cl G
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1

EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
SM 4500-Cl G
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
SM 4500-H B
SM 2510B
EPA 552.3 Rev 1.
EPA 524.2 Rev4.1
EPA 524.2 Rev4.1
SM 2550B
EPA 552.3 Rev 1.
SM 4500-Cl G
EPA 524.2 Rev4.1
EPA 552.3 Rev 1.
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE
SM 9223B,22nd ed
SM 4500-Cl G
SM 9223B,22nd ed
SM 4500-Cl G
SM 4500-H B
SM 2510B
SM 2550B
IODINE
SM 9223B,22nd ed
SM 4500-Cl G