DCP Operating Company, LP
3026 4th Avenue
Greeley, CO 80631

970-356-9700

Semi-Annual NSPS Subpart OOOOa Report

Mewbourn
2nd Half
2018

Semi-annual Report
NSPS OOOOa

Date Range
7/1/2018 to 12/31/2018

Site: DCP Operating Company, L.P. - Mewbourn II

Unit: CONDENSATE PIPELINE

Reference #	Compressor	July	August	September	October	November	December
	All						
.	Monitor Count	0	0	0	0	0	0
60.487a.c.2.v	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.vi	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0 , 0	0 , 0	0 , 0	0 , 0	0 , 0	0 , 0
Reference #	**Connector**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	0	0	40	0	0	4
60.487a.c.2.vii	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.viii	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Press Relief Device**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	0	0	0	0	0	0
60.487a.c.2.iii	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.iv	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Pump**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	0	0	0	0	0	0
60.487a.c.2.iii	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.iv	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Valve**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	0	0	18	0	0	19
60.487a.c.2.i	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.ii	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0

Monitor Count = total monitored

Leak Count = number of leaks found

Not Repaired = items not repaired in 15 days of initial leak (includes leaking dor in some instances)

Repair Delay Previous = items on repair delay before the current period, based on initial leak date

Repair Delay New = items put on repair delay during the current period only, based on initial leak date

Leak Percent = Leak count/Monitor Count (includes leaking dor in some instances)

Semi-annual Report
NSPS OOOOa

Date Range
7/1/2018 to 12/31/2018

Site: **DCP Operating Company, L.P. - Mewbourn II**

Unit: **NORTH INLET**

Reference #	Compressor	July	August	September	October	November	December
	All						
.	Monitor Count	0	0	0	0	0	0
60.487a.c.2.v	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.vi	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0 , 0	0 , 0	0 , 0	0 , 0	0 , 0	0 , 0
Reference #	**Connector**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	1	122	63	2	644	2
60.487a.c.2.vii	Leak Count	1	1	2	2	4	2
.	Leak Percent	100.00%	0.82%	3.17%	100.00%	0.62%	100.00%
60.487a.c.2.viii	Not Repaired in 15 Days	0	0	1	0	0	0
.	Repair Delay New, Previous	0,1	0,1	1,1	0,2	0,2	0,2
Reference #	**Press Relief Device**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	0	0	11	0	1	11
60.487a.c.2.iii	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.iv	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Pump**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	8	8	8	8	8	8
60.487a.c.2.iii	Leak Count	0	0	0	0	2	1
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	25.00%	12.50%
60.487a.c.2.iv	Not Repaired in 15 Days	0	0	0	0	1	1
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Valve**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	6	8	492	10	21	491
60.487a.c.2.i	Leak Count	2	3	9	5	4	5
.	Leak Percent	33.33%	37.50%	1.83%	50.00%	19.05%	1.02%
60.487a.c.2.ii	Not Repaired in 15 Days	1	0	3	2	2	1
	Repair Delay New, Previous	0,3	0,2	1,2	0,3	0,3	0,3

Monitor Count = total monitored

Leak Count = number of leaks found

Not Repaired = leaks not repaired in 15 days of initial leak (includes leaking for in some instances)

Repair Delay Previous = leaks in repair delay before the current period. Based on initial leak date

Repair Delay New = leaks put on repair delay during the current period only. Based on initial leak date

Leak Percent = Leak Count/Monitor Count (includes leaking for in some instances)

Semi-annual Report
NSPS OOOOa

Date Range
7/1/2018 to 12/31/2018

Site: **DCP Operating Company, L.P. - Mewbourn II**

Unit: **TANK FARM**

Reference #	Compressor	July	August	September	October	November	December
	All						
.	Monitor Count	0	0	0	0	0	0
60.487a.c.2.v	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.vi	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0 , 0	0 , 0	0 , 0	0 , 0	0 , 0	0 , 0
Reference #	**Connector**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	0	332	0	3	208	0
60.487a.c.2.vii	Leak Count	0	5	0	0	0	0
.	Leak Percent	0.00%	1.51%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.viii	Not Repaired in 15 Days	0	2	0	0	0	0
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Press Relief Device**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	0	1	9	1	5	8
60.487a.c.2.iii	Leak Count	0	0	0	1	0	3
.	Leak Percent	0.00%	0.00%	0.00%	100.00%	0.00%	37.50%
60.487a.c.2.iv	Not Repaired in 15 Days	0	0	0	1	0	1
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Pump**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	9	11	12	12	12	12
60.487a.c.2.iii	Leak Count	0	0	0	0	0	0
.	Leak Percent	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
60.487a.c.2.iv	Not Repaired in 15 Days	0	0	0	0	0	0
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	0,0
Reference #	**Valve**	**July**	**August**	**September**	**October**	**November**	**December**
	All						
.	Monitor Count	1	132	868	106	68	920
60.487a.c.2.i	Leak Count	0	0	7	0	0	6
.	Leak Percent	0.00%	0.00%	0.81%	0.00%	0.00%	0.65%
60.487a.c.2.ii	Not Repaired in 15 Days	0	0	0	0	0	1
.	Repair Delay New, Previous	0,0	0,0	0,0	0,0	0,0	1,0

Monitor Count = total monitored

Leak Count = number of leaks found

Not Repaired = Items not repaired in 15 days of initial leak (includes leaking out in some instances)

Repair Delay Previous = Items on repair delay before the current period, based on initial leak date

Repair Delay New = Items put on repair delay during the current period only, based on initial leak date

Leak Percent = Leak count/Monitor Count (includes leaking out in some instances)

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
AMINE/GLYCOL	JULY 2018	COM-Q	2	0	0	0	0	0	0	0		0		0	0	Start:	0
		CON-A	1916	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-Q	21	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	3	0	0	0	0	0	0	0		0		0	0	Total:	0
		PMP-M	3	0	0	0	0	0	0	0		0		0	3		
		VLV-Q	605	0	0	0	0	0	0	0		0		0	6		
		VLV-A	38	0	0	0	0	0	0	0		0		0	0		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CONDENDATE PIPELINE	JULY 2018	CON-A	44	0	0	0	0	0	0	0		0		0	0	Start:	0
		VLV-Q	19	0	0	0	0	0	0	0		0		0	0	Add:	0
		VLV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
																Total:	0

Additional Comments: (Tag lists, DOR details, etc.)

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CRYO	JULY 2018	CON-A	1453	0	0	0	0	0	0	0		0		0	0	Start:	2
		PRV-Q	5	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	11	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	8	0	0	0	0	0	0	0		0		1	8	Total:	2
		VLV-Q	439	0	0	0	0	0	0	0		0		1	9		
		VLV-A	33	0	0	0	0	0	0	0		0		0	0		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
DEHY	JULY 2018	COM-A	1	0	0	0	0	0	0	0		0		0	0	Start:	3
		CON-A	1727	0	0	0	0	0	0	0		0		2	2	Add:	0
		PRV-Q	8	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	1	0	0	0	0	0	0	0		0		0	0	Total:	3
		PMP-M	1	0	0	0	0	0	0	0		0		0	1		
		VLV-Q	243	0	0	0	0	0	0	0		0		1	7		
		VLV-A	15	0	0	0	0	0	0	0		0		0	1		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
INLET TURBINE	JULY 2018	COM-A	4	0	0	0	0	0	0	0		0		0	0	Start:	0
		CON-A	3724	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-Q	6	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	12	0	0	0	0	0	0	0		0		0	0	Total:	0
		PMP-M	2	0	0	0	0	0	0	0		0		0	2		
		VLV-Q	835	0	0	0	0	0	0	0		0		0	2		
		VLV-A	65	0	0	0	0	0	0	0		0		0	0		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NGL	JULY 2018	CON-A	2947	0	0	0	0	0	0	0		0		2	2	Start:	2
		PRV-Q	5	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	37	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	7	0	0	0	0	0	1	0		0		0	6	Total:	2
		PMP-A	1	0	0	0	0	0	0	0		0		0	0		
		VLV-Q	781	0	0	0	0	0	0	0		0		0	14		
		VLV-A	50	0	0	0	0	0	0	0		0		0	1		

Additional Comments: (Tag lists, DOR details, etc.)

1 monthly pump was TOS

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NORTH INLET	JULY 2018	CON-A	1161	0	0	0	0	0	0	0		0		1	1	Start:	4
		PRV-Q	11	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	1
		PMP-M	8	0	0	0	0	0	0	0		0		0	8	Total:	3
		VLV-Q	491	0	0	0	0	0	0	0		0		2	6		
		VLV-A	25	0	0	0	0	0	0	0		0		0	0		

Additional Comments: (Tag lists, DOR details, etc.)

1 quarterly valve was repaired and removed from the DOR list: 4333

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
PROPANE	JULY 2018	COM-A	2	0	0	0	0	0	0	0		0		0	0	Start:	0
		CON-A	5356	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-Q	10	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	5	0	0	0	0	0	0	0		0		0	0	Total:	0
		PMP-M	2	0	0	0	0	0	0	0		0		0	2		
		VLV-Q	464	0	0	0	0	0	0	0		0		0	1		
		VLV-A	35	0	0	0	0	0	0	0		0		0	0		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn Facility	Date:	10/9/2018
Month/Semi Period:	2018-JULY	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
TANK FARM	JULY 2018	CON-A	2466	0	0	0	0	0	0	0		0		0	0	Start:	0
		PRV-Q	7	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	37	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	10	0	0	0	0	0	1	0		0		0	9	Total:	0
		VLV-Q	707	0	0	0	0	0	0	0		0		0	1		
		VLV-A	73	0	0	0	0	0	0	0		0		0	0		

Additional Comments: (Tag lists, DOR details, etc.)

1 monthly pump was TOS

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
AMINE/GLYCOL	AUGUST 2018	COM-Q	2	0	0	0	0	0	0	0		0		0	0	Start:	0
		CON-A	1916	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-Q	21	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	3	0	0	0	0	0	0	0		0		0	0	Total:	0
		PMP-M	3	0	0	0	0	0	1	0		0		0	2		
		VLV-Q	605	0	0	0	0	0	0	0		0		0	7		
		VLV-A	38	0	0	0	0	0	0	0		0		0	0		

Additional Comments: (Tag lists, DOR details, etc.)

1 monthly pump was TOS

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CONDENDATE PIPELINE	AUGUST 2018	CON-A	44	0	0	0	0	0	0	0		0		0	0	Start:	0
		VLV-Q	19	0	0	0	0	0	0	0		0		0	0	Add:	0
		VLV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
																Total:	0

Additional Comments: (Tag lists, DOR details, etc.)

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CRYO	AUGUST 2018	CON-A	1453	0	0	0	0	0	0	0		0		0	0	Start:	2
		PRV-Q	5	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	11	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	8	0	0	0	0	0	0	0		0		1	8	Total:	2
		VLV-Q	439	0	0	0	0	0	0	0		0		1	17		
		VLV-A	33	0	0	0	0	0	0	0		0		0	0		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
DEHY	AUGUST 2018	COM-A	1	0	0	0	0	0	0	0		0		0	0	Start:	3
		CON-A	1727	0	0	0	0	0	0	0		0		2	2	Add:	0
		PRV-Q	8	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	1	0	0	0	0	0	0	0		0		0	0	Total:	3
		PMP-M	1	0	0	0	0	0	0	0		0		0	1		
		VLV-Q	243	0	0	0	0	0	0	0		0		1	10		
		VLV-A	15	0	0	0	0	0	0	0		0		0	1		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
INLET TURBINE	AUGUST 2018	COM-A	4	0	0	0	0	0	0	0		0		0	0	Start:	0
		CON-A	3724	0	0	0	0	0	0	0		0		0	230	Add:	0
		PRV-Q	6	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	12	0	0	0	0	0	0	0		0		0	0	Total:	0
		PMP-M	2	0	0	0	0	0	0	0		0		0	2		
		VLV-Q	835	0	0	0	0	0	0	0		0		0	6		
		VLV-A	65	0	0	0	0	0	0	0		0		0	1		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NGL	AUGUST 2018	CON-A	2947	477	0	0	0	203	0	0		0		3	468	Start:	2
		PRV-Q	5	0	0	0	0	0	0	0		0		0	5	Add:	1
		PRV-A	37	5	0	0	0	2	0	0		0		0	0	Repair:	0
		PMP-M	7	0	0	0	0	1	0	0		0		0	6	Total:	3
		PMP-A	1	1	0	0	0	0	0	0		0		0	1		
		VLV-Q	781	16	0	0	0	48	0	0		0		0	35		
		VLV-A	50	75	0	0	0	3	1	0		0		0	75		

Additional Comments: (Tag lists, DOR details, etc.)

477 annual connectors were added into service
203 annual connectors were permanently removed from service
5 annual pressure relief valves were added into service
2 annual pressure relief valves were permanently removed from service
1 monthly pump was permanently removed from service
1 annual pump was added into service
16 quarterly valves were added into service
48 quarterly valves were permanently removed from service
75 annual valves were added into service
3 annual valves were permanently removed from service
1 annual valve was TOS
1 annual connector was added to the DOR list: 7387-003

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NORTH INLET	AUGUST 2018	CON-A	1161	0	0	0	0	0	0	0		0		1	122	Start:	3
		PRV-Q	11	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	8	0	0	0	0	0	0	0		0		0	8	Total:	3
		VLV-Q	491	0	0	0	0	0	0	0		0		2	6		
		VLV-A	25	0	0	0	0	0	0	0		0		0	2		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
PROPANE	AUGUST 2018	COM-A	2	0	0	0	0	0	0	0		0		0	0	Start:	0
		CON-A	5356	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-Q	10	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PRV-A	5	0	0	0	0	0	0	0		0		0	0	Total:	0
		PMP-M	2	0	0	0	0	0	0	0		0		0	2		
		VLV-Q	464	0	0	0	0	0	0	0		0		0	6		
		VLV-A	35	0	0	0	0	0	0	0		0		0	0		

Additional Comments: (Tag lists, DOR details, etc.)

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	11/26/2018
Month/Semi Period:	2018-AUGUST	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
TANK FARM	AUGUST 2018	CON-A	2466	543	0	0	0	3	0	0		0		0	332	Start:	0
		PRV-Q	7	1	0	0	0	0	0	0		0		0	1	Add:	0
		PRV-A	37	6	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	10	2	0	0	0	0	1	0		0		0	11	Total:	0
		VLV-Q	717	207	0	0	0	0	94	0		0		0	117		
		VLV-A	63	19	0	0	0	0	4	0		0		0	15		

Additional Comments: (Tag lists, DOR details, etc.)

543 annual connectors were added into service
3 annual connectors were permanently removed from service
1 quarterly pressure relief valve was added into service
6 annual pressure relief valves were added into service
2 monthly pumps were added into service
207 quarterly valves were added into service
19 annual valves were added into service
1 monthly pump was TOS
94 quarterly valves were TOS
4 annual valves were TOS
10 annual valves changed monitoring frequency to quarterly

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-SEPTEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CONDENDATE PIPELINE	SEPTEMBER 2018	CON-A	44	0	0	0	0	0	0	0		0		0	40	Start:	0
		VLV-Q	19	0	0	0	0	0	2	0		0		0	17	Add:	0
		VLV-A	1	0	0	0	0	0	0	0		0		0	1	Repair:	0
																Total:	0

Additional Comments: (Tag lists, DOR details, etc.)

2 quarterly valves were TOS

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-SEPTEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NORTH INLET	SEPTEMBER 2018	CON-A	1161	2	0	0	0	0	0	0		0		2	63	Start:	3
		PRV-Q	11	0	0	0	0	0	0	0		0		0	11	Add:	2
		PRV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	8	0	0	0	0	0	0	0		0		0	8	Total:	5
		VLV-Q	491	0	0	0	0	0	0	0		0		3	491		
		VLV-A	25	0	0	0	0	0	0	0		0		0	1		

Additional Comments: (Tag lists, DOR details, etc.)

2 annual connectors were added into service
2 quarterly valves were not repaired within 15 days; site is aware and accepts deviations: 4245, 7439
1 annual connector was added to the DOR list: 4456
1 quarterly valve was added to the DOR list: 4672

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-SEPTEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
TANK FARM	SEPTEMBER 2018	CON-A	3006	0	0	0	0	0	0	0		0		0	0	Start:	0
		PRV-Q	8	0	0	0	0	0	0	0		0		0	8	Add:	0
		PRV-A	43	1	0	0	0	0	0	0		0		0	1	Repair:	0
		PMP-M	12	0	0	0	0	0	0	0		0		0	12	Total:	0
		VLV-Q	924	0	0	0	0	0	62	0		0		0	851		
		VLV-A	82	0	0	0	0	0	2	0		0		0	17		

Additional Comments: (Tag lists, DOR details, etc.)

1 annual pressure relief valve was added into service
73 quarterly valves have already been inspected this quarter

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-OCTOBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CONDENDATE PIPELINE	OCTOBER 2018	CON-A	44	0	0	0	0	0	0	0		0		0	0	Start:	0
		VLV-Q	19	0	0	0	0	0	0	0		0		0	0	Add:	0
		VLV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
																Total:	0
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-OCTOBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NORTH INLET	OCTOBER 2018	CON-A	1163	0	0	0	0	0	0	0		0		2	2	Start:	5
		PRV-Q	11	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	8	0	0	0	0	0	0	0		0		0	8	Total:	5
		VLV-Q	491	0	0	0	0	0	0	0		0		3	10		
		VLV-A	25	0	0	0	0	0	0	0		0		0	0		

Additional Comments: (Tag lists, DOR details, etc.)

2 quarterly valves were not repaired within 15 days; site is aware and accepts deviations: 4245, 7439

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-OCTOBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
TANK FARM	OCTOBER 2018	CON-A	3006	0	0	0	0	0	0	0		0		0	3	Start:	0
		PRV-Q	8	0	0	0	0	0	0	0		0		0	1	Add:	0
		PRV-A	44	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	12	0	0	0	0	0	0	0		0		0	12	Total:	0
		VLV-Q	924	0	0	0	0	0	0	0		0		0	102		
		VLV-A	82	0	0	0	0	0	0	0		0		0	4		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-NOVEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CONDENDATE PIPELINE	NOVEMBER 2018	CON-A	44	0	0	0	0	0	0	0		0		0	0	Start:	0
		VLV-Q	19	0	0	0	0	0	0	0		0		0	0	Add:	0
		VLV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
																Total:	0
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-NOVEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NORTH INLET	NOVEMBER 2018	CON-A	1163	0	0	0	0	0	0	0		0		2	644	Start:	5
		PRV-Q	11	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	1	0	0	0	0	0	0	0		0		0	1	Repair:	0
		PMP-M	8	0	0	0	0	0	0	0		0		0	8	Total:	5
		VLV-Q	491	0	0	0	0	0	0	0		0		3	9		
		VLV-A	25	0	0	0	0	0	0	0		0		0	12		

Additional Comments: (Tag lists, DOR details, etc.)

2 quarterly valves were not repaired within 15 days; site is aware and accepts deviations: 4245, 7439
1 monthly pump was not repaired within 15 days; site is aware and accepts deviation: 4237

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-NOVEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
TANK FARM	NOVEMBER 2018	CON-A	3006	0	0	0	0	0	0	0		0		0	208	Start:	0
		PRV-Q	8	0	0	0	0	0	0	0		0		0	0	Add:	0
		PRV-A	44	0	0	0	0	0	0	0		0		0	5	Repair:	0
		PMP-M	12	0	0	0	0	0	0	0		0		0	12	Total:	0
		VLV-Q	924	0	0	0	0	0	0	0		0		0	66		
		VLV-A	82	0	0	0	0	0	0	0		0		0	2		
		Additional Comments: (Tag lists, DOR details, etc.)															

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-DECEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
CONDENDATE PIPELINE	DECEMBER 2018	CON-A	44	0	0	0	0	0	0	0		0		0	4	Start:	0
		VLV-Q	19	0	0	0	0	0	0	0		0		0	19	Add:	0
		VLV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	0
																Total:	0

Additional Comments: (Tag lists, DOR details, etc.)

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-DECEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
NORTH INLET	DECEMBER 2018	CON-A	1163	0	0	0	0	0	0	0		0		2	2	Start:	5
		PRV-Q	11	0	0	0	0	0	0	0		0		0	11	Add:	0
		PRV-A	1	0	0	0	0	0	0	0		0		0	0	Repair:	1
		PMP-M	8	0	0	0	0	0	0	0		0		0	8	Total:	4
		VLV-Q	491	0	0	0	0	0	0	0		0		2	491		
		VLV-A	25	0	0	0	0	0	0	0		0		0	0		

Additional Comments: (Tag lists, DOR details, etc.)

1 quarterly valve was not repaired within 15 days; site is aware and accepts deviation: 4245
1 monthly pump was not repaired within 15 days; site is aware and accepts deviation: 4237
1 quarterly pressure relief valve was not repaired within 15 days; site is aware and accepts deviation: 4753A
1 quarterly valve was repaired and removed from the DOR list: 4672

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Program:	NSPS OOOOa	DCP Operating Company, L. P. – Mewbourn II Facility	Date:	1/21/2019
Month/Semi Period:	2018-DECEMBER	LDAR Program Comments Summary Report	Prepared by:	Stephanie Smith

Unit	Period:	Balance Comments:														DOR Balance:	
			Begin Total:	Add (Re-identified)	Add (month)	Add 1st mon	Add 2nd mon	Delete:	TOS:	PL (1st re-mon)	PL (1) Period	PL (2nd re-mon)	PL (2) Period	DOR:	Total Mon:	Turnaround Date: 00/00/0000	
TANK FARM	DECEMBER 2018	CON-A	3006	0	0	0	0	0	0	0		0		0	0	Start:	0
		PRV-Q	8	0	0	0	0	0	0	0		0		0	8	Add:	1
		PRV-A	44	0	0	0	0	0	0	0		0		0	0	Repair:	0
		PMP-M	12	0	0	0	0	0	0	0		0		0	12	Total:	1
		VLV-Q	924	0	0	0	0	4	0	0		0		1	920		
		VLV-A	82	0	0	0	0	0	0	0		0		0	0		

Additional Comments: (Tag lists, DOR details, etc.)

4 quarterly valves were permanently removed from service
1 quarterly valve was added to the DOR list: 5649

Abbreviation Key:
PL (1) or (2) = Previous Leaker
M = Monthly Component
Q = Quarterly Component
A = Annual Component
NR= Not Required Component

Component Count Changes

DCP Operating Company, L.P. - Mewbourn II

From: 7/1/2018, To: 12/31/2018, Rule: NSPS OOOOa

Unit: **CONDENSATE PIPELINE**

Component Type	Frequency	# of Beginning Tags	# of Tags Added	Total # of Tags	# of Tags Removed	# of Ending Tags
CONNECTOR	Annually	44	0	44	0	44
VALVE	Quarterly - 3rd Month	19	0	19	0	19
	Annually	1	0	1	0	1
	Total:	20	0	20	0	20
	Unit Total:	**64**	**0**	**64**	**0**	**64**

Unit: **NORTH INLET**

Component Type	Frequency	# of Beginning Tags	# of Tags Added	Total # of Tags	# of Tags Removed	# of Ending Tags
CONNECTOR	Annually	1161	2	1163	0	1163
		Sep 2018	2			
PRESS RELIEF DEVICE	Quarterly - 3rd Month	11	0	11	0	11
	Annually	1	0	1	0	1
	Total:	12	0	12	0	12
PUMP	Monthly	8	0	8	0	8
VALVE	Quarterly - 3rd Month	491	0	491	0	491
	Annually	25	0	25	0	25
	Total:	516	0	516	0	516
	Unit Total:	**1697**	**2**	**1699**	**0**	**1699**

Unit: **TANK FARM**

Component Type	Frequency	# of Beginning Tags	# of Tags Added	Total # of Tags	# of Tags Removed	# of Ending Tags
CONNECTOR	Annually	2466	543	3009	3	3006
		Aug 2018	543	Aug 2018	3	
PRESS RELIEF DEVICE	Quarterly - 3rd Month	7	1	8	0	8
		Aug 2018	1			
	Annually	37	7	44	0	44
		Aug 2018	6			
		Sep 2018	1			
	Total:	44	8	52	0	52
PUMP	Monthly	10	2	12	0	12
		Aug 2018	2			
VALVE	Quarterly - 3rd Month	717	207	924	4	920
		Aug 2018	207	Dec 2018	4	
	Annually	63	19	82	0	82
		Aug 2018	19			
	Total:	780	226	1006	4	1002
	Unit Total:	**3300**	**779**	**4079**	**7**	**4072**

Component Count Changes

DCP Operating Company, L.P. - Mewbourn II

From: 7/1/2018, To: 12/31/2018, Rule: NSPS OOOOa

Facility Total:	**5061**	**781**	**5842**	**7**	**5835**

This report was generated using a filter:

Rule Name is equal to NSPS OOOOa And
(Unit is equal to CONDENSATE PIPELINE Or
Unit is equal to NORTH INLET Or
Unit is equal to TANK FARM)

Permanently Out Of Service Components

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Subtype:	MOC:	Date Removed:	Reason Removed:
TANKFARM	SUB	SUB	5556-000	VALVE-UNCATEGORIZED	3079881	12/26/2018	PERMANENTLY REMOVED FROM SERVICE
TANKFARM	SUB	SUB	5558-000	VALVE-UNCATEGORIZED	3079891	12/26/2018	PERMANENTLY REMOVED FROM SERVICE
TANKFARM	SUB	SUB	5559-000	VALVE-UNCATEGORIZED	2463506	12/26/2018	PERMANENTLY REMOVED FROM SERVICE
TANKFARM	SUB	SUB	5561-000	VALVE-UNCATEGORIZED	3079900	12/26/2018	PERMANENTLY REMOVED FROM SERVICE
TANKFARM	SUB	SUB	5730-007	SCREWED FITTING	3080198	8/30/2018	PERMANENTLY REMOVED FROM SERVICE
TANKFARM	SUB	SUB	5737-007	SCREWED FITTING	3080198	8/30/2018	PERMANENTLY REMOVED FROM SERVICE
TANKFARM	SUB	SUB	5738-006	SCREWED FITTING	3080198	8/30/2018	PERMANENTLY REMOVED FROM SERVICE

Total Number of Removed Components: 7

This report was generated using a filter:

Rule Name is equal to NSPS OOOOa And
(Unit is equal to CONDENSATE PIPELINE Or
Unit is equal to NORTH INLET Or
Unit is equal to TANK FARM)

Printed By: scsmith

NDE Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **CONDENSATE PIPELINE** Area: **CONDENSATE PIPELINE**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
7695-000	VALVE	CHECK VALVE	9/20/2018 2:52:42 PM	L	500	17	6	JOSUE	3564	N	N

Unit: **NORTH INLET** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
4391-000	VALVE	REGULATOR VALVE	9/19/2018 2:46:24 PM	G	500	23	2	NATE	6239	N	N
4395-000	VALVE	CHECK VALVE	8/30/2018 3:28:25 PM	G	500	3	7	JOSUE	31426	N	N
4401-000	VALVE	CHECK VALVE	8/30/2018 3:36:55 PM	G	500	2	7	JOSUE	31426	N	N
4432-000	VALVE	CHECK VALVE	11/21/2018 8:53:47 AM	L	500	9	3	CARTER	27760	N	N
4436-000	VALVE	CHECK VALVE	11/21/2018 8:56:20 AM	L	500	24	3	CARTER	27760	N	N
4445-000	VALVE	CHECK VALVE	11/21/2018 9:01:47 AM	L	500	23	3	CARTER	27760	N	N
4452-000	VALVE	CHECK VALVE	11/21/2018 9:08:09 AM	L	500	10	3	CARTER	27760	N	N
4492-000	VALVE	CHECK VALVE	11/21/2018 9:37:58 AM	L	500	35	3	CARTER	27760	N	N
4499-000	VALVE	CHECK VALVE	11/21/2018 9:46:24 AM	L	500	15	3	CARTER	27760	N	N
4655-000	VALVE	CHECK VALVE	11/21/2018 1:34:36 PM	G	500	11	6	CARTER	27760	N	N
4658-000	VALVE	CHECK VALVE	11/21/2018 1:38:49 PM	G	500	12	6	CARTER	27760	N	N
7445-000	VALVE	CHECK VALVE	11/21/2018 10:40:35 AM	G	500	28	3	CARTER	27760	N	N

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5804-000	VALVE	CHECK VALVE	9/20/2018 3:41:54 PM	L	500	7	7	JOSUE	3564	N	N
5804-000	VALVE	CHECK VALVE	10/29/2018 11:53:55 AM	L	500	19	33	CARTER	27760	N	N
5850-000	VALVE	CHECK VALVE	10/29/2018 12:19:36 PM	L	500	6	33	CARTER	27760	N	N
5850-000	VALVE	CHECK VALVE	11/28/2018 10:10:49 AM	L	500	7	0	JOSUE	3564	N	N
5888-000	VALVE	CHECK VALVE	10/29/2018 12:15:35 PM	L	500	11	0	NATE	6239	N	N
5888-000	VALVE	CHECK VALVE	11/28/2018 10:23:32 AM	L	500	6	0	JOSUE	3564	N	N
5899-000	VALVE	CHECK VALVE	9/26/2018 8:02:00 AM	L	500	15	15	CARTER	27760	N	N
5899-000	VALVE	CHECK VALVE	10/29/2018 12:20:10 PM	L	500	12	0	NATE	6239	N	N

Printed By: scsmith

NDE Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

This report was generated using a filter:

Non-Detectable Emitter is true And
Rule Name is equal to NSPS OOOOa And
(Unit is equal to CONDENSATE PIPELINE Or
Unit is equal to NORTH INLET Or
Unit is equal to TANK FARM)

Monitor Frequency Counts

DCP Operating Company, L.P. - Mewbourn II

NSPS OOOOa as of 12/31/2018, Follow-Ups Combined

Unit: **CONDENSATE PIPELINE**

Component Type	Frequency	Heavy Liquid	Light Liquid	Gas/Vapor	Other	Total
CONNECTOR	Annually	0	40	4	0	44
VALVE	Quarterly - 3rd Month	0	17	2	0	19
	Annually	0	1	0	0	1
	Total:	0	18	2	0	20
	Unit Total:	**0**	**58**	**6**	**0**	**64**

Unit: **NORTH INLET**

Component Type	Frequency	Heavy Liquid	Light Liquid	Gas/Vapor	Other	Total
CONNECTOR	Annually	0	406	757	0	1163
PRESS RELIEF DEVICE	Quarterly - 3rd Month	0	0	11	0	11
	Annually	0	1	0	0	1
	Total:	0	1	11	0	12
PUMP	Monthly	0	8	0	0	8
VALVE	Quarterly - 3rd Month	0	144	347	0	491
	Annually	0	13	12	0	25
	Total:	0	157	359	0	516
	Unit Total:	**0**	**572**	**1127**	**0**	**1699**

Unit: **TANK FARM**

Component Type	Frequency	Heavy Liquid	Light Liquid	Gas/Vapor	Other	Total
CONNECTOR	Annually	0	2361	645	0	3006
PRESS RELIEF DEVICE	Quarterly - 3rd Month	0	0	8	0	8
	Annually	0	38	6	0	44
	Total:	0	38	14	0	52
PUMP	Monthly	0	12	0	0	12
VALVE	Quarterly - 3rd Month	0	726	194	0	920
	Annually	0	59	23	0	82
	Total:	0	785	217	0	1002
	Unit Total:	**0**	**3196**	**876**	**0**	**4072**
	Facility Total:	**0**	**3826**	**2009**	**0**	**5835**

This report was generated using a filter:

Rule Name is equal to NSPS OOOOa And
(Unit is equal to CONDENSATE PIPELINE Or
Unit is equal to NORTH INLET Or
Unit is equal to TANK FARM)

CVS Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
4806-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	9/24/2018 1:01:40 PM	G	500	12	2	(b) (6) [redacted]	46852	N	N
4806-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	12/12/2018 9:45:42 AM	G	500	6	1	[redacted]	3564	N	N
4806A-000	VALVE	VALVE-UNCATEGORIZED	9/27/2018 2:54:09 PM	G	500	6	4	[redacted]	3564	N	N
4806A-000	VALVE	VALVE-UNCATEGORIZED	12/12/2018 9:46:04 AM	G	500	5	1	[redacted]	3564	N	N
4806B-000	VALVE	VALVE-UNCATEGORIZED	9/27/2018 2:55:07 PM	G	500	6	4	[redacted]	3564	N	N
4806B-000	VALVE	VALVE-UNCATEGORIZED	12/12/2018 9:46:47 AM	G	500	6	1	[redacted]	3564	N	N
4874-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	9/24/2018 1:39:27 PM	G	500	44	2	[redacted]	46852	N	N
4874-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	12/12/2018 9:49:12 AM	G	500	6	1	[redacted]	3564	N	N
4874A-000	VALVE	VALVE-UNCATEGORIZED	9/24/2018 1:39:56 PM	G	500	16	2	[redacted]	46852	N	N
4874A-000	VALVE	VALVE-UNCATEGORIZED	12/11/2018 11:57:10 AM	G	500	7	7	[redacted]	3564	N	N
4874B-000	VALVE	VALVE-UNCATEGORIZED	9/24/2018 1:40:28 PM	G	500	10	2	[redacted]	46852	N	N
4874B-000	VALVE	VALVE-UNCATEGORIZED	12/11/2018 11:57:54 AM	G	500	7	7	[redacted]	3564	N	N
5377-000	VALVE	VALVE-UNCATEGORIZED	9/27/2018 2:58:41 PM	G	500	6	4	[redacted]	3564	N	N
5377-000	VALVE	VALVE-UNCATEGORIZED	12/12/2018 10:00:33 AM	G	500	5	1	[redacted]	3564	N	N
5377A-000	VALVE	VALVE	12/12/2018 10:00:59 AM	G	500	5	1	[redacted]	3564	N	N
5377B-000	VALVE	VALVE	12/12/2018 10:01:19 AM	G	500	6	1	[redacted]	3564	N	N
5384-000	VALVE	VALVE-UNCATEGORIZED	12/12/2018 9:55:10 AM	G	500	6	1	[redacted]	3564	N	N
5385-000	VALVE	VALVE-UNCATEGORIZED	12/12/2018 9:55:53 AM	G	500	5	1	[redacted]	3564	N	N
5386-000	VALVE	VALVE-UNCATEGORIZED	12/12/2018 9:56:26 AM	G	500	9	1	[redacted]	3564	N	N
5387-000	VALVE	VALVE-UNCATEGORIZED	9/27/2018 11:39:25 AM	G	500	14	6	[redacted]	3564	N	N
5387-000	VALVE	VALVE-UNCATEGORIZED	12/12/2018 9:56:59 AM	G	500	4	1	[redacted]	3564	N	N
5663-000	VALVE	VALVE	8/30/2018 9:23:51 AM	L	500	5	5	[redacted]	9034	Y	N
5663-000	VALVE	VALVE	9/26/2018 12:37:49 PM	L	500	16	15	[redacted]	27760	Y	N
5663-001	CONNECTOR	SCREWED FITTING	8/30/2018 9:24:13 AM	L	500	8	5	[redacted]	9034	Y	N
5663-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:24:38 AM	L	500	12	5	[redacted]	9034	Y	N
5663-003	CONNECTOR	UNION	8/30/2018 9:24:56 AM	L	500	8	5	[redacted]	9034	Y	N
5664-000	VALVE	VALVE	8/30/2018 9:25:19 AM	L	500	10	5	[redacted]	9034	Y	N
5664-000	VALVE	VALVE	9/26/2018 12:38:19 PM	L	500	16	15	[redacted]	27760	Y	N
5664-001	CONNECTOR	FLANGE	8/30/2018 9:25:48 AM	L	500	6	5	[redacted]	9034	Y	N
5664-002	CONNECTOR	FLANGE	8/30/2018 9:26:14 AM	L	500	5	5	[redacted]	9034	Y	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5665-000	VALVE	CHECK VALVE	8/30/2018 9:26:43 AM	L	500	6	5	(b) (6) [redacted]	9034	Y	N
5665-000	VALVE	CHECK VALVE	9/26/2018 12:38:41 PM	L	500	16	15	[redacted]	27760	Y	N
5665-001	CONNECTOR	FLANGE	8/30/2018 9:27:11 AM	L	500	5	5	[redacted]	9034	Y	N
5666-000	VALVE	VALVE	8/30/2018 9:27:48 AM	L	500	31	5	[redacted]	9034	Y	N
5666-000	VALVE	VALVE	9/26/2018 12:39:20 PM	L	500	16	15	[redacted]	27760	Y	N
5666-001	CONNECTOR	SCREWED FITTING	8/30/2018 9:28:05 AM	L	500	31	5	[redacted]	9034	Y	N
5666-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:28:23 AM	L	500	116	5	[redacted]	9034	Y	N
5666-003	CONNECTOR	PLUG	8/30/2018 9:28:48 AM	L	500	82400	5	[redacted]	9034	Y	N
5666-003	CONNECTOR	PLUG	10/30/2018 11:44:22 AM	L	500	6	6	[redacted]	6239	Y	N
5667-000	VALVE	VALVE	8/30/2018 9:41:36 AM	L	500	7	5	[redacted]	9034	Y	N
5667-000	VALVE	VALVE	9/26/2018 12:40:29 PM	L	500	16	15	[redacted]	27760	Y	N
5667-001	CONNECTOR	SCREWED FITTING	8/30/2018 9:41:54 AM	L	500	8	5	[redacted]	9034	Y	N
5667-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:42:12 AM	L	500	9	5	[redacted]	9034	Y	N
5667-003	CONNECTOR	UNION	8/30/2018 9:42:28 AM	L	500	17	5	[redacted]	9034	Y	N
5668-000	VALVE	VALVE	8/30/2018 9:43:03 AM	L	500	6	5	[redacted]	9034	Y	N
5668-000	VALVE	VALVE	9/26/2018 12:41:28 PM	L	500	16	15	[redacted]	27760	Y	N
5668-001	CONNECTOR	SCREWED FITTING	8/30/2018 9:43:21 AM	L	500	6	5	[redacted]	9034	Y	N
5668-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:43:42 AM	L	500	6	5	[redacted]	9034	Y	N
5668-003	CONNECTOR	SCREWED FITTING	8/30/2018 9:44:03 AM	L	500	6	5	[redacted]	9034	Y	N
5669-000	VALVE	VALVE	8/30/2018 9:44:25 AM	L	500	6	5	[redacted]	9034	Y	N
5669-000	VALVE	VALVE	9/26/2018 12:41:45 PM	L	500	16	15	[redacted]	27760	Y	N
5669-001	CONNECTOR	FLANGE	8/30/2018 9:44:45 AM	L	500	6	5	[redacted]	9034	Y	N
5669-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:45:05 AM	L	500	8	5	[redacted]	9034	Y	N
5669-003	CONNECTOR	SCREWED FITTING	8/30/2018 9:45:34 AM	L	500	8	5	[redacted]	9034	Y	N
5669-004	CONNECTOR	SCREWED FITTING	8/30/2018 9:45:55 AM	L	500	8	5	[redacted]	9034	Y	N
5669-005	CONNECTOR	TUBING FITTING	8/30/2018 9:46:20 AM	L	500	8	5	[redacted]	9034	Y	N
5670-000	VALVE	VALVE	8/30/2018 9:46:44 AM	L	500	6	5	[redacted]	9034	Y	N
5670-000	VALVE	VALVE	9/26/2018 12:42:08 PM	L	500	16	15	[redacted]	27760	Y	N
5670-001	CONNECTOR	SCREWED FITTING	8/30/2018 9:47:01 AM	L	500	6	5	[redacted]	9034	Y	N
5670-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:47:19 AM	L	500	6	5	[redacted]	9034	Y	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5670-003	CONNECTOR	SCREWED FITTING	8/30/2018 9:47:35 AM	L	500	6	5	(b) (6) [redacted]	9034	Y	N
5670-004	CONNECTOR	TUBING FITTING	8/30/2018 9:47:55 AM	L	500	6	5	[redacted]	9034	Y	N
5671-000	VALVE	INSTRUMENT VALVE	8/30/2018 9:48:16 AM	L	500	7	5	[redacted]	9034	Y	N
5671-000	VALVE	INSTRUMENT VALVE	9/26/2018 12:42:39 PM	L	500	16	15	[redacted]	27760	Y	N
5671-001	CONNECTOR	PLUG	8/30/2018 9:48:32 AM	L	500	7	5	[redacted]	9034	Y	N
5671-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:48:52 AM	L	500	6	5	[redacted]	9034	Y	N
5671-003	CONNECTOR	TUBING FITTING	8/30/2018 9:49:13 AM	L	500	6	5	[redacted]	9034	Y	N
5672-000	VALVE	INSTRUMENT VALVE	8/30/2018 9:49:36 AM	L	500	5	5	[redacted]	9034	Y	N
5672-000	VALVE	INSTRUMENT VALVE	9/26/2018 12:43:22 PM	L	500	21	15	[redacted]	27760	Y	N
5673-000	VALVE	INSTRUMENT VALVE	8/30/2018 9:49:57 AM	L	500	5	5	[redacted]	9034	Y	N
5673-000	VALVE	INSTRUMENT VALVE	9/26/2018 12:43:42 PM	L	500	21	15	[redacted]	27760	Y	N
5673-001	CONNECTOR	PLUG	8/30/2018 9:50:14 AM	L	500	5	5	[redacted]	9034	Y	N
5673-002	CONNECTOR	SCREWED FITTING	8/30/2018 9:50:49 AM	L	500	10	5	[redacted]	9034	Y	N
5673-003	CONNECTOR	TUBING FITTING	8/30/2018 9:51:18 AM	L	500	6	5	[redacted]	9034	Y	N
5674-000	VALVE	VALVE	8/30/2018 9:51:56 AM	L	500	6	5	[redacted]	9034	Y	N
5674-000	VALVE	VALVE	9/26/2018 12:44:13 PM	L	500	16	15	[redacted]	27760	Y	N
5674-001	CONNECTOR	FLANGE	8/30/2018 9:52:21 AM	L	500	6	5	[redacted]	9034	Y	N
5674-002	CONNECTOR	FLANGE	8/30/2018 9:52:46 AM	L	500	6	5	[redacted]	9034	Y	N
5674-003	CONNECTOR	FLANGE	8/30/2018 9:53:03 AM	L	500	8	5	[redacted]	9034	Y	N
5675-000	VALVE	CHECK VALVE	8/30/2018 9:53:26 AM	L	500	7	5	[redacted]	9034	Y	N
5675-000	VALVE	CHECK VALVE	9/26/2018 12:44:35 PM	L	500	16	15	[redacted]	27760	Y	N
5675-001	CONNECTOR	FLANGE	8/30/2018 9:53:47 AM	L	500	6	5	[redacted]	9034	Y	N
5676-000	VALVE	VALVE	8/30/2018 9:54:26 AM	L	500	5	5	[redacted]	9034	Y	N
5676-000	VALVE	VALVE	9/26/2018 12:45:47 PM	L	500	16	15	[redacted]	27760	Y	N
5676-001	CONNECTOR	FLANGE	8/30/2018 9:54:48 AM	L	500	5	5	[redacted]	9034	Y	N
5676-002	CONNECTOR	FLANGE	8/30/2018 9:55:11 AM	L	500	7	5	[redacted]	9034	Y	N
5676-003	CONNECTOR	FLANGE	8/30/2018 9:55:42 AM	L	500	5	5	[redacted]	9034	Y	N
5677-000	VALVE	VALVE	8/30/2018 9:56:05 AM	L	500	5	5	[redacted]	9034	Y	N
5677-000	VALVE	VALVE	9/26/2018 12:46:10 PM	L	500	16	15	[redacted]	27760	Y	N
5677-001	CONNECTOR	FLANGE	8/30/2018 9:56:31 AM	L	500	5	5	[redacted]	9034	Y	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5677-002	CONNECTOR	FLANGE	8/30/2018 9:56:59 AM	L	500	6	5	(b) (6) [redacted]	9034	Y	N
5678-000	CONNECTOR	MANWAY	8/30/2018 9:58:28 AM	L	500	6	5	[redacted]	9034	N	N
5679-000	VALVE	VALVE	8/30/2018 9:58:59 AM	L	500	5	5	[redacted]	9034	N	N
5679-000	VALVE	VALVE	9/26/2018 12:50:22 PM	L	500	18	15	[redacted]	27760	N	N
5679-000	VALVE	VALVE	12/10/2018 3:40:07 PM	L	500	28	11	[redacted]	3564	N	N
5679-001	CONNECTOR	FLANGE	8/30/2018 9:59:26 AM	L	500	5	5	[redacted]	9034	N	N
5679-002	CONNECTOR	FLANGE	8/30/2018 9:59:47 AM	L	500	5	5	[redacted]	9034	N	N
5680-000	VALVE	VALVE	8/30/2018 10:00:05 AM	L	500	5	5	[redacted]	9034	N	N
5680-000	VALVE	VALVE	9/26/2018 12:51:06 PM	L	500	20	15	[redacted]	27760	N	N
5680-000	VALVE	VALVE	12/10/2018 3:40:26 PM	L	500	26	11	[redacted]	3564	N	N
5680-001	CONNECTOR	SCREWED FITTING	8/30/2018 10:00:24 AM	L	500	13	5	[redacted]	9034	N	N
5680-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:01:56 AM	L	500	5	5	[redacted]	9034	N	N
5681-000	VALVE	VALVE	8/30/2018 10:02:17 AM	L	500	5	5	[redacted]	9034	N	N
5681-000	VALVE	VALVE	9/26/2018 12:51:25 PM	L	500	20	15	[redacted]	27760	N	N
5681-000	VALVE	VALVE	12/10/2018 3:40:47 PM	L	500	32	11	[redacted]	3564	N	N
5681-001	CONNECTOR	PLUG	8/30/2018 10:02:33 AM	L	500	18	5	[redacted]	9034	N	N
5682-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	8/30/2018 10:03:03 AM	L	500	7	5	[redacted]	9034	N	N
5682-001	CONNECTOR	SCREWED FITTING	8/30/2018 10:03:19 AM	L	500	5	5	[redacted]	9034	N	N
5683-000	VALVE	VALVE	8/30/2018 10:03:36 AM	L	500	5	5	[redacted]	9034	N	N
5683-000	VALVE	VALVE	9/26/2018 12:51:42 PM	L	500	22	15	[redacted]	27760	N	N
5683-000	VALVE	VALVE	12/10/2018 3:41:08 PM	L	500	29	11	[redacted]	3564	N	N
5683-001	CONNECTOR	PLUG	8/30/2018 10:03:53 AM	L	500	6	5	[redacted]	9034	N	N
5683-002	CONNECTOR	PLUG	8/30/2018 10:04:10 AM	L	500	6	5	[redacted]	9034	N	N
5684-000	VALVE	CONTROL VALVE	8/30/2018 10:04:43 AM	L	500	6	5	[redacted]	9034	N	N
5684-000	VALVE	CONTROL VALVE	9/26/2018 12:52:11 PM	L	500	24	15	[redacted]	27760	N	N
5684-000	VALVE	CONTROL VALVE	12/10/2018 3:41:48 PM	L	500	33	11	[redacted]	3564	N	N
5684-001	CONNECTOR	FLANGE	8/30/2018 10:05:06 AM	L	500	5	5	[redacted]	9034	N	N
5684-002	CONNECTOR	FLANGE	8/30/2018 10:05:27 AM	L	500	5	5	[redacted]	9034	N	N
5685-000	VALVE	CONTROL VALVE	8/30/2018 10:07:20 AM	L	500	5	5	[redacted]	9034	N	N
5685-000	VALVE	CONTROL VALVE	9/26/2018 12:52:45 PM	L	500	21	15	[redacted]	27760	N	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5685-000	VALVE	CONTROL VALVE	12/10/2018 3:42:30 PM	L	500	30	11	(b) (6) [redacted]	3564	N	N
5685-001	CONNECTOR	FLANGE	8/30/2018 10:07:42 AM	L	500	5	5	[redacted]	9034	N	N
5685-002	CONNECTOR	FLANGE	8/30/2018 10:08:11 AM	L	500	5	5	[redacted]	9034	N	N
5686-000	VALVE	VALVE	8/30/2018 10:09:03 AM	L	500	5	5	[redacted]	9034	N	N
5686-000	VALVE	VALVE	9/26/2018 12:53:01 PM	L	500	19	15	[redacted]	27760	N	N
5686-000	VALVE	VALVE	12/10/2018 3:42:45 PM	L	500	32	11	[redacted]	3564	N	N
5686-001	CONNECTOR	PLUG	8/30/2018 10:09:21 AM	L	500	5	5	[redacted]	9034	N	N
5686-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:09:41 AM	L	500	5	5	[redacted]	9034	N	N
5687-000	VALVE	VALVE	8/30/2018 10:10:00 AM	L	500	6	5	[redacted]	9034	N	N
5687-000	VALVE	VALVE	9/26/2018 12:53:49 PM	L	500	22	15	[redacted]	27760	N	N
5687-000	VALVE	VALVE	12/10/2018 3:42:59 PM	L	500	33	11	[redacted]	3564	N	N
5687-001	CONNECTOR	PLUG	8/30/2018 10:10:20 AM	L	500	5	5	[redacted]	9034	N	N
5687-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:10:40 AM	L	500	6	5	[redacted]	9034	N	N
5687-003	CONNECTOR	FLANGE	8/30/2018 10:11:01 AM	L	500	5	5	[redacted]	9034	N	N
5688-000	VALVE	VALVE	8/30/2018 10:11:21 AM	L	500	7	5	[redacted]	9034	N	N
5688-000	VALVE	VALVE	9/26/2018 12:54:05 PM	L	500	21	15	[redacted]	27760	N	N
5688-000	VALVE	VALVE	12/10/2018 3:43:14 PM	L	500	39	11	[redacted]	3564	N	N
5688-001	CONNECTOR	PLUG	8/30/2018 10:11:39 AM	L	500	5	5	[redacted]	9034	N	N
5688-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:11:57 AM	L	500	5	5	[redacted]	9034	N	N
5689-000	VALVE	VALVE	8/30/2018 10:12:31 AM	L	500	5	5	[redacted]	9034	N	N
5689-000	VALVE	VALVE	9/26/2018 12:55:15 PM	L	500	19	15	[redacted]	27760	N	N
5689-000	VALVE	VALVE	12/10/2018 3:44:07 PM	L	500	87	11	[redacted]	3564	N	N
5689-001	CONNECTOR	FLANGE	8/30/2018 10:12:56 AM	L	500	5	5	[redacted]	9034	N	N
5689-002	CONNECTOR	FLANGE	8/30/2018 10:13:23 AM	L	500	5	5	[redacted]	9034	N	N
5689-003	CONNECTOR	FLANGE	8/30/2018 10:13:51 AM	L	500	5	5	[redacted]	9034	N	N
5689-004	CONNECTOR	FLANGE	8/30/2018 10:14:16 AM	L	500	5	5	[redacted]	9034	N	N
5690-000	VALVE	VALVE	8/30/2018 10:14:34 AM	L	500	5	5	[redacted]	9034	N	N
5690-000	VALVE	VALVE	9/26/2018 12:55:31 PM	L	500	23	15	[redacted]	27760	N	N
5690-000	VALVE	VALVE	12/10/2018 3:44:28 PM	L	500	84	11	[redacted]	3564	N	N
5690-001	CONNECTOR	FLANGE	8/30/2018 10:14:54 AM	L	500	5	5	[redacted]	9034	N	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5690-002	CONNECTOR	FLANGE	8/30/2018 10:15:45 AM	L	500	5	5	(b) (6) [redacted]	9034	N	N
5691-000	CONNECTOR	MANWAY	8/30/2018 10:16:36 AM	L	500	5	5	[redacted]	9034	N	N
5691-001	CONNECTOR	FLANGE	8/30/2018 10:17:20 AM	L	500	5	5	[redacted]	9034	N	N
5691-002	CONNECTOR	FLANGE	8/30/2018 10:17:55 AM	L	500	5	5	[redacted]	9034	N	N
5692-000	VALVE	VALVE	8/30/2018 10:19:32 AM	L	500	5	5	[redacted]	9034	N	N
5692-000	VALVE	VALVE	9/26/2018 12:56:30 PM	L	500	16	15	[redacted]	27760	N	N
5692-000	VALVE	VALVE	12/10/2018 3:45:05 PM	L	500	60	11	[redacted]	3564	N	N
5692-001	CONNECTOR	FLANGE	8/30/2018 10:19:53 AM	L	500	5	5	[redacted]	9034	N	N
5692-002	CONNECTOR	FLANGE	8/30/2018 10:20:17 AM	L	500	5	5	[redacted]	9034	N	N
5692-003	CONNECTOR	FLANGE	8/30/2018 10:20:41 AM	L	500	6	5	[redacted]	9034	N	N
5693-000	VALVE	VALVE	8/30/2018 10:21:06 AM	L	500	12	5	[redacted]	9034	N	N
5693-000	VALVE	VALVE	9/26/2018 12:56:58 PM	L	500	16	15	[redacted]	27760	N	N
5693-000	VALVE	VALVE	12/10/2018 3:45:39 PM	L	500	27	11	[redacted]	3564	N	N
5693-001	CONNECTOR	FLANGE	8/30/2018 10:21:36 AM	L	500	7	5	[redacted]	9034	N	N
5693-002	CONNECTOR	FLANGE	8/30/2018 10:22:07 AM	L	500	5	5	[redacted]	9034	N	N
5693-003	CONNECTOR	FLANGE	8/30/2018 10:22:37 AM	L	500	6	5	[redacted]	9034	N	N
5693-004	CONNECTOR	FLANGE	8/30/2018 10:23:04 AM	L	500	5	5	[redacted]	9034	N	N
5693-005	CONNECTOR	FLANGE	8/30/2018 10:23:31 AM	L	500	5	5	[redacted]	9034	N	N
5693-006	CONNECTOR	FLANGE	8/30/2018 10:23:57 AM	L	500	5	5	[redacted]	9034	N	N
5694-000	VALVE	VALVE	8/30/2018 10:24:16 AM	L	500	5	5	[redacted]	9034	N	N
5694-000	VALVE	VALVE	9/26/2018 12:57:16 PM	L	500	16	15	[redacted]	27760	N	N
5694-000	VALVE	VALVE	12/10/2018 3:46:05 PM	L	500	16	11	[redacted]	3564	N	N
5694-001	CONNECTOR	SCREWED FITTING	8/30/2018 10:24:37 AM	L	500	5	5	[redacted]	9034	N	N
5694-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:25:03 AM	L	500	8	5	[redacted]	9034	N	N
5694-003	CONNECTOR	90-DEGREE	8/30/2018 10:25:29 AM	L	500	9	5	[redacted]	9034	N	N
5694-004	CONNECTOR	SCREWED FITTING	8/30/2018 10:25:51 AM	L	500	5	5	[redacted]	9034	N	N
5695-000	VALVE	VALVE	8/30/2018 10:26:26 AM	L	500	5	5	[redacted]	9034	N	N
5695-000	VALVE	VALVE	9/26/2018 12:57:32 PM	L	500	15	15	[redacted]	27760	N	N
5695-000	VALVE	VALVE	12/10/2018 3:46:21 PM	L	500	14	11	[redacted]	3564	N	N
5695-001	CONNECTOR	SCREWED FITTING	8/30/2018 10:26:43 AM	L	500	5	5	[redacted]	9034	N	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5695-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:27:01 AM	L	500	5	5	(b) (6) [redacted]	9034	N	N
5695-003	CONNECTOR	90-DEGREE	8/30/2018 10:27:18 AM	L	500	5	5	[redacted]	9034	N	N
5695-004	CONNECTOR	SCREWED FITTING	8/30/2018 10:27:35 AM	L	500	5	5	[redacted]	9034	N	N
5696-000	VALVE	VALVE	8/30/2018 10:28:00 AM	L	500	5	5	[redacted]	9034	N	N
5696-000	VALVE	VALVE	9/26/2018 12:57:54 PM	L	500	16	15	[redacted]	27760	N	N
5696-000	VALVE	VALVE	12/10/2018 3:46:56 PM	L	500	14	11	[redacted]	3564	N	N
5696-001	CONNECTOR	FLANGE	8/30/2018 10:28:23 AM	L	500	5	5	[redacted]	9034	N	N
5696-002	CONNECTOR	FLANGE	8/30/2018 10:28:41 AM	L	500	5	5	[redacted]	9034	N	N
5697-000	CONNECTOR	MANWAY	8/30/2018 10:29:19 AM	L	500	5	5	[redacted]	9034	N	N
5697-001	CONNECTOR	FLANGE	8/30/2018 10:30:00 AM	L	500	5	5	[redacted]	9034	N	N
5697-002	CONNECTOR	FLANGE	8/30/2018 10:30:21 AM	L	500	5	5	[redacted]	9034	N	N
5698-000	VALVE	VALVE	8/30/2018 10:30:51 AM	L	500	5	5	[redacted]	9034	N	N
5698-000	VALVE	VALVE	9/26/2018 1:43:59 PM	L	500	16	15	[redacted]	27760	N	N
5698-000	VALVE	VALVE	12/10/2018 3:47:38 PM	L	500	13	11	[redacted]	3564	N	N
5698-001	CONNECTOR	FLANGE	8/30/2018 10:31:20 AM	L	500	5	5	[redacted]	9034	N	N
5698-002	CONNECTOR	FLANGE	8/30/2018 10:31:47 AM	L	500	5	5	[redacted]	9034	N	N
5698-003	CONNECTOR	FLANGE	8/30/2018 10:32:14 AM	L	500	5	5	[redacted]	9034	N	N
5699-000	CONNECTOR	MANWAY	8/30/2018 10:33:22 AM	L	500	5	5	[redacted]	9034	N	N
5700-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	11/28/2018 2:27:55 PM	L	500	23	7	[redacted]	3564	N	N
5700-001	CONNECTOR	FLANGE	11/28/2018 2:28:13 PM	L	500	6	7	[redacted]	3564	N	N
5700-002	CONNECTOR	FLANGE	11/28/2018 2:28:28 PM	L	500	6	7	[redacted]	3564	N	N
5701-000	VALVE	VALVE	8/30/2018 11:02:01 AM	L	500	16	5	[redacted]	9034	N	N
5701-000	VALVE	VALVE	9/26/2018 2:35:27 PM	L	500	17	16	[redacted]	27760	N	N
5701-000	VALVE	VALVE	12/10/2018 3:49:52 PM	L	500	15	11	[redacted]	3564	N	N
5701-001	CONNECTOR	FLANGE	8/30/2018 11:02:25 AM	L	500	5	5	[redacted]	9034	N	N
5701-002	CONNECTOR	FLANGE	8/30/2018 11:02:43 AM	L	500	5	5	[redacted]	9034	N	N
5701-003	CONNECTOR	FLANGE	8/30/2018 11:03:00 AM	L	500	6	5	[redacted]	9034	N	N
5701-004	CONNECTOR	FLANGE	8/30/2018 11:03:26 AM	L	500	5	5	[redacted]	9034	N	N
5701-005	CONNECTOR	FLANGE	8/30/2018 11:03:42 AM	L	500	5	5	[redacted]	9034	N	N
5701-006	CONNECTOR	FLANGE	8/30/2018 11:03:58 AM	L	500	5	5	[redacted]	9034	N	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5702-000	CONNECTOR	CAP	8/30/2018 11:04:56 AM	L	500	1475	5	(b) (6) [redacted]	9034	N	N
5702-001	CONNECTOR	FLANGE	8/30/2018 11:06:32 AM	L	500	9	5	[redacted]	9034	N	N
5702-002	CONNECTOR	FLANGE	8/30/2018 11:08:19 AM	L	500	5	5	[redacted]	9034	N	N
5703-000	VALVE	VALVE	8/30/2018 11:09:11 AM	G	500	5	5	[redacted]	9034	N	N
5703-000	VALVE	VALVE	9/26/2018 2:37:13 PM	G	500	23	16	[redacted]	27760	N	N
5703-000	VALVE	VALVE	12/10/2018 3:49:29 PM	G	500	28	11	[redacted]	3564	N	N
5703-001	CONNECTOR	SCREWED FITTING	8/30/2018 11:09:40 AM	G	500	5	5	[redacted]	9034	N	N
5703-002	CONNECTOR	SCREWED FITTING	8/30/2018 11:09:57 AM	G	500	5	5	[redacted]	9034	N	N
5703-003	CONNECTOR	UNION	8/30/2018 11:10:17 AM	G	500	5	5	[redacted]	9034	N	N
5703-004	CONNECTOR	SCREWED FITTING	8/30/2018 11:11:06 AM	G	500	5	5	[redacted]	9034	N	N
5703-005	CONNECTOR	SCREWED FITTING	8/30/2018 11:11:36 AM	G	500	5	5	[redacted]	9034	N	N
5704-000	VALVE	VALVE	8/30/2018 11:12:09 AM	G	500	5	5	[redacted]	9034	N	N
5704-000	VALVE	VALVE	9/26/2018 2:37:45 PM	G	500	17	16	[redacted]	27760	N	N
5704-000	VALVE	VALVE	12/10/2018 3:50:16 PM	G	500	38	11	[redacted]	3564	N	N
5704-001	CONNECTOR	FLANGE	8/30/2018 11:12:37 AM	G	500	5	5	[redacted]	9034	N	N
5704-002	CONNECTOR	FLANGE	8/30/2018 11:13:02 AM	G	500	5	5	[redacted]	9034	N	N
5704-003	CONNECTOR	FLANGE	8/30/2018 11:13:50 AM	G	500	6	5	[redacted]	9034	N	N
5705-000	VALVE	VALVE	8/30/2018 11:14:15 AM	G	500	5	5	[redacted]	9034	N	N
5705-000	VALVE	VALVE	9/26/2018 2:38:04 PM	G	500	16	16	[redacted]	27760	N	N
5705-000	VALVE	VALVE	12/10/2018 3:50:35 PM	G	500	16	11	[redacted]	3564	N	N
5705-001	CONNECTOR	SCREWED FITTING	8/30/2018 11:14:33 AM	G	500	5	5	[redacted]	9034	N	N
5705-002	CONNECTOR	SCREWED FITTING	8/30/2018 11:14:59 AM	G	500	7	5	[redacted]	9034	N	N
5706-000	VALVE	VALVE	8/30/2018 10:39:42 AM	G	500	5	5	[redacted]	9034	N	N
5706-000	VALVE	VALVE	9/26/2018 2:38:31 PM	G	500	17	16	[redacted]	27760	N	N
5706-000	VALVE	VALVE	12/10/2018 3:51:22 PM	G	500	16	11	[redacted]	3564	N	N
5706-001	CONNECTOR	FLANGE	8/30/2018 10:42:58 AM	G	500	33	5	[redacted]	9034	N	N
5706-002	CONNECTOR	FLANGE	8/30/2018 10:45:55 AM	G	500	5	5	[redacted]	9034	N	N
5707-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	9/27/2018 11:55:06 AM	G	500	6	6	[redacted]	3564	N	N
5707-000	PRESS RELIEF DEVICE	PRESSURE RELIEF VALVE	12/10/2018 3:52:37 PM	G	500	92	11	[redacted]	3564	N	N
5707-001	CONNECTOR	FLANGE	8/30/2018 10:46:19 AM	G	500	5	5	[redacted]	9034	N	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5707-002	CONNECTOR	FLANGE	8/30/2018 10:46:44 AM	G	500	5	5	(b) (6) [redacted]	9034	N	N
5708-000	VALVE	VALVE	8/30/2018 10:47:44 AM	G	500	5	5	[redacted]	9034	N	N
5708-000	VALVE	VALVE	9/27/2018 11:55:24 AM	G	500	6	6	[redacted]	3564	N	N
5708-000	VALVE	VALVE	12/10/2018 3:52:59 PM	G	500	23	11	[redacted]	3564	N	N
5708-001	CONNECTOR	FLANGE	8/30/2018 10:48:11 AM	G	500	5	5	[redacted]	9034	N	N
5708-002	CONNECTOR	FLANGE	8/30/2018 10:48:33 AM	G	500	5	5	[redacted]	9034	N	N
5708-003	CONNECTOR	FLANGE	8/30/2018 10:49:28 AM	G	500	5	5	[redacted]	9034	N	N
5708-004	CONNECTOR	FLANGE	8/30/2018 10:49:51 AM	G	500	5	5	[redacted]	9034	N	N
5709-000	VALVE	VALVE	8/30/2018 10:50:09 AM	G	500	5	5	[redacted]	9034	N	N
5709-000	VALVE	VALVE	9/27/2018 11:55:41 AM	G	500	6	6	[redacted]	3564	N	N
5709-000	VALVE	VALVE	12/10/2018 3:53:21 PM	G	500	19	11	[redacted]	3564	N	N
5709-001	CONNECTOR	PLUG	8/30/2018 10:50:39 AM	G	500	5	5	[redacted]	9034	N	N
5709-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:50:56 AM	G	500	5	5	[redacted]	9034	N	N
5710-000	VALVE	VALVE	8/30/2018 10:51:16 AM	G	500	5	5	[redacted]	9034	N	N
5710-000	VALVE	VALVE	9/27/2018 11:55:59 AM	G	500	6	6	[redacted]	3564	N	N
5710-000	VALVE	VALVE	12/10/2018 3:53:45 PM	G	500	15	11	[redacted]	3564	N	N
5710-001	CONNECTOR	PLUG	8/30/2018 10:51:33 AM	G	500	5	5	[redacted]	9034	N	N
5710-002	CONNECTOR	SCREWED FITTING	8/30/2018 10:51:52 AM	G	500	5	5	[redacted]	9034	N	N
5710-003	CONNECTOR	FLANGE	8/30/2018 10:52:15 AM	G	500	5	5	[redacted]	9034	N	N
5710-004	CONNECTOR	FLANGE	8/30/2018 10:52:38 AM	G	500	5	5	[redacted]	9034	N	N
5711-000	CONNECTOR	CAP	8/30/2018 10:53:34 AM	G	500	3602	5	[redacted]	9034	N	N
5711-001	CONNECTOR	FLANGE	8/30/2018 10:56:08 AM	G	500	102200	5	[redacted]	9034	N	N
5711-001	CONNECTOR	FLANGE	10/30/2018 11:47:18 AM	G	500	9	6	[redacted]	6239	N	N
5712-000	VALVE	VALVE	8/30/2018 10:59:06 AM	G	500	5	5	[redacted]	9034	N	N
5712-000	VALVE	VALVE	9/26/2018 2:41:03 PM	G	500	23	16	[redacted]	27760	N	N
5712-000	VALVE	VALVE	12/10/2018 3:54:05 PM	G	500	15	11	[redacted]	3564	N	N
5712-001	CONNECTOR	FLANGE	8/30/2018 10:59:30 AM	G	500	45	5	[redacted]	9034	N	N
5712-002	CONNECTOR	FLANGE	8/30/2018 11:00:25 AM	G	500	85	5	[redacted]	9034	N	N
5713-000	VALVE	VALVE	8/30/2018 11:16:25 AM	G	500	5	5	[redacted]	9034	N	N
5713-000	VALVE	VALVE	9/26/2018 2:42:04 PM	G	500	20	16	[redacted]	27760	N	N

Printed By: scsmith

Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5713-000	VALVE	VALVE	12/10/2018 3:54:25 PM	G	500	15	11	(b) (6) [redacted]	3564	N	N
5713-001	CONNECTOR	FLANGE	8/30/2018 11:17:02 AM	G	500	5	5	[redacted]	9034	N	N
5713-002	CONNECTOR	FLANGE	8/30/2018 11:17:40 AM	G	500	5	5	[redacted]	9034	N	N
5720-000	VALVE	VALVE	8/30/2018 11:25:57 AM	L	500	5	5	[redacted]	9034	N	N
5720-000	VALVE	VALVE	9/26/2018 2:48:07 PM	L	500	23	16	[redacted]	27760	N	N
5720-000	VALVE	VALVE	12/10/2018 3:58:05 PM	L	500	14	11	[redacted]	3564	N	N
5720-001	CONNECTOR	SCREWED FITTING	8/30/2018 11:26:13 AM	L	500	5	5	[redacted]	9034	N	N
5720-002	CONNECTOR	SCREWED FITTING	8/30/2018 11:26:29 AM	L	500	5	5	[redacted]	9034	N	N
5721-000	VALVE	VALVE	8/30/2018 11:26:49 AM	L	500	5	5	[redacted]	9034	N	N
5721-000	VALVE	VALVE	9/26/2018 2:48:24 PM	L	500	20	16	[redacted]	27760	N	N
5721-000	VALVE	VALVE	12/10/2018 3:58:23 PM	L	500	13	11	[redacted]	3564	N	N
5721-001	CONNECTOR	PLUG	8/30/2018 11:27:05 AM	L	500	5	5	[redacted]	9034	N	N
5721-002	CONNECTOR	SCREWED FITTING	8/30/2018 11:27:22 AM	L	500	5	5	[redacted]	9034	N	N
5722-000	VALVE	VALVE	8/30/2018 11:27:39 AM	L	500	5	5	[redacted]	9034	N	N
5722-000	VALVE	VALVE	9/26/2018 2:48:58 PM	L	500	19	16	[redacted]	27760	N	N
5722-000	VALVE	VALVE	12/10/2018 3:59:25 PM	L	500	13	11	[redacted]	3564	N	N
5722-001	CONNECTOR	PLUG	8/30/2018 11:27:55 AM	L	500	5	5	[redacted]	9034	N	N
5722-002	CONNECTOR	SCREWED FITTING	8/30/2018 11:28:24 AM	L	500	5	5	[redacted]	9034	N	N
5723-000	VALVE	VALVE	8/30/2018 11:28:41 AM	L	500	5	5	[redacted]	9034	N	N
5723-000	VALVE	VALVE	9/26/2018 2:49:14 PM	L	500	20	16	[redacted]	27760	N	N
5723-000	VALVE	VALVE	12/10/2018 3:59:43 PM	L	500	12	11	[redacted]	3564	N	N
5723-001	CONNECTOR	PLUG	8/30/2018 11:28:57 AM	L	500	5	5	[redacted]	9034	N	N
5723-002	CONNECTOR	SCREWED FITTING	8/30/2018 11:29:19 AM	L	500	5	5	[redacted]	9034	N	N
5724-000	VALVE	VALVE	8/30/2018 11:29:37 AM	L	500	5	5	[redacted]	9034	N	N
5724-000	VALVE	VALVE	9/26/2018 2:49:31 PM	L	500	21	16	[redacted]	27760	N	N
5724-000	VALVE	VALVE	12/10/2018 4:00:03 PM	L	500	13	11	[redacted]	3564	N	N
5724-001	CONNECTOR	SCREWED FITTING	8/30/2018 11:29:59 AM	L	500	5	5	[redacted]	9034	N	N
5724-002	CONNECTOR	SCREWED FITTING	8/30/2018 11:30:15 AM	L	500	5	5	[redacted]	9034	N	N
5744-000	VALVE	VALVE	8/30/2018 9:20:33 AM	L	500	7	2	[redacted]	46852	N	N
5744-000	VALVE	VALVE	9/26/2018 3:03:44 PM	L	500	17	16	[redacted]	27760	N	N

Printed By: scsmith

CVS Monitor Details Report

DCP Operating Company, L.P. - Mewbourn II
From: 7/1/2018 To: 12/31/2018
NSPS OOOOa

Unit: **TANK FARM** Area: **SUB**

Tag	Component Type	Sub Type	Monitor Date	Service Type	Threshold	Reading	BkGnd	Tech	Instrument	DTM	UTM
5744-000	VALVE	VALVE	12/10/2018 4:09:37 PM	L	500	17	11	(b) (6) [redacted]	3564	N	N
5744-001	CONNECTOR	FLANGE	8/30/2018 9:20:51 AM	L	500	7	2	[redacted]	46852	N	N
5773-000	VALVE	CHECK VALVE	8/30/2018 10:06:44 AM	L	500	6	2	[redacted]	46852	N	N
5773-000	VALVE	CHECK VALVE	9/26/2018 3:23:22 PM	L	500	16	16	[redacted]	27760	N	N
5773-000	VALVE	CHECK VALVE	12/13/2018 9:13:38 AM	L	500	5	4	[redacted]	3564	N	N
5773-001	CONNECTOR	FLANGE	8/30/2018 10:07:12 AM	L	500	6	2	[redacted]	46852	N	N
5774-000	VALVE	VALVE	8/30/2018 10:07:34 AM	L	500	5	2	[redacted]	46852	N	N
5774-000	VALVE	VALVE	9/26/2018 3:23:38 PM	L	500	17	16	[redacted]	27760	N	N
5774-000	VALVE	VALVE	12/13/2018 9:13:54 AM	L	500	5	4	[redacted]	3564	N	N

This report was generated using a filter:

CVS / Control Device is true And
Rule Name is equal to NSPS OOOOa And
(Unit is equal to CONDENSATE PIPELINE Or
Unit is equal to NORTH INLET Or
Unit is equal to TANK FARM)

Printed By: scsmith

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
NORINLET	SUB	SUB	4411-003	CONNECTOR	09/19/2018 14:56:34	LLovato
NORINLET	SUB	SUB	4412-003	CONNECTOR	09/19/2018 14:58:19	LLovato
TANKFARM	SUB	SUB	4732E-000	PRESS RELIEF DEVICE	09/24/2018 12:40:28	ibatterton
TANKFARM	SUB	SUB	4744B-000	VALVE	08/28/2018 14:05:49	LARISA
TANKFARM	SUB	SUB	4744B-001	CONNECTOR	08/28/2018 14:06:05	LARISA
TANKFARM	SUB	SUB	4744B-002	CONNECTOR	08/28/2018 14:06:05	LARISA
TANKFARM	SUB	SUB	4744B-003	CONNECTOR	08/28/2018 14:06:06	LARISA
TANKFARM	SUB	SUB	5663-000	VALVE	08/28/2018 15:01:59	LARISA
TANKFARM	SUB	SUB	5663-001	CONNECTOR	08/28/2018 15:02:29	LARISA
TANKFARM	SUB	SUB	5663-002	CONNECTOR	08/28/2018 15:02:29	LARISA
TANKFARM	SUB	SUB	5663-003	CONNECTOR	08/28/2018 15:02:30	LARISA
TANKFARM	SUB	SUB	5664-000	VALVE	08/28/2018 15:03:04	LARISA
TANKFARM	SUB	SUB	5664-001	CONNECTOR	08/28/2018 15:03:25	LARISA
TANKFARM	SUB	SUB	5664-002	CONNECTOR	08/28/2018 15:03:26	LARISA
TANKFARM	SUB	SUB	5665-000	VALVE	08/28/2018 15:03:51	LARISA
TANKFARM	SUB	SUB	5665-001	CONNECTOR	08/28/2018 15:04:09	LARISA
TANKFARM	SUB	SUB	5666-000	VALVE	08/28/2018 15:04:30	LARISA
TANKFARM	SUB	SUB	5666-001	CONNECTOR	08/28/2018 15:04:46	LARISA
TANKFARM	SUB	SUB	5666-002	CONNECTOR	08/28/2018 15:04:46	LARISA
TANKFARM	SUB	SUB	5666-003	CONNECTOR	08/28/2018 15:04:47	LARISA
TANKFARM	SUB	SUB	5667-000	VALVE	08/28/2018 15:05:19	LARISA
TANKFARM	SUB	SUB	5667-001	CONNECTOR	08/28/2018 15:05:34	LARISA
TANKFARM	SUB	SUB	5667-002	CONNECTOR	08/28/2018 15:05:35	LARISA
TANKFARM	SUB	SUB	5667-003	CONNECTOR	08/28/2018 15:05:35	LARISA
TANKFARM	SUB	SUB	5668-000	VALVE	08/28/2018 15:06:30	LARISA
TANKFARM	SUB	SUB	5668-001	CONNECTOR	08/28/2018 15:06:54	LARISA
TANKFARM	SUB	SUB	5668-002	CONNECTOR	08/28/2018 15:06:55	LARISA
TANKFARM	SUB	SUB	5668-003	CONNECTOR	08/28/2018 15:06:56	LARISA
TANKFARM	SUB	SUB	5669-000	VALVE	08/28/2018 15:08:07	LARISA
TANKFARM	SUB	SUB	5669-001	CONNECTOR	08/28/2018 15:08:32	LARISA
TANKFARM	SUB	SUB	5669-002	CONNECTOR	08/28/2018 15:08:33	LARISA

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5669-003	CONNECTOR	08/28/2018 15:08:34	LARISA
TANKFARM	SUB	SUB	5669-004	CONNECTOR	08/28/2018 15:08:34	LARISA
TANKFARM	SUB	SUB	5669-005	CONNECTOR	08/28/2018 15:08:35	LARISA
TANKFARM	SUB	SUB	5670-000	VALVE	08/28/2018 15:09:36	LARISA
TANKFARM	SUB	SUB	5670-001	CONNECTOR	08/28/2018 15:09:56	LARISA
TANKFARM	SUB	SUB	5670-002	CONNECTOR	08/28/2018 15:09:57	LARISA
TANKFARM	SUB	SUB	5670-003	CONNECTOR	08/28/2018 15:09:57	LARISA
TANKFARM	SUB	SUB	5670-004	CONNECTOR	08/28/2018 15:09:58	LARISA
TANKFARM	SUB	SUB	5671-000	VALVE	08/28/2018 15:11:04	LARISA
TANKFARM	SUB	SUB	5671-001	CONNECTOR	08/28/2018 15:11:24	LARISA
TANKFARM	SUB	SUB	5671-002	CONNECTOR	08/28/2018 15:11:25	LARISA
TANKFARM	SUB	SUB	5671-003	CONNECTOR	08/28/2018 15:11:26	LARISA
TANKFARM	SUB	SUB	5672-000	VALVE	08/28/2018 15:12:07	LARISA
TANKFARM	SUB	SUB	5673-000	VALVE	08/28/2018 15:12:20	LARISA
TANKFARM	SUB	SUB	5673-001	CONNECTOR	08/28/2018 15:12:36	LARISA
TANKFARM	SUB	SUB	5673-002	CONNECTOR	08/28/2018 15:12:37	LARISA
TANKFARM	SUB	SUB	5673-003	CONNECTOR	08/28/2018 15:12:38	LARISA
TANKFARM	SUB	SUB	5674-000	VALVE	08/28/2018 15:13:21	LARISA
TANKFARM	SUB	SUB	5674-001	CONNECTOR	08/28/2018 15:13:35	LARISA
TANKFARM	SUB	SUB	5674-002	CONNECTOR	08/28/2018 15:13:36	LARISA
TANKFARM	SUB	SUB	5674-003	CONNECTOR	08/28/2018 15:13:37	LARISA
TANKFARM	SUB	SUB	5675-000	VALVE	08/28/2018 15:14:04	LARISA
TANKFARM	SUB	SUB	5675-001	CONNECTOR	08/28/2018 15:14:21	LARISA
TANKFARM	SUB	SUB	5676-000	VALVE	08/28/2018 15:15:45	LARISA
TANKFARM	SUB	SUB	5676-001	CONNECTOR	08/28/2018 15:16:00	LARISA
TANKFARM	SUB	SUB	5676-002	CONNECTOR	08/28/2018 15:16:01	LARISA
TANKFARM	SUB	SUB	5676-003	CONNECTOR	08/28/2018 15:16:02	LARISA
TANKFARM	SUB	SUB	5677-000	VALVE	08/28/2018 15:16:16	LARISA
TANKFARM	SUB	SUB	5677-001	CONNECTOR	08/28/2018 15:16:38	LARISA
TANKFARM	SUB	SUB	5677-002	CONNECTOR	08/28/2018 15:16:39	LARISA
TANKFARM	SUB	SUB	5678-000	CONNECTOR	08/28/2018 15:26:24	LARISA

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5679-000	VALVE	08/28/2018 15:27:00	LARISA
TANKFARM	SUB	SUB	5679-001	CONNECTOR	08/28/2018 15:27:27	LARISA
TANKFARM	SUB	SUB	5679-002	CONNECTOR	08/28/2018 15:27:28	LARISA
TANKFARM	SUB	SUB	5680-000	VALVE	08/28/2018 15:27:56	LARISA
TANKFARM	SUB	SUB	5680-001	CONNECTOR	08/28/2018 15:28:29	LARISA
TANKFARM	SUB	SUB	5680-002	CONNECTOR	08/28/2018 15:28:29	LARISA
TANKFARM	SUB	SUB	5681-000	VALVE	08/28/2018 15:29:38	LARISA
TANKFARM	SUB	SUB	5681-001	CONNECTOR	08/28/2018 15:30:07	LARISA
TANKFARM	SUB	SUB	5682-000	PRESS RELIEF DEVICE	08/28/2018 15:30:31	LARISA
TANKFARM	SUB	SUB	5682-001	CONNECTOR	08/28/2018 15:30:58	LARISA
TANKFARM	SUB	SUB	5683-000	VALVE	08/28/2018 15:31:17	LARISA
TANKFARM	SUB	SUB	5683-001	CONNECTOR	08/28/2018 15:31:31	LARISA
TANKFARM	SUB	SUB	5683-002	CONNECTOR	08/28/2018 15:31:31	LARISA
TANKFARM	SUB	SUB	5684-000	VALVE	08/28/2018 15:33:00	LARISA
TANKFARM	SUB	SUB	5684-001	CONNECTOR	08/28/2018 15:33:20	LARISA
TANKFARM	SUB	SUB	5684-002	CONNECTOR	08/28/2018 15:33:21	LARISA
TANKFARM	SUB	SUB	5685-000	VALVE	08/28/2018 15:33:51	LARISA
TANKFARM	SUB	SUB	5685-001	CONNECTOR	08/28/2018 15:34:04	LARISA
TANKFARM	SUB	SUB	5685-002	CONNECTOR	08/28/2018 15:34:05	LARISA
TANKFARM	SUB	SUB	5686-000	VALVE	08/28/2018 15:34:51	LARISA
TANKFARM	SUB	SUB	5686-001	CONNECTOR	08/28/2018 15:35:12	LARISA
TANKFARM	SUB	SUB	5686-002	CONNECTOR	08/28/2018 15:35:13	LARISA
TANKFARM	SUB	SUB	5687-000	VALVE	08/28/2018 15:35:39	LARISA
TANKFARM	SUB	SUB	5687-001	CONNECTOR	08/28/2018 15:36:03	LARISA
TANKFARM	SUB	SUB	5687-002	CONNECTOR	08/28/2018 15:36:04	LARISA
TANKFARM	SUB	SUB	5687-003	CONNECTOR	08/28/2018 15:36:04	LARISA
TANKFARM	SUB	SUB	5688-000	VALVE	08/28/2018 15:38:41	LARISA
TANKFARM	SUB	SUB	5688-001	CONNECTOR	08/28/2018 15:38:58	LARISA
TANKFARM	SUB	SUB	5688-002	CONNECTOR	08/28/2018 15:38:59	LARISA
TANKFARM	SUB	SUB	5689-000	VALVE	08/28/2018 15:39:30	LARISA
TANKFARM	SUB	SUB	5689-001	CONNECTOR	08/28/2018 15:39:42	LARISA

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5689-002	CONNECTOR	08/28/2018 15:39:43	LARISA
TANKFARM	SUB	SUB	5689-003	CONNECTOR	08/28/2018 15:39:44	LARISA
TANKFARM	SUB	SUB	5689-004	CONNECTOR	08/28/2018 15:39:44	LARISA
TANKFARM	SUB	SUB	5690-000	VALVE	08/28/2018 15:40:06	LARISA
TANKFARM	SUB	SUB	5690-001	CONNECTOR	08/28/2018 15:42:47	LARISA
TANKFARM	SUB	SUB	5690-002	CONNECTOR	08/28/2018 15:42:48	LARISA
TANKFARM	SUB	SUB	5691-000	CONNECTOR	08/28/2018 15:43:09	LARISA
TANKFARM	SUB	SUB	5691-001	CONNECTOR	08/28/2018 15:43:24	LARISA
TANKFARM	SUB	SUB	5691-002	CONNECTOR	08/28/2018 15:43:26	LARISA
TANKFARM	SUB	SUB	5692-000	VALVE	08/28/2018 15:44:11	LARISA
TANKFARM	SUB	SUB	5692-001	CONNECTOR	08/28/2018 15:44:27	LARISA
TANKFARM	SUB	SUB	5692-002	CONNECTOR	08/28/2018 15:44:27	LARISA
TANKFARM	SUB	SUB	5692-003	CONNECTOR	08/28/2018 15:44:29	LARISA
TANKFARM	SUB	SUB	5693-000	VALVE	08/28/2018 15:45:20	LARISA
TANKFARM	SUB	SUB	5693-001	CONNECTOR	08/28/2018 15:45:32	LARISA
TANKFARM	SUB	SUB	5693-002	CONNECTOR	08/28/2018 15:45:33	LARISA
TANKFARM	SUB	SUB	5693-003	CONNECTOR	08/28/2018 15:45:34	LARISA
TANKFARM	SUB	SUB	5693-004	CONNECTOR	08/28/2018 15:45:35	LARISA
TANKFARM	SUB	SUB	5693-005	CONNECTOR	08/28/2018 15:45:36	LARISA
TANKFARM	SUB	SUB	5693-006	CONNECTOR	08/28/2018 15:45:36	LARISA
TANKFARM	SUB	SUB	5694-000	VALVE	08/28/2018 15:46:22	LARISA
TANKFARM	SUB	SUB	5694-001	CONNECTOR	08/28/2018 15:47:02	LARISA
TANKFARM	SUB	SUB	5694-002	CONNECTOR	08/28/2018 15:47:03	LARISA
TANKFARM	SUB	SUB	5694-003	CONNECTOR	08/28/2018 15:47:04	LARISA
TANKFARM	SUB	SUB	5694-004	CONNECTOR	08/28/2018 15:47:05	LARISA
TANKFARM	SUB	SUB	5695-000	VALVE	08/28/2018 15:47:55	LARISA
TANKFARM	SUB	SUB	5695-001	CONNECTOR	08/28/2018 15:48:07	LARISA
TANKFARM	SUB	SUB	5695-002	CONNECTOR	08/28/2018 15:48:08	LARISA
TANKFARM	SUB	SUB	5695-003	CONNECTOR	08/28/2018 15:48:10	LARISA
TANKFARM	SUB	SUB	5695-004	CONNECTOR	08/28/2018 15:48:10	LARISA
TANKFARM	SUB	SUB	5696-000	VALVE	08/28/2018 15:48:44	LARISA

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5696-001	CONNECTOR	08/28/2018 15:48:56	LARISA
TANKFARM	SUB	SUB	5696-002	CONNECTOR	08/28/2018 15:48:57	LARISA
TANKFARM	SUB	SUB	5697-000	CONNECTOR	08/28/2018 15:49:17	LARISA
TANKFARM	SUB	SUB	5697-001	CONNECTOR	08/28/2018 15:49:52	LARISA
TANKFARM	SUB	SUB	5697-002	CONNECTOR	08/28/2018 15:49:53	LARISA
TANKFARM	SUB	SUB	5698-000	VALVE	08/28/2018 15:50:49	LARISA
TANKFARM	SUB	SUB	5698-001	CONNECTOR	08/28/2018 15:51:10	LARISA
TANKFARM	SUB	SUB	5698-002	CONNECTOR	08/28/2018 15:51:11	LARISA
TANKFARM	SUB	SUB	5698-003	CONNECTOR	08/28/2018 15:51:11	LARISA
TANKFARM	SUB	SUB	5699-000	CONNECTOR	08/28/2018 15:51:53	LARISA
TANKFARM	SUB	SUB	5700-000	PRESS RELIEF DEVICE	08/28/2018 15:53:30	LARISA
TANKFARM	SUB	SUB	5700-001	CONNECTOR	08/28/2018 15:53:56	LARISA
TANKFARM	SUB	SUB	5700-002	CONNECTOR	08/28/2018 15:53:57	LARISA
TANKFARM	SUB	SUB	5701-000	VALVE	08/28/2018 15:54:27	LARISA
TANKFARM	SUB	SUB	5701-001	CONNECTOR	08/28/2018 15:54:45	LARISA
TANKFARM	SUB	SUB	5701-002	CONNECTOR	08/28/2018 15:54:46	LARISA
TANKFARM	SUB	SUB	5701-003	CONNECTOR	08/28/2018 15:54:47	LARISA
TANKFARM	SUB	SUB	5701-004	CONNECTOR	08/28/2018 15:54:47	LARISA
TANKFARM	SUB	SUB	5701-005	CONNECTOR	08/28/2018 15:54:48	LARISA
TANKFARM	SUB	SUB	5701-006	CONNECTOR	08/28/2018 15:54:49	LARISA
TANKFARM	SUB	SUB	5702-000	CONNECTOR	08/28/2018 15:57:14	LARISA
TANKFARM	SUB	SUB	5702-001	CONNECTOR	08/28/2018 15:57:33	LARISA
TANKFARM	SUB	SUB	5702-002	CONNECTOR	08/28/2018 15:57:34	LARISA
TANKFARM	SUB	SUB	5703-000	VALVE	08/28/2018 15:59:06	LARISA
TANKFARM	SUB	SUB	5703-001	CONNECTOR	08/28/2018 15:59:26	LARISA
TANKFARM	SUB	SUB	5703-002	CONNECTOR	08/28/2018 15:59:27	LARISA
TANKFARM	SUB	SUB	5703-003	CONNECTOR	08/28/2018 15:59:27	LARISA
TANKFARM	SUB	SUB	5703-004	CONNECTOR	08/28/2018 15:59:28	LARISA
TANKFARM	SUB	SUB	5703-005	CONNECTOR	08/28/2018 15:59:28	LARISA
TANKFARM	SUB	SUB	5704-000	VALVE	08/28/2018 16:00:08	LARISA
TANKFARM	SUB	SUB	5704-001	CONNECTOR	08/28/2018 16:00:24	LARISA

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5704-002	CONNECTOR	08/28/2018 16:00:25	LARISA
TANKFARM	SUB	SUB	5704-003	CONNECTOR	08/28/2018 16:00:26	LARISA
TANKFARM	SUB	SUB	5705-000	VALVE	08/28/2018 16:00:49	LARISA
TANKFARM	SUB	SUB	5705-001	CONNECTOR	08/28/2018 16:01:33	LARISA
TANKFARM	SUB	SUB	5705-002	CONNECTOR	08/28/2018 16:01:35	LARISA
TANKFARM	SUB	SUB	5706-000	VALVE	08/28/2018 16:02:03	LARISA
TANKFARM	SUB	SUB	5706-001	CONNECTOR	08/28/2018 16:02:15	LARISA
TANKFARM	SUB	SUB	5706-002	CONNECTOR	08/28/2018 16:02:16	LARISA
TANKFARM	SUB	SUB	5707-000	PRESS RELIEF DEVICE	08/28/2018 16:02:42	LARISA
TANKFARM	SUB	SUB	5707-001	CONNECTOR	08/28/2018 16:02:55	LARISA
TANKFARM	SUB	SUB	5707-002	CONNECTOR	08/28/2018 16:02:56	LARISA
TANKFARM	SUB	SUB	5708-000	VALVE	08/28/2018 16:03:27	LARISA
TANKFARM	SUB	SUB	5708-001	CONNECTOR	08/28/2018 16:03:44	LARISA
TANKFARM	SUB	SUB	5708-002	CONNECTOR	08/28/2018 16:03:44	LARISA
TANKFARM	SUB	SUB	5708-003	CONNECTOR	08/28/2018 16:03:45	LARISA
TANKFARM	SUB	SUB	5708-004	CONNECTOR	08/28/2018 16:03:46	LARISA
TANKFARM	SUB	SUB	5709-000	VALVE	08/28/2018 16:04:04	LARISA
TANKFARM	SUB	SUB	5709-001	CONNECTOR	08/28/2018 16:04:17	LARISA
TANKFARM	SUB	SUB	5709-002	CONNECTOR	08/28/2018 16:04:18	LARISA
TANKFARM	SUB	SUB	5710-000	VALVE	08/28/2018 16:04:38	LARISA
TANKFARM	SUB	SUB	5710-001	CONNECTOR	08/28/2018 16:05:01	LARISA
TANKFARM	SUB	SUB	5710-002	CONNECTOR	08/28/2018 16:05:02	LARISA
TANKFARM	SUB	SUB	5710-003	CONNECTOR	08/28/2018 16:05:03	LARISA
TANKFARM	SUB	SUB	5710-004	CONNECTOR	08/28/2018 16:05:03	LARISA
TANKFARM	SUB	SUB	5711-000	CONNECTOR	08/28/2018 16:06:06	LARISA
TANKFARM	SUB	SUB	5711-001	CONNECTOR	08/28/2018 16:06:18	LARISA
TANKFARM	SUB	SUB	5712-000	VALVE	08/28/2018 16:06:45	LARISA
TANKFARM	SUB	SUB	5712-001	CONNECTOR	08/28/2018 16:07:04	LARISA
TANKFARM	SUB	SUB	5712-002	CONNECTOR	08/28/2018 16:07:04	LARISA
TANKFARM	SUB	SUB	5713-000	VALVE	08/28/2018 16:11:18	LARISA
TANKFARM	SUB	SUB	5713-001	CONNECTOR	08/28/2018 16:12:08	LARISA

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5713-002	CONNECTOR	08/28/2018 16:12:09	LARISA
TANKFARM	SUB	SUB	5714-000	VALVE	08/29/2018 14:56:02	ibatterton
TANKFARM	SUB	SUB	5714-001	CONNECTOR	08/29/2018 15:13:33	ibatterton
TANKFARM	SUB	SUB	5714-002	CONNECTOR	08/29/2018 15:13:34	ibatterton
TANKFARM	SUB	SUB	5715-000	VALVE	08/29/2018 15:11:28	ibatterton
TANKFARM	SUB	SUB	5715-001	CONNECTOR	08/29/2018 15:14:59	ibatterton
TANKFARM	SUB	SUB	5715-002	CONNECTOR	08/29/2018 15:15:00	ibatterton
TANKFARM	SUB	SUB	5716-000	VALVE	08/29/2018 15:12:22	ibatterton
TANKFARM	SUB	SUB	5716-001	CONNECTOR	08/29/2018 15:16:10	ibatterton
TANKFARM	SUB	SUB	5716-002	CONNECTOR	08/29/2018 15:16:10	ibatterton
TANKFARM	SUB	SUB	5717-000	VALVE	08/29/2018 15:12:48	ibatterton
TANKFARM	SUB	SUB	5717-001	CONNECTOR	08/29/2018 15:16:45	ibatterton
TANKFARM	SUB	SUB	5717-002	CONNECTOR	08/29/2018 15:16:46	ibatterton
TANKFARM	SUB	SUB	5718-000	VALVE	08/29/2018 15:13:13	ibatterton
TANKFARM	SUB	SUB	5718-001	CONNECTOR	08/29/2018 15:17:29	ibatterton
TANKFARM	SUB	SUB	5718-002	CONNECTOR	08/29/2018 15:17:30	ibatterton
TANKFARM	SUB	SUB	5719-000	VALVE	08/29/2018 15:18:00	ibatterton
TANKFARM	SUB	SUB	5719-001	CONNECTOR	08/29/2018 15:20:21	ibatterton
TANKFARM	SUB	SUB	5719-002	CONNECTOR	08/29/2018 15:20:22	ibatterton
TANKFARM	SUB	SUB	5720-000	VALVE	08/29/2018 15:18:53	ibatterton
TANKFARM	SUB	SUB	5720-001	CONNECTOR	08/29/2018 15:20:46	ibatterton
TANKFARM	SUB	SUB	5720-002	CONNECTOR	08/29/2018 15:20:47	ibatterton
TANKFARM	SUB	SUB	5721-000	VALVE	08/29/2018 15:19:10	ibatterton
TANKFARM	SUB	SUB	5721-001	CONNECTOR	08/29/2018 15:21:25	ibatterton
TANKFARM	SUB	SUB	5721-002	CONNECTOR	08/29/2018 15:21:26	ibatterton
TANKFARM	SUB	SUB	5722-000	VALVE	08/29/2018 15:19:23	ibatterton
TANKFARM	SUB	SUB	5722-001	CONNECTOR	08/29/2018 15:22:36	ibatterton
TANKFARM	SUB	SUB	5722-002	CONNECTOR	08/29/2018 15:22:37	ibatterton
TANKFARM	SUB	SUB	5723-000	VALVE	08/29/2018 15:23:45	ibatterton
TANKFARM	SUB	SUB	5723-001	CONNECTOR	08/29/2018 15:26:49	ibatterton
TANKFARM	SUB	SUB	5723-002	CONNECTOR	08/29/2018 15:26:51	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5724-000	VALVE	08/29/2018 15:19:57	ibatterton
TANKFARM	SUB	SUB	5724-001	CONNECTOR	08/29/2018 15:27:25	ibatterton
TANKFARM	SUB	SUB	5724-002	CONNECTOR	08/29/2018 15:27:26	ibatterton
TANKFARM	SUB	SUB	5725-000	VALVE	08/29/2018 15:38:44	ibatterton
TANKFARM	SUB	SUB	5725-001	CONNECTOR	08/29/2018 15:40:41	ibatterton
TANKFARM	SUB	SUB	5725-002	CONNECTOR	08/29/2018 15:40:43	ibatterton
TANKFARM	SUB	SUB	5726-000	VALVE	08/29/2018 15:38:59	ibatterton
TANKFARM	SUB	SUB	5726-001	CONNECTOR	08/29/2018 15:41:01	ibatterton
TANKFARM	SUB	SUB	5726-002	CONNECTOR	08/29/2018 15:41:02	ibatterton
TANKFARM	SUB	SUB	5727-000	VALVE	08/29/2018 15:40:20	ibatterton
TANKFARM	SUB	SUB	5727-001	CONNECTOR	08/29/2018 15:42:09	ibatterton
TANKFARM	SUB	SUB	5727-002	CONNECTOR	08/29/2018 15:42:10	ibatterton
TANKFARM	SUB	SUB	5728-000	VALVE	08/29/2018 15:42:32	ibatterton
TANKFARM	SUB	SUB	5728-001	CONNECTOR	08/29/2018 15:42:50	ibatterton
TANKFARM	SUB	SUB	5728-002	CONNECTOR	08/29/2018 15:42:51	ibatterton
TANKFARM	SUB	SUB	5729-000	VALVE	08/29/2018 15:59:03	ibatterton
TANKFARM	SUB	SUB	5730-000	VALVE	08/29/2018 16:00:40	ibatterton
TANKFARM	SUB	SUB	5730-001	CONNECTOR	08/29/2018 16:01:30	ibatterton
TANKFARM	SUB	SUB	5730-002	CONNECTOR	08/29/2018 16:01:31	ibatterton
TANKFARM	SUB	SUB	5730-003	CONNECTOR	08/29/2018 16:01:32	ibatterton
TANKFARM	SUB	SUB	5730-004	CONNECTOR	08/29/2018 16:01:32	ibatterton
TANKFARM	SUB	SUB	5730-005	CONNECTOR	08/29/2018 16:01:33	ibatterton
TANKFARM	SUB	SUB	5730-006	CONNECTOR	08/29/2018 16:01:34	ibatterton
TANKFARM	SUB	SUB	5730-007	CONNECTOR	08/29/2018 16:01:34	ibatterton
TANKFARM	SUB	SUB	5731-000	VALVE	08/29/2018 16:00:55	ibatterton
TANKFARM	SUB	SUB	5731-001	CONNECTOR	08/29/2018 16:02:50	ibatterton
TANKFARM	SUB	SUB	5731-002	CONNECTOR	08/29/2018 16:02:51	ibatterton
TANKFARM	SUB	SUB	5731-003	CONNECTOR	08/29/2018 16:02:52	ibatterton
TANKFARM	SUB	SUB	5731-004	CONNECTOR	08/29/2018 16:02:53	ibatterton
TANKFARM	SUB	SUB	5731-005	CONNECTOR	08/29/2018 16:02:53	ibatterton
TANKFARM	SUB	SUB	5731-006	CONNECTOR	08/29/2018 16:02:54	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5732-000	VALVE	08/29/2018 16:04:31	ibatterton
TANKFARM	SUB	SUB	5732-001	CONNECTOR	08/29/2018 16:06:31	ibatterton
TANKFARM	SUB	SUB	5733-000	VALVE	08/29/2018 16:04:48	ibatterton
TANKFARM	SUB	SUB	5734-000	VALVE	08/29/2018 16:05:35	ibatterton
TANKFARM	SUB	SUB	5735-000	VALVE	08/29/2018 16:05:46	ibatterton
TANKFARM	SUB	SUB	5736-000	VALVE	08/29/2018 16:05:57	ibatterton
TANKFARM	SUB	SUB	5736-001	CONNECTOR	08/29/2018 16:06:52	ibatterton
TANKFARM	SUB	SUB	5737-000	VALVE	08/29/2018 16:08:29	ibatterton
TANKFARM	SUB	SUB	5737-001	CONNECTOR	08/29/2018 16:09:15	ibatterton
TANKFARM	SUB	SUB	5737-002	CONNECTOR	08/29/2018 16:09:16	ibatterton
TANKFARM	SUB	SUB	5737-003	CONNECTOR	08/29/2018 16:09:17	ibatterton
TANKFARM	SUB	SUB	5737-004	CONNECTOR	08/29/2018 16:09:18	ibatterton
TANKFARM	SUB	SUB	5737-005	CONNECTOR	08/29/2018 16:09:18	ibatterton
TANKFARM	SUB	SUB	5737-006	CONNECTOR	08/29/2018 16:09:19	ibatterton
TANKFARM	SUB	SUB	5737-007	CONNECTOR	08/29/2018 16:09:19	ibatterton
TANKFARM	SUB	SUB	5738-000	VALVE	08/29/2018 16:08:43	ibatterton
TANKFARM	SUB	SUB	5738-001	CONNECTOR	08/29/2018 16:10:45	ibatterton
TANKFARM	SUB	SUB	5738-002	CONNECTOR	08/29/2018 16:10:46	ibatterton
TANKFARM	SUB	SUB	5738-003	CONNECTOR	08/29/2018 16:10:46	ibatterton
TANKFARM	SUB	SUB	5738-004	CONNECTOR	08/29/2018 16:10:47	ibatterton
TANKFARM	SUB	SUB	5738-005	CONNECTOR	08/29/2018 16:10:47	ibatterton
TANKFARM	SUB	SUB	5738-006	CONNECTOR	08/29/2018 16:10:48	ibatterton
TANKFARM	SUB	SUB	5739-000	VALVE	08/29/2018 16:11:38	ibatterton
TANKFARM	SUB	SUB	5739-001	CONNECTOR	08/29/2018 16:13:34	ibatterton
TANKFARM	SUB	SUB	5740-000	VALVE	08/29/2018 16:12:11	ibatterton
TANKFARM	SUB	SUB	5741-000	VALVE	08/29/2018 16:12:22	ibatterton
TANKFARM	SUB	SUB	5742-000	VALVE	08/29/2018 16:12:32	ibatterton
TANKFARM	SUB	SUB	5743-000	VALVE	08/29/2018 16:12:44	ibatterton
TANKFARM	SUB	SUB	5743-001	CONNECTOR	08/29/2018 16:13:02	ibatterton
TANKFARM	SUB	SUB	5744-000	VALVE	08/29/2018 16:14:54	ibatterton
TANKFARM	SUB	SUB	5744-001	CONNECTOR	08/29/2018 16:15:14	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5745-000	VALVE	08/29/2018 16:17:24	ibatterton
TANKFARM	SUB	SUB	5745-001	CONNECTOR	08/29/2018 16:20:26	ibatterton
TANKFARM	SUB	SUB	5745-002	CONNECTOR	08/29/2018 16:20:26	ibatterton
TANKFARM	SUB	SUB	5745-003	CONNECTOR	08/29/2018 16:20:27	ibatterton
TANKFARM	SUB	SUB	5746-000	VALVE	08/29/2018 16:18:13	ibatterton
TANKFARM	SUB	SUB	5746-001	CONNECTOR	08/29/2018 16:20:47	ibatterton
TANKFARM	SUB	SUB	5746-002	CONNECTOR	08/29/2018 16:20:48	ibatterton
TANKFARM	SUB	SUB	5747-000	VALVE	08/29/2018 16:19:30	ibatterton
TANKFARM	SUB	SUB	5747-001	CONNECTOR	08/29/2018 16:21:08	ibatterton
TANKFARM	SUB	SUB	5747-002	CONNECTOR	08/29/2018 16:21:09	ibatterton
TANKFARM	SUB	SUB	5748-000	VALVE	08/29/2018 16:19:47	ibatterton
TANKFARM	SUB	SUB	5748-001	CONNECTOR	08/29/2018 16:21:51	ibatterton
TANKFARM	SUB	SUB	5748-002	CONNECTOR	08/29/2018 16:21:52	ibatterton
TANKFARM	SUB	SUB	5749-000	VALVE	08/29/2018 16:24:29	ibatterton
TANKFARM	SUB	SUB	5749-001	CONNECTOR	08/29/2018 16:26:03	ibatterton
TANKFARM	SUB	SUB	5749-002	CONNECTOR	08/29/2018 16:26:04	ibatterton
TANKFARM	SUB	SUB	5749-003	CONNECTOR	08/29/2018 16:26:05	ibatterton
TANKFARM	SUB	SUB	5749-004	CONNECTOR	08/29/2018 16:26:06	ibatterton
TANKFARM	SUB	SUB	5749-005	CONNECTOR	08/29/2018 16:26:07	ibatterton
TANKFARM	SUB	SUB	5749-006	CONNECTOR	08/29/2018 16:26:07	ibatterton
TANKFARM	SUB	SUB	5749-007	CONNECTOR	08/29/2018 16:26:08	ibatterton
TANKFARM	SUB	SUB	5749-008	CONNECTOR	08/29/2018 16:26:08	ibatterton
TANKFARM	SUB	SUB	5749-009	CONNECTOR	08/29/2018 16:26:09	ibatterton
TANKFARM	SUB	SUB	5749-010	CONNECTOR	08/29/2018 16:26:10	ibatterton
TANKFARM	SUB	SUB	5749-011	CONNECTOR	08/29/2018 16:26:11	ibatterton
TANKFARM	SUB	SUB	5750-000	VALVE	08/29/2018 16:24:49	ibatterton
TANKFARM	SUB	SUB	5750-001	CONNECTOR	08/29/2018 16:28:04	ibatterton
TANKFARM	SUB	SUB	5750-002	CONNECTOR	08/29/2018 16:28:05	ibatterton
TANKFARM	SUB	SUB	5750-003	CONNECTOR	08/29/2018 16:28:05	ibatterton
TANKFARM	SUB	SUB	5750-004	CONNECTOR	08/29/2018 16:28:06	ibatterton
TANKFARM	SUB	SUB	5751-000	VALVE	08/29/2018 16:25:11	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5751-001	CONNECTOR	08/29/2018 16:29:12	ibatterton
TANKFARM	SUB	SUB	5751-002	CONNECTOR	08/29/2018 16:29:12	ibatterton
TANKFARM	SUB	SUB	5752-000	VALVE	08/29/2018 16:25:25	ibatterton
TANKFARM	SUB	SUB	5752-001	CONNECTOR	08/29/2018 16:29:42	ibatterton
TANKFARM	SUB	SUB	5753-000	VALVE	08/29/2018 16:30:34	ibatterton
TANKFARM	SUB	SUB	5753-001	CONNECTOR	08/29/2018 16:31:51	ibatterton
TANKFARM	SUB	SUB	5753-002	CONNECTOR	08/29/2018 16:31:52	ibatterton
TANKFARM	SUB	SUB	5753-003	CONNECTOR	08/29/2018 16:31:53	ibatterton
TANKFARM	SUB	SUB	5754-000	VALVE	08/29/2018 16:31:00	ibatterton
TANKFARM	SUB	SUB	5754-001	CONNECTOR	08/29/2018 16:32:24	ibatterton
TANKFARM	SUB	SUB	5754-002	CONNECTOR	08/29/2018 16:32:25	ibatterton
TANKFARM	SUB	SUB	5755-000	VALVE	08/29/2018 16:31:12	ibatterton
TANKFARM	SUB	SUB	5755-001	CONNECTOR	08/29/2018 16:33:03	ibatterton
TANKFARM	SUB	SUB	5756-000	VALVE	08/29/2018 16:31:26	ibatterton
TANKFARM	SUB	SUB	5757-000	VALVE	08/29/2018 16:34:41	ibatterton
TANKFARM	SUB	SUB	5757-001	CONNECTOR	08/29/2018 16:35:57	ibatterton
TANKFARM	SUB	SUB	5757-002	CONNECTOR	08/29/2018 16:35:58	ibatterton
TANKFARM	SUB	SUB	5758-000	VALVE	08/29/2018 16:35:07	ibatterton
TANKFARM	SUB	SUB	5758-001	CONNECTOR	08/29/2018 16:37:22	ibatterton
TANKFARM	SUB	SUB	5758-002	CONNECTOR	08/29/2018 16:37:23	ibatterton
TANKFARM	SUB	SUB	5759-000	VALVE	08/29/2018 16:35:24	ibatterton
TANKFARM	SUB	SUB	5759-001	CONNECTOR	08/29/2018 16:37:49	ibatterton
TANKFARM	SUB	SUB	5760-000	VALVE	08/29/2018 16:38:47	ibatterton
TANKFARM	SUB	SUB	5760-001	CONNECTOR	08/29/2018 16:40:46	ibatterton
TANKFARM	SUB	SUB	5760-002	CONNECTOR	08/29/2018 16:40:47	ibatterton
TANKFARM	SUB	SUB	5760-003	CONNECTOR	08/29/2018 16:40:47	ibatterton
TANKFARM	SUB	SUB	5760-004	CONNECTOR	08/29/2018 16:40:48	ibatterton
TANKFARM	SUB	SUB	5760-005	CONNECTOR	08/29/2018 16:40:49	ibatterton
TANKFARM	SUB	SUB	5760-006	CONNECTOR	08/29/2018 16:40:49	ibatterton
TANKFARM	SUB	SUB	5761-000	PUMP	08/29/2018 16:40:25	ibatterton
TANKFARM	SUB	SUB	5762-000	VALVE	08/29/2018 16:42:10	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5762-001	CONNECTOR	08/29/2018 16:47:11	ibatterton
TANKFARM	SUB	SUB	5762-002	CONNECTOR	08/29/2018 16:47:12	ibatterton
TANKFARM	SUB	SUB	5763-000	VALVE	08/29/2018 16:42:39	ibatterton
TANKFARM	SUB	SUB	5763-001	CONNECTOR	08/29/2018 16:48:06	ibatterton
TANKFARM	SUB	SUB	5764-000	VALVE	08/29/2018 16:44:05	ibatterton
TANKFARM	SUB	SUB	5764-001	CONNECTOR	08/29/2018 16:45:14	ibatterton
TANKFARM	SUB	SUB	5764-002	CONNECTOR	08/29/2018 16:45:15	ibatterton
TANKFARM	SUB	SUB	5764-003	CONNECTOR	08/29/2018 16:45:16	ibatterton
TANKFARM	SUB	SUB	5765-000	VALVE	08/29/2018 16:44:19	ibatterton
TANKFARM	SUB	SUB	5766-000	VALVE	08/29/2018 16:44:29	ibatterton
TANKFARM	SUB	SUB	5766-001	CONNECTOR	08/29/2018 16:46:14	ibatterton
TANKFARM	SUB	SUB	5766-002	CONNECTOR	08/29/2018 16:46:15	ibatterton
TANKFARM	SUB	SUB	5766-003	CONNECTOR	08/29/2018 16:46:16	ibatterton
TANKFARM	SUB	SUB	5766-004	CONNECTOR	08/29/2018 16:46:16	ibatterton
TANKFARM	SUB	SUB	5767-000	VALVE	08/29/2018 16:50:23	ibatterton
TANKFARM	SUB	SUB	5767-001	CONNECTOR	08/29/2018 16:51:03	ibatterton
TANKFARM	SUB	SUB	5767-002	CONNECTOR	08/29/2018 16:51:03	ibatterton
TANKFARM	SUB	SUB	5768-000	VALVE	08/29/2018 16:50:39	ibatterton
TANKFARM	SUB	SUB	5768-001	CONNECTOR	08/29/2018 16:51:47	ibatterton
TANKFARM	SUB	SUB	5769-000	VALVE	08/29/2018 16:52:36	ibatterton
TANKFARM	SUB	SUB	5769-001	CONNECTOR	08/29/2018 16:54:28	ibatterton
TANKFARM	SUB	SUB	5769-002	CONNECTOR	08/29/2018 16:54:29	ibatterton
TANKFARM	SUB	SUB	5770-000	VALVE	08/29/2018 16:52:50	ibatterton
TANKFARM	SUB	SUB	5770-001	CONNECTOR	08/29/2018 16:54:53	ibatterton
TANKFARM	SUB	SUB	5770-002	CONNECTOR	08/29/2018 16:54:54	ibatterton
TANKFARM	SUB	SUB	5771-000	VALVE	08/29/2018 16:53:42	ibatterton
TANKFARM	SUB	SUB	5771-001	CONNECTOR	08/29/2018 16:55:32	ibatterton
TANKFARM	SUB	SUB	5771-002	CONNECTOR	08/29/2018 16:55:33	ibatterton
TANKFARM	SUB	SUB	5772-000	VALVE	08/29/2018 16:54:05	ibatterton
TANKFARM	SUB	SUB	5772-001	CONNECTOR	08/29/2018 16:55:55	ibatterton
TANKFARM	SUB	SUB	5772-002	CONNECTOR	08/29/2018 16:55:56	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5773-000	VALVE	08/29/2018 16:56:58	ibatterton
TANKFARM	SUB	SUB	5773-001	CONNECTOR	08/29/2018 16:57:57	ibatterton
TANKFARM	SUB	SUB	5774-000	VALVE	08/29/2018 16:57:21	ibatterton
TANKFARM	SUB	SUB	5775-000	VALVE	08/29/2018 16:58:59	ibatterton
TANKFARM	SUB	SUB	5775-001	CONNECTOR	08/29/2018 17:00:44	ibatterton
TANKFARM	SUB	SUB	5775-002	CONNECTOR	08/29/2018 17:00:44	ibatterton
TANKFARM	SUB	SUB	5775-003	CONNECTOR	08/29/2018 17:00:45	ibatterton
TANKFARM	SUB	SUB	5776-000	VALVE	08/29/2018 16:59:33	ibatterton
TANKFARM	SUB	SUB	5776-001	CONNECTOR	08/29/2018 17:01:03	ibatterton
TANKFARM	SUB	SUB	5777-000	VALVE	08/29/2018 16:59:54	ibatterton
TANKFARM	SUB	SUB	5778-000	VALVE	08/29/2018 17:00:10	ibatterton
TANKFARM	SUB	SUB	5778-001	CONNECTOR	08/29/2018 17:01:31	ibatterton
TANKFARM	SUB	SUB	5779-000	VALVE	08/29/2018 17:02:04	ibatterton
TANKFARM	SUB	SUB	5779-001	CONNECTOR	08/29/2018 17:02:28	ibatterton
TANKFARM	SUB	SUB	5779-002	CONNECTOR	08/29/2018 17:02:28	ibatterton
TANKFARM	SUB	SUB	5780-000	VALVE	08/29/2018 17:03:28	ibatterton
TANKFARM	SUB	SUB	5780-001	CONNECTOR	08/29/2018 17:03:28	ibatterton
TANKFARM	SUB	SUB	5780-002	CONNECTOR	08/29/2018 17:03:29	ibatterton
TANKFARM	SUB	SUB	5781-000	VALVE	08/29/2018 17:04:21	ibatterton
TANKFARM	SUB	SUB	5781-001	CONNECTOR	08/29/2018 17:05:31	ibatterton
TANKFARM	SUB	SUB	5781-002	CONNECTOR	08/29/2018 17:05:32	ibatterton
TANKFARM	SUB	SUB	5782-000	VALVE	08/29/2018 17:04:39	ibatterton
TANKFARM	SUB	SUB	5782-001	CONNECTOR	08/29/2018 17:05:51	ibatterton
TANKFARM	SUB	SUB	5782-002	CONNECTOR	08/29/2018 17:05:52	ibatterton
TANKFARM	SUB	SUB	5783-000	VALVE	08/29/2018 17:04:51	ibatterton
TANKFARM	SUB	SUB	5783-001	CONNECTOR	08/29/2018 17:06:32	ibatterton
TANKFARM	SUB	SUB	5784-000	VALVE	08/29/2018 17:05:08	ibatterton
TANKFARM	SUB	SUB	5784-001	CONNECTOR	08/29/2018 17:07:03	ibatterton
TANKFARM	SUB	SUB	5784-002	CONNECTOR	08/29/2018 17:07:04	ibatterton
TANKFARM	SUB	SUB	5785-000	VALVE	08/29/2018 17:08:03	ibatterton
TANKFARM	SUB	SUB	5785-001	CONNECTOR	08/29/2018 17:09:15	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5785-002	CONNECTOR	08/29/2018 17:09:15	ibatterton
TANKFARM	SUB	SUB	5785-003	CONNECTOR	08/29/2018 17:09:16	ibatterton
TANKFARM	SUB	SUB	5786-000	VALVE	08/29/2018 17:08:23	ibatterton
TANKFARM	SUB	SUB	5787-000	VALVE	08/29/2018 17:08:35	ibatterton
TANKFARM	SUB	SUB	5787-001	CONNECTOR	08/29/2018 17:11:27	ibatterton
TANKFARM	SUB	SUB	5787-002	CONNECTOR	08/29/2018 17:11:28	ibatterton
TANKFARM	SUB	SUB	5787-003	CONNECTOR	08/29/2018 17:11:29	ibatterton
TANKFARM	SUB	SUB	5788-000	VALVE	08/29/2018 17:12:22	ibatterton
TANKFARM	SUB	SUB	5788-001	CONNECTOR	08/29/2018 17:12:45	ibatterton
TANKFARM	SUB	SUB	5789-000	VALVE	08/29/2018 17:13:24	ibatterton
TANKFARM	SUB	SUB	5789-001	CONNECTOR	08/29/2018 17:13:46	ibatterton
TANKFARM	SUB	SUB	5789-002	CONNECTOR	08/29/2018 17:13:47	ibatterton
TANKFARM	SUB	SUB	5789-003	CONNECTOR	08/29/2018 17:13:48	ibatterton
TANKFARM	SUB	SUB	5789-004	CONNECTOR	08/29/2018 17:13:48	ibatterton
TANKFARM	SUB	SUB	5789-005	CONNECTOR	08/29/2018 17:13:49	ibatterton
TANKFARM	SUB	SUB	5789-006	CONNECTOR	08/29/2018 17:13:49	ibatterton
TANKFARM	SUB	SUB	5790-000	PUMP	08/29/2018 17:15:20	ibatterton
TANKFARM	SUB	SUB	5790-001	CONNECTOR	08/29/2018 17:17:33	ibatterton
TANKFARM	SUB	SUB	5790-002	CONNECTOR	08/29/2018 17:17:34	ibatterton
TANKFARM	SUB	SUB	5790-003	CONNECTOR	08/29/2018 17:17:55	ibatterton
TANKFARM	SUB	SUB	5790-004	CONNECTOR	08/29/2018 17:18:22	ibatterton
TANKFARM	SUB	SUB	5790-005	CONNECTOR	08/29/2018 17:18:53	ibatterton
TANKFARM	SUB	SUB	5790-006	CONNECTOR	08/29/2018 17:18:54	ibatterton
TANKFARM	SUB	SUB	5790-007	CONNECTOR	08/29/2018 17:18:54	ibatterton
TANKFARM	SUB	SUB	5790-008	CONNECTOR	08/29/2018 17:18:55	ibatterton
TANKFARM	SUB	SUB	5790-009	CONNECTOR	08/29/2018 17:18:55	ibatterton
TANKFARM	SUB	SUB	5790-010	CONNECTOR	08/29/2018 17:18:56	ibatterton
TANKFARM	SUB	SUB	5790-011	CONNECTOR	08/29/2018 17:18:57	ibatterton
TANKFARM	SUB	SUB	5790-012	CONNECTOR	08/29/2018 17:18:57	ibatterton
TANKFARM	SUB	SUB	5790-013	CONNECTOR	08/29/2018 17:18:58	ibatterton
TANKFARM	SUB	SUB	5791-000	VALVE	08/29/2018 17:16:12	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5791-001	CONNECTOR	08/29/2018 17:20:57	ibatterton
TANKFARM	SUB	SUB	5792-000	VALVE	08/29/2018 17:16:33	ibatterton
TANKFARM	SUB	SUB	5792-001	CONNECTOR	08/29/2018 17:21:28	ibatterton
TANKFARM	SUB	SUB	5792-002	CONNECTOR	08/29/2018 17:21:28	ibatterton
TANKFARM	SUB	SUB	5793-000	VALVE	08/29/2018 17:16:49	ibatterton
TANKFARM	SUB	SUB	5793-001	CONNECTOR	08/29/2018 17:21:59	ibatterton
TANKFARM	SUB	SUB	5793-002	CONNECTOR	08/29/2018 17:22:00	ibatterton
TANKFARM	SUB	SUB	5794-000	VALVE	08/29/2018 17:22:32	ibatterton
TANKFARM	SUB	SUB	5795-000	VALVE	08/29/2018 17:22:42	ibatterton
TANKFARM	SUB	SUB	5795-001	CONNECTOR	08/29/2018 17:23:02	ibatterton
TANKFARM	SUB	SUB	5796-000	VALVE	08/29/2018 17:23:26	ibatterton
TANKFARM	SUB	SUB	5796-001	CONNECTOR	08/29/2018 17:24:04	ibatterton
TANKFARM	SUB	SUB	5796-002	CONNECTOR	08/29/2018 17:24:05	ibatterton
TANKFARM	SUB	SUB	5797-000	VALVE	08/29/2018 17:23:43	ibatterton
TANKFARM	SUB	SUB	5797-001	CONNECTOR	08/29/2018 17:24:29	ibatterton
TANKFARM	SUB	SUB	5797-002	CONNECTOR	08/29/2018 17:24:30	ibatterton
TANKFARM	SUB	SUB	5797-003	CONNECTOR	08/29/2018 17:24:31	ibatterton
TANKFARM	SUB	SUB	5798-000	VALVE	08/29/2018 17:25:26	ibatterton
TANKFARM	SUB	SUB	5798-001	CONNECTOR	08/29/2018 17:27:01	ibatterton
TANKFARM	SUB	SUB	5798-002	CONNECTOR	08/29/2018 17:27:01	ibatterton
TANKFARM	SUB	SUB	5799-000	VALVE	08/29/2018 17:25:36	ibatterton
TANKFARM	SUB	SUB	5799-001	CONNECTOR	08/29/2018 17:27:19	ibatterton
TANKFARM	SUB	SUB	5799-002	CONNECTOR	08/29/2018 17:27:20	ibatterton
TANKFARM	SUB	SUB	5800-000	VALVE	08/29/2018 17:25:48	ibatterton
TANKFARM	SUB	SUB	5800-001	CONNECTOR	08/29/2018 17:27:52	ibatterton
TANKFARM	SUB	SUB	5800-002	CONNECTOR	08/29/2018 17:27:53	ibatterton
TANKFARM	SUB	SUB	5800-003	CONNECTOR	08/29/2018 17:27:53	ibatterton
TANKFARM	SUB	SUB	5800-004	CONNECTOR	08/29/2018 17:27:54	ibatterton
TANKFARM	SUB	SUB	5801-000	VALVE	08/29/2018 17:26:02	ibatterton
TANKFARM	SUB	SUB	5801-001	CONNECTOR	08/29/2018 17:29:18	ibatterton
TANKFARM	SUB	SUB	5801-002	CONNECTOR	08/29/2018 17:29:18	ibatterton

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5801-003	CONNECTOR	08/29/2018 17:29:19	ibatterton
TANKFARM	SUB	SUB	5801-004	CONNECTOR	08/29/2018 17:29:20	ibatterton
TANKFARM	SUB	SUB	5801-005	CONNECTOR	08/29/2018 17:29:21	ibatterton
TANKFARM	SUB	SUB	5801-006	CONNECTOR	08/29/2018 17:29:21	ibatterton
TANKFARM	SUB	SUB	5801-007	CONNECTOR	08/29/2018 17:29:22	ibatterton
TANKFARM	SUB	SUB	5801-008	CONNECTOR	08/29/2018 17:29:22	ibatterton
TANKFARM	SUB	SUB	5801-009	CONNECTOR	08/29/2018 17:29:23	ibatterton
TANKFARM	SUB	SUB	5801-010	CONNECTOR	08/29/2018 17:29:24	ibatterton
TANKFARM	SUB	SUB	5801-011	CONNECTOR	08/29/2018 17:29:24	ibatterton
TANKFARM	SUB	SUB	5802-000	VALVE	08/30/2018 15:35:21	dhiggins
TANKFARM	SUB	SUB	5802-001	CONNECTOR	08/30/2018 15:35:36	dhiggins
TANKFARM	SUB	SUB	5802-002	CONNECTOR	08/30/2018 15:35:36	dhiggins
TANKFARM	SUB	SUB	5803-000	VALVE	08/30/2018 15:25:19	dhiggins
TANKFARM	SUB	SUB	5803-001	CONNECTOR	08/30/2018 15:35:55	dhiggins
TANKFARM	SUB	SUB	5803-002	CONNECTOR	08/30/2018 15:35:56	dhiggins
TANKFARM	SUB	SUB	5804-000	VALVE	08/30/2018 15:27:28	dhiggins
TANKFARM	SUB	SUB	5804-001	CONNECTOR	08/30/2018 15:36:35	dhiggins
TANKFARM	SUB	SUB	5804-002	CONNECTOR	08/30/2018 15:36:35	dhiggins
TANKFARM	SUB	SUB	5805-000	VALVE	08/30/2018 15:28:58	dhiggins
TANKFARM	SUB	SUB	5806-000	CONNECTOR	08/30/2018 15:28:10	dhiggins
TANKFARM	SUB	SUB	5807-000	VALVE	08/30/2018 15:29:36	dhiggins
TANKFARM	SUB	SUB	5807-001	CONNECTOR	08/30/2018 15:37:05	dhiggins
TANKFARM	SUB	SUB	5807-002	CONNECTOR	08/30/2018 15:37:06	dhiggins
TANKFARM	SUB	SUB	5808-000	VALVE	08/30/2018 15:29:48	dhiggins
TANKFARM	SUB	SUB	5808-001	CONNECTOR	08/30/2018 15:37:49	dhiggins
TANKFARM	SUB	SUB	5808-002	CONNECTOR	08/30/2018 15:37:50	dhiggins
TANKFARM	SUB	SUB	5808-003	CONNECTOR	08/30/2018 15:38:04	dhiggins
TANKFARM	SUB	SUB	5808-004	CONNECTOR	08/30/2018 15:38:05	dhiggins
TANKFARM	SUB	SUB	5808-005	CONNECTOR	08/30/2018 15:38:06	dhiggins
TANKFARM	SUB	SUB	5808-006	CONNECTOR	08/30/2018 15:38:06	dhiggins
TANKFARM	SUB	SUB	5808-007	CONNECTOR	08/30/2018 15:38:07	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5809-000	VALVE	08/30/2018 15:30:02	dhiggins
TANKFARM	SUB	SUB	5809-001	CONNECTOR	08/30/2018 15:38:47	dhiggins
TANKFARM	SUB	SUB	5809-002	CONNECTOR	08/30/2018 15:38:49	dhiggins
TANKFARM	SUB	SUB	5810-000	PRESS RELIEF DEVICE	08/30/2018 15:30:21	dhiggins
TANKFARM	SUB	SUB	5810-001	CONNECTOR	08/30/2018 15:39:05	dhiggins
TANKFARM	SUB	SUB	5810-002	CONNECTOR	08/30/2018 15:39:05	dhiggins
TANKFARM	SUB	SUB	5811-000	VALVE	08/30/2018 15:30:37	dhiggins
TANKFARM	SUB	SUB	5811-001	CONNECTOR	08/30/2018 15:39:26	dhiggins
TANKFARM	SUB	SUB	5811-002	CONNECTOR	08/30/2018 15:39:27	dhiggins
TANKFARM	SUB	SUB	5812-000	VALVE	08/30/2018 15:30:48	dhiggins
TANKFARM	SUB	SUB	5812-001	CONNECTOR	08/30/2018 15:39:57	dhiggins
TANKFARM	SUB	SUB	5812-002	CONNECTOR	08/30/2018 15:39:58	dhiggins
TANKFARM	SUB	SUB	5813-000	VALVE	08/30/2018 15:30:58	dhiggins
TANKFARM	SUB	SUB	5813-001	CONNECTOR	08/30/2018 15:40:51	dhiggins
TANKFARM	SUB	SUB	5813-002	CONNECTOR	08/30/2018 15:40:51	dhiggins
TANKFARM	SUB	SUB	5814-000	VALVE	08/30/2018 15:31:10	dhiggins
TANKFARM	SUB	SUB	5815-000	VALVE	08/30/2018 15:31:21	dhiggins
TANKFARM	SUB	SUB	5816-000	VALVE	08/30/2018 15:31:34	dhiggins
TANKFARM	SUB	SUB	5816-001	CONNECTOR	08/30/2018 15:41:14	dhiggins
TANKFARM	SUB	SUB	5816-002	CONNECTOR	08/30/2018 15:41:14	dhiggins
TANKFARM	SUB	SUB	5817-000	VALVE	08/30/2018 15:31:48	dhiggins
TANKFARM	SUB	SUB	5817-001	CONNECTOR	08/30/2018 15:41:55	dhiggins
TANKFARM	SUB	SUB	5817-002	CONNECTOR	08/30/2018 15:41:56	dhiggins
TANKFARM	SUB	SUB	5818-000	VALVE	08/30/2018 15:32:05	dhiggins
TANKFARM	SUB	SUB	5818-001	CONNECTOR	08/30/2018 15:43:26	dhiggins
TANKFARM	SUB	SUB	5818-002	CONNECTOR	08/30/2018 15:43:27	dhiggins
TANKFARM	SUB	SUB	5819-000	VALVE	08/30/2018 15:32:23	dhiggins
TANKFARM	SUB	SUB	5819-001	CONNECTOR	08/30/2018 15:43:44	dhiggins
TANKFARM	SUB	SUB	5819-002	CONNECTOR	08/30/2018 15:43:45	dhiggins
TANKFARM	SUB	SUB	5820-000	VALVE	08/30/2018 15:32:38	dhiggins
TANKFARM	SUB	SUB	5821-000	VALVE	08/30/2018 15:33:04	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5821-001	CONNECTOR	08/30/2018 15:44:03	dhiggins
TANKFARM	SUB	SUB	5821-002	CONNECTOR	08/30/2018 15:44:04	dhiggins
TANKFARM	SUB	SUB	5822-000	VALVE	08/30/2018 15:33:14	dhiggins
TANKFARM	SUB	SUB	5822-001	CONNECTOR	08/30/2018 15:44:48	dhiggins
TANKFARM	SUB	SUB	5822-002	CONNECTOR	08/30/2018 15:44:49	dhiggins
TANKFARM	SUB	SUB	5823-000	VALVE	08/30/2018 15:33:54	dhiggins
TANKFARM	SUB	SUB	5823-001	CONNECTOR	08/30/2018 15:45:13	dhiggins
TANKFARM	SUB	SUB	5823-002	CONNECTOR	08/30/2018 15:45:13	dhiggins
TANKFARM	SUB	SUB	5823-003	CONNECTOR	08/30/2018 15:45:23	dhiggins
TANKFARM	SUB	SUB	5823-004	CONNECTOR	08/30/2018 15:45:25	dhiggins
TANKFARM	SUB	SUB	5823-005	CONNECTOR	08/30/2018 15:45:25	dhiggins
TANKFARM	SUB	SUB	5823-006	CONNECTOR	08/30/2018 15:45:26	dhiggins
TANKFARM	SUB	SUB	5823-007	CONNECTOR	08/30/2018 15:45:27	dhiggins
TANKFARM	SUB	SUB	5823-008	CONNECTOR	08/30/2018 15:45:27	dhiggins
TANKFARM	SUB	SUB	5823-009	CONNECTOR	08/30/2018 15:45:28	dhiggins
TANKFARM	SUB	SUB	5824-000	VALVE	08/30/2018 15:34:16	dhiggins
TANKFARM	SUB	SUB	5824-001	CONNECTOR	08/30/2018 15:46:05	dhiggins
TANKFARM	SUB	SUB	5824-002	CONNECTOR	08/30/2018 15:46:07	dhiggins
TANKFARM	SUB	SUB	5825-000	VALVE	08/30/2018 15:34:32	dhiggins
TANKFARM	SUB	SUB	5825-001	CONNECTOR	08/30/2018 15:46:33	dhiggins
TANKFARM	SUB	SUB	5825-002	CONNECTOR	08/30/2018 15:46:34	dhiggins
TANKFARM	SUB	SUB	5826-000	VALVE	08/30/2018 15:47:43	dhiggins
TANKFARM	SUB	SUB	5826-001	CONNECTOR	08/30/2018 15:48:23	dhiggins
TANKFARM	SUB	SUB	5826-002	CONNECTOR	08/30/2018 15:48:24	dhiggins
TANKFARM	SUB	SUB	5827-000	VALVE	08/30/2018 15:47:53	dhiggins
TANKFARM	SUB	SUB	5827-001	CONNECTOR	08/30/2018 15:49:28	dhiggins
TANKFARM	SUB	SUB	5827-002	CONNECTOR	08/30/2018 15:49:29	dhiggins
TANKFARM	SUB	SUB	5828-000	VALVE	08/31/2018 12:43:05	dhiggins
TANKFARM	SUB	SUB	5828-001	CONNECTOR	08/31/2018 12:43:20	dhiggins
TANKFARM	SUB	SUB	5828-002	CONNECTOR	08/31/2018 12:43:21	dhiggins
TANKFARM	SUB	SUB	5829-000	VALVE	08/31/2018 12:46:38	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5829-001	CONNECTOR	08/31/2018 13:07:18	dhiggins
TANKFARM	SUB	SUB	5829-002	CONNECTOR	08/31/2018 13:07:18	dhiggins
TANKFARM	SUB	SUB	5830-000	VALVE	08/31/2018 12:46:49	dhiggins
TANKFARM	SUB	SUB	5830-001	CONNECTOR	08/31/2018 13:07:47	dhiggins
TANKFARM	SUB	SUB	5830-002	CONNECTOR	08/31/2018 13:07:48	dhiggins
TANKFARM	SUB	SUB	5831-000	VALVE	08/31/2018 12:46:59	dhiggins
TANKFARM	SUB	SUB	5831-001	CONNECTOR	08/31/2018 13:08:10	dhiggins
TANKFARM	SUB	SUB	5831-002	CONNECTOR	08/31/2018 13:08:11	dhiggins
TANKFARM	SUB	SUB	5832-000	PRESS RELIEF DEVICE	08/31/2018 12:47:14	dhiggins
TANKFARM	SUB	SUB	5832-001	CONNECTOR	08/31/2018 13:08:41	dhiggins
TANKFARM	SUB	SUB	5832-002	CONNECTOR	08/31/2018 13:08:42	dhiggins
TANKFARM	SUB	SUB	5833-000	VALVE	08/31/2018 12:47:27	dhiggins
TANKFARM	SUB	SUB	5833-001	CONNECTOR	08/31/2018 13:09:02	dhiggins
TANKFARM	SUB	SUB	5833-002	CONNECTOR	08/31/2018 13:09:02	dhiggins
TANKFARM	SUB	SUB	5834-000	VALVE	08/31/2018 12:47:41	dhiggins
TANKFARM	SUB	SUB	5835-000	VALVE	08/31/2018 12:48:14	dhiggins
TANKFARM	SUB	SUB	5835-001	CONNECTOR	08/31/2018 13:09:38	dhiggins
TANKFARM	SUB	SUB	5835-002	CONNECTOR	08/31/2018 13:09:40	dhiggins
TANKFARM	SUB	SUB	5836-000	VALVE	08/31/2018 12:48:26	dhiggins
TANKFARM	SUB	SUB	5836-001	CONNECTOR	08/31/2018 13:09:56	dhiggins
TANKFARM	SUB	SUB	5836-002	CONNECTOR	08/31/2018 13:09:57	dhiggins
TANKFARM	SUB	SUB	5837-000	VALVE	08/31/2018 12:49:03	dhiggins
TANKFARM	SUB	SUB	5837-001	CONNECTOR	08/31/2018 13:10:13	dhiggins
TANKFARM	SUB	SUB	5837-002	CONNECTOR	08/31/2018 13:10:15	dhiggins
TANKFARM	SUB	SUB	5838-000	VALVE	08/31/2018 12:49:14	dhiggins
TANKFARM	SUB	SUB	5838-001	CONNECTOR	08/31/2018 13:10:41	dhiggins
TANKFARM	SUB	SUB	5838-002	CONNECTOR	08/31/2018 13:10:41	dhiggins
TANKFARM	SUB	SUB	5839-000	VALVE	08/31/2018 12:49:25	dhiggins
TANKFARM	SUB	SUB	5839-001	CONNECTOR	08/31/2018 13:10:58	dhiggins
TANKFARM	SUB	SUB	5839-002	CONNECTOR	08/31/2018 13:10:59	dhiggins
TANKFARM	SUB	SUB	5840-000	VALVE	08/31/2018 12:49:48	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5840-001	CONNECTOR	08/31/2018 13:11:20	dhiggins
TANKFARM	SUB	SUB	5840-002	CONNECTOR	08/31/2018 13:11:21	dhiggins
TANKFARM	SUB	SUB	5840-003	CONNECTOR	08/31/2018 13:11:32	dhiggins
TANKFARM	SUB	SUB	5840-004	CONNECTOR	08/31/2018 13:11:34	dhiggins
TANKFARM	SUB	SUB	5841-000	CONNECTOR	08/31/2018 12:50:13	dhiggins
TANKFARM	SUB	SUB	5842-000	VALVE	08/31/2018 12:50:27	dhiggins
TANKFARM	SUB	SUB	5842-001	CONNECTOR	08/31/2018 13:11:52	dhiggins
TANKFARM	SUB	SUB	5842-002	CONNECTOR	08/31/2018 13:11:54	dhiggins
TANKFARM	SUB	SUB	5842-003	CONNECTOR	08/31/2018 13:12:10	dhiggins
TANKFARM	SUB	SUB	5842-004	CONNECTOR	08/31/2018 13:12:11	dhiggins
TANKFARM	SUB	SUB	5843-000	VALVE	08/31/2018 12:50:42	dhiggins
TANKFARM	SUB	SUB	5843-001	CONNECTOR	08/31/2018 13:12:27	dhiggins
TANKFARM	SUB	SUB	5843-002	CONNECTOR	08/31/2018 13:12:28	dhiggins
TANKFARM	SUB	SUB	5844-000	VALVE	08/31/2018 12:50:51	dhiggins
TANKFARM	SUB	SUB	5844-001	CONNECTOR	08/31/2018 13:12:44	dhiggins
TANKFARM	SUB	SUB	5844-002	CONNECTOR	08/31/2018 13:12:45	dhiggins
TANKFARM	SUB	SUB	5845-000	VALVE	08/31/2018 12:51:05	dhiggins
TANKFARM	SUB	SUB	5845-001	CONNECTOR	08/31/2018 13:13:09	dhiggins
TANKFARM	SUB	SUB	5845-002	CONNECTOR	08/31/2018 13:13:11	dhiggins
TANKFARM	SUB	SUB	5846-000	VALVE	08/31/2018 12:51:19	dhiggins
TANKFARM	SUB	SUB	5846-001	CONNECTOR	08/31/2018 13:13:31	dhiggins
TANKFARM	SUB	SUB	5846-002	CONNECTOR	08/31/2018 13:13:33	dhiggins
TANKFARM	SUB	SUB	5847-000	PRESS RELIEF DEVICE	08/31/2018 12:51:35	dhiggins
TANKFARM	SUB	SUB	5847-001	CONNECTOR	08/31/2018 13:14:01	dhiggins
TANKFARM	SUB	SUB	5847-002	CONNECTOR	08/31/2018 13:14:03	dhiggins
TANKFARM	SUB	SUB	5848-000	VALVE	08/31/2018 12:51:54	dhiggins
TANKFARM	SUB	SUB	5848-001	CONNECTOR	08/31/2018 13:14:37	dhiggins
TANKFARM	SUB	SUB	5848-002	CONNECTOR	08/31/2018 13:14:39	dhiggins
TANKFARM	SUB	SUB	5849-000	VALVE	08/31/2018 12:52:05	dhiggins
TANKFARM	SUB	SUB	5849-001	CONNECTOR	08/31/2018 13:15:11	dhiggins
TANKFARM	SUB	SUB	5849-002	CONNECTOR	08/31/2018 13:15:13	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5850-000	VALVE	08/31/2018 12:52:33	dhiggins
TANKFARM	SUB	SUB	5851-000	VALVE	08/31/2018 12:52:52	dhiggins
TANKFARM	SUB	SUB	5851-001	CONNECTOR	08/31/2018 13:15:37	dhiggins
TANKFARM	SUB	SUB	5851-002	CONNECTOR	08/31/2018 13:15:38	dhiggins
TANKFARM	SUB	SUB	5852-000	VALVE	08/31/2018 12:53:02	dhiggins
TANKFARM	SUB	SUB	5852-001	CONNECTOR	08/31/2018 13:15:59	dhiggins
TANKFARM	SUB	SUB	5852-002	CONNECTOR	08/31/2018 13:16:00	dhiggins
TANKFARM	SUB	SUB	5853-000	VALVE	08/31/2018 12:53:14	dhiggins
TANKFARM	SUB	SUB	5853-001	CONNECTOR	08/31/2018 13:16:26	dhiggins
TANKFARM	SUB	SUB	5853-002	CONNECTOR	08/31/2018 13:16:26	dhiggins
TANKFARM	SUB	SUB	5854-000	VALVE	08/31/2018 12:53:44	dhiggins
TANKFARM	SUB	SUB	5855-000	VALVE	08/31/2018 12:53:52	dhiggins
TANKFARM	SUB	SUB	5856-000	VALVE	08/31/2018 12:54:07	dhiggins
TANKFARM	SUB	SUB	5856-001	CONNECTOR	08/31/2018 13:17:02	dhiggins
TANKFARM	SUB	SUB	5856-002	CONNECTOR	08/31/2018 13:17:02	dhiggins
TANKFARM	SUB	SUB	5857-000	VALVE	08/31/2018 12:54:16	dhiggins
TANKFARM	SUB	SUB	5857-001	CONNECTOR	08/31/2018 13:17:30	dhiggins
TANKFARM	SUB	SUB	5857-002	CONNECTOR	08/31/2018 13:17:30	dhiggins
TANKFARM	SUB	SUB	5858-000	VALVE	08/31/2018 12:54:27	dhiggins
TANKFARM	SUB	SUB	5858-001	CONNECTOR	08/31/2018 13:17:58	dhiggins
TANKFARM	SUB	SUB	5858-002	CONNECTOR	08/31/2018 13:17:58	dhiggins
TANKFARM	SUB	SUB	5859-000	VALVE	08/31/2018 12:54:37	dhiggins
TANKFARM	SUB	SUB	5859-001	CONNECTOR	08/31/2018 13:18:22	dhiggins
TANKFARM	SUB	SUB	5859-002	CONNECTOR	08/31/2018 13:18:24	dhiggins
TANKFARM	SUB	SUB	5860-000	VALVE	08/31/2018 12:54:48	dhiggins
TANKFARM	SUB	SUB	5860-001	CONNECTOR	08/31/2018 13:19:06	dhiggins
TANKFARM	SUB	SUB	5860-002	CONNECTOR	08/31/2018 13:19:06	dhiggins
TANKFARM	SUB	SUB	5861-000	VALVE	08/31/2018 12:54:57	dhiggins
TANKFARM	SUB	SUB	5861-001	CONNECTOR	08/31/2018 13:19:32	dhiggins
TANKFARM	SUB	SUB	5861-002	CONNECTOR	08/31/2018 13:19:33	dhiggins
TANKFARM	SUB	SUB	5862-000	VALVE	08/31/2018 12:55:06	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5862-001	CONNECTOR	08/31/2018 13:19:57	dhiggins
TANKFARM	SUB	SUB	5862-002	CONNECTOR	08/31/2018 13:19:58	dhiggins
TANKFARM	SUB	SUB	5863-000	CONNECTOR	08/31/2018 12:55:17	dhiggins
TANKFARM	SUB	SUB	5864-000	VALVE	08/31/2018 12:55:28	dhiggins
TANKFARM	SUB	SUB	5864-001	CONNECTOR	08/31/2018 13:21:20	dhiggins
TANKFARM	SUB	SUB	5864-002	CONNECTOR	08/31/2018 13:21:21	dhiggins
TANKFARM	SUB	SUB	5865-000	VALVE	08/31/2018 12:55:39	dhiggins
TANKFARM	SUB	SUB	5865-001	CONNECTOR	08/31/2018 13:21:56	dhiggins
TANKFARM	SUB	SUB	5865-002	CONNECTOR	08/31/2018 13:21:57	dhiggins
TANKFARM	SUB	SUB	5866-000	VALVE	08/31/2018 12:55:57	dhiggins
TANKFARM	SUB	SUB	5866-001	CONNECTOR	08/31/2018 13:22:29	dhiggins
TANKFARM	SUB	SUB	5866-002	CONNECTOR	08/31/2018 13:22:30	dhiggins
TANKFARM	SUB	SUB	5867-000	VALVE	08/31/2018 12:56:06	dhiggins
TANKFARM	SUB	SUB	5867-001	CONNECTOR	08/31/2018 13:22:48	dhiggins
TANKFARM	SUB	SUB	5867-002	CONNECTOR	08/31/2018 13:22:49	dhiggins
TANKFARM	SUB	SUB	5868-000	VALVE	08/31/2018 12:56:15	dhiggins
TANKFARM	SUB	SUB	5868-001	CONNECTOR	08/31/2018 13:23:05	dhiggins
TANKFARM	SUB	SUB	5868-002	CONNECTOR	08/31/2018 13:23:05	dhiggins
TANKFARM	SUB	SUB	5869-000	VALVE	08/31/2018 12:56:24	dhiggins
TANKFARM	SUB	SUB	5869-001	CONNECTOR	08/31/2018 13:23:22	dhiggins
TANKFARM	SUB	SUB	5869-002	CONNECTOR	08/31/2018 13:23:23	dhiggins
TANKFARM	SUB	SUB	5870-000	VALVE	08/31/2018 12:56:35	dhiggins
TANKFARM	SUB	SUB	5870-001	CONNECTOR	08/31/2018 13:23:41	dhiggins
TANKFARM	SUB	SUB	5870-002	CONNECTOR	08/31/2018 13:23:41	dhiggins
TANKFARM	SUB	SUB	5871-000	VALVE	08/31/2018 12:57:33	dhiggins
TANKFARM	SUB	SUB	5871-001	CONNECTOR	08/31/2018 13:23:59	dhiggins
TANKFARM	SUB	SUB	5871-002	CONNECTOR	08/31/2018 13:24:00	dhiggins
TANKFARM	SUB	SUB	5872-000	VALVE	08/31/2018 12:57:43	dhiggins
TANKFARM	SUB	SUB	5872-001	CONNECTOR	08/31/2018 13:24:19	dhiggins
TANKFARM	SUB	SUB	5872-002	CONNECTOR	08/31/2018 13:24:20	dhiggins
TANKFARM	SUB	SUB	5873-000	VALVE	08/31/2018 12:57:52	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5873-001	CONNECTOR	08/31/2018 13:24:38	dhiggins
TANKFARM	SUB	SUB	5873-002	CONNECTOR	08/31/2018 13:24:39	dhiggins
TANKFARM	SUB	SUB	5874-000	VALVE	08/31/2018 12:58:02	dhiggins
TANKFARM	SUB	SUB	5874-001	CONNECTOR	08/31/2018 13:25:01	dhiggins
TANKFARM	SUB	SUB	5874-002	CONNECTOR	08/31/2018 13:25:02	dhiggins
TANKFARM	SUB	SUB	5875-000	VALVE	08/31/2018 12:58:12	dhiggins
TANKFARM	SUB	SUB	5875-001	CONNECTOR	08/31/2018 13:25:38	dhiggins
TANKFARM	SUB	SUB	5875-002	CONNECTOR	08/31/2018 13:25:39	dhiggins
TANKFARM	SUB	SUB	5876-000	VALVE	08/31/2018 12:58:26	dhiggins
TANKFARM	SUB	SUB	5876-001	CONNECTOR	08/31/2018 13:26:03	dhiggins
TANKFARM	SUB	SUB	5876-002	CONNECTOR	08/31/2018 13:26:04	dhiggins
TANKFARM	SUB	SUB	5877-000	VALVE	08/31/2018 12:58:36	dhiggins
TANKFARM	SUB	SUB	5877-001	CONNECTOR	08/31/2018 13:26:21	dhiggins
TANKFARM	SUB	SUB	5877-002	CONNECTOR	08/31/2018 13:26:21	dhiggins
TANKFARM	SUB	SUB	5878-000	VALVE	08/31/2018 12:58:51	dhiggins
TANKFARM	SUB	SUB	5878-001	CONNECTOR	08/31/2018 13:26:41	dhiggins
TANKFARM	SUB	SUB	5878-002	CONNECTOR	08/31/2018 13:26:42	dhiggins
TANKFARM	SUB	SUB	5878-003	CONNECTOR	08/31/2018 13:26:43	dhiggins
TANKFARM	SUB	SUB	5879-000	VALVE	08/31/2018 12:59:06	dhiggins
TANKFARM	SUB	SUB	5879-001	CONNECTOR	08/31/2018 13:27:02	dhiggins
TANKFARM	SUB	SUB	5879-002	CONNECTOR	08/31/2018 13:27:02	dhiggins
TANKFARM	SUB	SUB	5880-000	VALVE	08/31/2018 12:59:35	dhiggins
TANKFARM	SUB	SUB	5880-001	CONNECTOR	08/31/2018 13:27:21	dhiggins
TANKFARM	SUB	SUB	5880-002	CONNECTOR	08/31/2018 13:27:22	dhiggins
TANKFARM	SUB	SUB	5881-000	VALVE	08/31/2018 12:59:57	dhiggins
TANKFARM	SUB	SUB	5881-001	CONNECTOR	08/31/2018 13:27:38	dhiggins
TANKFARM	SUB	SUB	5881-002	CONNECTOR	08/31/2018 13:27:39	dhiggins
TANKFARM	SUB	SUB	5882-000	VALVE	08/31/2018 13:00:07	dhiggins
TANKFARM	SUB	SUB	5882-001	CONNECTOR	08/31/2018 13:28:16	dhiggins
TANKFARM	SUB	SUB	5882-002	CONNECTOR	08/31/2018 13:28:16	dhiggins
TANKFARM	SUB	SUB	5883-000	VALVE	08/31/2018 13:00:27	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5883-001	CONNECTOR	08/31/2018 13:28:36	dhiggins
TANKFARM	SUB	SUB	5883-002	CONNECTOR	08/31/2018 13:28:37	dhiggins
TANKFARM	SUB	SUB	5884-000	VALVE	08/31/2018 13:00:42	dhiggins
TANKFARM	SUB	SUB	5884-001	CONNECTOR	08/31/2018 13:29:00	dhiggins
TANKFARM	SUB	SUB	5884-002	CONNECTOR	08/31/2018 13:29:01	dhiggins
TANKFARM	SUB	SUB	5885-000	VALVE	08/31/2018 13:00:55	dhiggins
TANKFARM	SUB	SUB	5885-001	CONNECTOR	08/31/2018 13:29:22	dhiggins
TANKFARM	SUB	SUB	5885-002	CONNECTOR	08/31/2018 13:29:23	dhiggins
TANKFARM	SUB	SUB	5886-000	VALVE	08/31/2018 13:01:16	dhiggins
TANKFARM	SUB	SUB	5886-001	CONNECTOR	08/31/2018 13:29:40	dhiggins
TANKFARM	SUB	SUB	5886-002	CONNECTOR	08/31/2018 13:29:40	dhiggins
TANKFARM	SUB	SUB	5887-000	VALVE	08/31/2018 13:31:03	dhiggins
TANKFARM	SUB	SUB	5887-001	CONNECTOR	08/31/2018 13:31:17	dhiggins
TANKFARM	SUB	SUB	5887-002	CONNECTOR	08/31/2018 13:31:17	dhiggins
TANKFARM	SUB	SUB	5888-000	VALVE	08/31/2018 13:02:21	dhiggins
TANKFARM	SUB	SUB	5888-001	CONNECTOR	08/31/2018 13:31:39	dhiggins
TANKFARM	SUB	SUB	5888-002	CONNECTOR	08/31/2018 13:31:39	dhiggins
TANKFARM	SUB	SUB	5889-000	VALVE	08/31/2018 13:01:51	dhiggins
TANKFARM	SUB	SUB	5889-001	CONNECTOR	08/31/2018 13:31:57	dhiggins
TANKFARM	SUB	SUB	5889-002	CONNECTOR	08/31/2018 13:31:58	dhiggins
TANKFARM	SUB	SUB	5890-000	VALVE	08/31/2018 13:02:49	dhiggins
TANKFARM	SUB	SUB	5890-001	CONNECTOR	08/31/2018 13:32:20	dhiggins
TANKFARM	SUB	SUB	5890-002	CONNECTOR	08/31/2018 13:32:21	dhiggins
TANKFARM	SUB	SUB	5891-000	VALVE	08/31/2018 13:03:07	dhiggins
TANKFARM	SUB	SUB	5891-001	CONNECTOR	08/31/2018 13:32:48	dhiggins
TANKFARM	SUB	SUB	5891-002	CONNECTOR	08/31/2018 13:32:49	dhiggins
TANKFARM	SUB	SUB	5892-000	VALVE	08/31/2018 13:03:24	dhiggins
TANKFARM	SUB	SUB	5892-001	CONNECTOR	08/31/2018 13:33:29	dhiggins
TANKFARM	SUB	SUB	5892-002	CONNECTOR	08/31/2018 13:33:30	dhiggins
TANKFARM	SUB	SUB	5893-000	VALVE	08/31/2018 13:03:33	dhiggins
TANKFARM	SUB	SUB	5893-001	CONNECTOR	08/31/2018 13:33:51	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5893-002	CONNECTOR	08/31/2018 13:33:51	dhiggins
TANKFARM	SUB	SUB	5894-000	VALVE	08/31/2018 13:03:49	dhiggins
TANKFARM	SUB	SUB	5894-001	CONNECTOR	08/31/2018 13:34:08	dhiggins
TANKFARM	SUB	SUB	5894-002	CONNECTOR	08/31/2018 13:34:09	dhiggins
TANKFARM	SUB	SUB	5895-000	VALVE	08/31/2018 13:04:05	dhiggins
TANKFARM	SUB	SUB	5895-001	CONNECTOR	08/31/2018 13:34:24	dhiggins
TANKFARM	SUB	SUB	5895-002	CONNECTOR	08/31/2018 13:34:25	dhiggins
TANKFARM	SUB	SUB	5896-000	VALVE	08/31/2018 13:04:17	dhiggins
TANKFARM	SUB	SUB	5896-001	CONNECTOR	08/31/2018 13:34:48	dhiggins
TANKFARM	SUB	SUB	5896-002	CONNECTOR	08/31/2018 13:34:49	dhiggins
TANKFARM	SUB	SUB	5897-000	VALVE	08/31/2018 13:04:47	dhiggins
TANKFARM	SUB	SUB	5897-001	CONNECTOR	08/31/2018 13:35:09	dhiggins
TANKFARM	SUB	SUB	5897-002	CONNECTOR	08/31/2018 13:35:10	dhiggins
TANKFARM	SUB	SUB	5898-000	VALVE	08/31/2018 13:04:57	dhiggins
TANKFARM	SUB	SUB	5898-001	CONNECTOR	08/31/2018 13:35:26	dhiggins
TANKFARM	SUB	SUB	5898-002	CONNECTOR	08/31/2018 13:35:26	dhiggins
TANKFARM	SUB	SUB	5899-000	VALVE	08/31/2018 13:05:16	dhiggins
TANKFARM	SUB	SUB	5899-001	CONNECTOR	08/31/2018 13:35:41	dhiggins
TANKFARM	SUB	SUB	5899-002	CONNECTOR	08/31/2018 13:35:42	dhiggins
TANKFARM	SUB	SUB	5900-000	VALVE	08/31/2018 13:05:34	dhiggins
TANKFARM	SUB	SUB	5900-001	CONNECTOR	08/31/2018 13:38:02	dhiggins
TANKFARM	SUB	SUB	5900-002	CONNECTOR	08/31/2018 13:38:04	dhiggins
TANKFARM	SUB	SUB	5901-000	VALVE	08/31/2018 13:36:11	dhiggins
TANKFARM	SUB	SUB	5901-001	CONNECTOR	08/31/2018 13:38:21	dhiggins
TANKFARM	SUB	SUB	5901-002	CONNECTOR	08/31/2018 13:38:21	dhiggins
TANKFARM	SUB	SUB	5902-000	VALVE	08/31/2018 13:36:36	dhiggins
TANKFARM	SUB	SUB	5902-001	CONNECTOR	08/31/2018 13:38:39	dhiggins
TANKFARM	SUB	SUB	5902-002	CONNECTOR	08/31/2018 13:38:40	dhiggins
TANKFARM	SUB	SUB	5903-000	PRESS RELIEF DEVICE	08/31/2018 13:36:52	dhiggins
TANKFARM	SUB	SUB	5903-001	CONNECTOR	08/31/2018 13:39:12	dhiggins
TANKFARM	SUB	SUB	5903-002	CONNECTOR	08/31/2018 13:39:13	dhiggins

Added Components Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

Unit:	Area:	Equipment:	Tag:	Component Type:	Date Added:	Added By:
TANKFARM	SUB	SUB	5904-000	VALVE	08/31/2018 13:37:20	dhiggins
TANKFARM	SUB	SUB	5904-001	CONNECTOR	08/31/2018 13:39:40	dhiggins
TANKFARM	SUB	SUB	5904-002	CONNECTOR	08/31/2018 13:39:41	dhiggins
TANKFARM	SUB	SUB	5905-000	VALVE	08/31/2018 13:37:38	dhiggins
TANKFARM	SUB	SUB	5905-001	CONNECTOR	08/31/2018 13:39:59	dhiggins
TANKFARM	SUB	SUB	5905-002	CONNECTOR	08/31/2018 13:40:01	dhiggins

Total Number of Added Components: 781

This report was generated using a filter:

Rule Name is equal to NSPS OOOOa And
(Unit is equal to CONDENSATE PIPELINE Or
Unit is equal to NORTH INLET Or
Unit is equal to TANK FARM)

Repair Delay Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

NSPS OOOOa

Unit: NORTH INLET

Area Code	Equipment	Tag	DOR Reason	Component Type	Leak Source		DOR Start Date
SUB	SUB	4333-000	SHUTDOWN REQ FOR REPAIR OR RPL	VALVE	PACKING		03/21/2018
Monitor Date	**Reading**	**Location Description**		**Authorized By:**	**Size**	**Exp Shutdown Date**	**DOR End Date**
03/21/2018	4462	W SIDE OF F-0114 @ LCV-0114B LOOP		CHRIS JAHRAUS	3	03/21/2019	07/30/2018
Area Code	**Equipment**	**Tag**	**DOR Reason**	**Component Type**	**Leak Source**		**DOR Start Date**
SUB	SUB	4364-000	SHUTDOWN REQ FOR REPAIR OR RPL	VALVE	PACKING		03/21/2018
Monitor Date	**Reading**	**Location Description**		**Authorized By:**	**Size**	**Exp Shutdown Date**	**DOR End Date**
03/21/2018	7090	E SIDE BELOW F-0114		CHRIS JAHRAUS	1	03/21/2019	
Area Code	**Equipment**	**Tag**	**DOR Reason**	**Component Type**	**Leak Source**		**DOR Start Date**
SUB	SUB	5671-000	SHUTDOWN REQ FOR REPAIR OR RPL	VALVE	PACKING		03/22/2018
Monitor Date	**Reading**	**Location Description**		**Authorized By:**	**Size**	**Exp Shutdown Date**	**DOR End Date**
03/22/2018	91600	R-5 RECEIVER E OF CONTROL RM		CHRIS JAHRAUS	1	03/22/2019	
Area Code	**Equipment**	**Tag**	**DOR Reason**	**Component Type**	**Leak Source**		**DOR Start Date**
SUB	SUB	4347-000	SHUTDOWN REQ FOR REPAIR OR RPL	CONNECTOR	MANWAY		06/27/2018
Monitor Date	**Reading**	**Location Description**		**Authorized By:**	**Size**	**Exp Shutdown Date**	**DOR End Date**
06/27/2018	16100	NW SIDE OF F-0114		CHRIS JAHRAUS	58	06/27/2019	
Area Code	**Equipment**	**Tag**	**DOR Reason**	**Component Type**	**Leak Source**		**DOR Start Date**
SUB	SUB	4456-000	SHUTDOWN REQ FOR REPAIR OR RPL	CONNECTOR	MANWAY		09/19/2018
Monitor Date	**Reading**	**Location Description**		**Authorized By:**	**Size**	**Exp Shutdown Date**	**DOR End Date**
09/19/2018	37400	N SIDE OF F-0104 ON PLATFORM		CHRIS JAHRAUS	58	09/19/2019	
Area Code	**Equipment**	**Tag**	**DOR Reason**	**Component Type**	**Leak Source**		**DOR Start Date**
SUB	SUB	4672-000	SHUTDOWN REQ FOR REPAIR OR RPL	VALVE	FLANGE		09/20/2018
Monitor Date	**Reading**	**Location Description**		**Authorized By:**	**Size**	**Exp Shutdown Date**	**DOR End Date**
09/20/2018	608	R-1 RECEIVER INLET E OF CONTROL RM		CHRIS JAHRAUS	6	09/20/2019	12/10/2018

Unit Repair Delay Count: 6

Printed By: scsmith

Repair Delay Report

From: 7/1/2018 To: 12/31/2018

DCP Operating Company, L.P. - Mewbourn II

NSPS OOOOa

Unit: TANK FARM

Area Code	Equipment	Tag	DOR Reason	Component Type	Leak Source		DOR Start Date
SUB	SUB	5649-000	CANNOT SAFELY ISOLATE	VALVE	PACKING		12/10/2018
Monitor Date	**Reading**	**Location Description**		**Authorized By:**	**Size**	**Exp Shutdown Date**	**DOR End Date**
12/10/2018	24600	TOP OF TK-1A OH 20'Ft		CHRIS JAHRAUS	2	12/10/2019	

(b) (6) [redacted]

Unit Repair Delay Count: 1

Facility Repair Delay Count: 7

Signature of Owner or Operator
Responsible for Delay of Repair Decision

This report was generated using a filter:

Rule Name is equal to NSPS OOOOa And
(Unit is equal to CONDENSATE PIPELINE Or
Unit is equal to NORTH INLET Or
Unit is equal to TANK FARM)