IOWA DEPARTMENT OF NATURAL RESOURCES
NPDS REPORTING SYSTEM - DISCHARGE MONITORING REPORT
FACILITY INFORMATION

This form is valid 4/1/2015 to 3/31/2020

Facility Name: SIOUX CITY, CITY OF STP

Permit #: 9778001

Month/Year: 8 | 2017

Outfall #(s): 001 - DISCHARGE FROM AN ACTIVATED SLUDGE WASTEWATER TREATMENT PLANT.

Operator Name: James Maynes

Certification #: 6232

Phone #: 712-279-6916

Lab Cert. #: 323

Comments: E. coli sampled grabbed on 8/21 was rejected by ACS lab as contaminated, possibly due to sample bottle sodium thiosulfate issue, as our lab noticed no problem with the split sample. Sample taken on 8/22 sample was 45.0. Raw BOD on 8/5 lost due to dilution water issue. CBOD Prior to Disinfection on 8/30 missing from worksheet.

*Include Comments longer than 1000 characters in email

Signature:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibilityof fine and imprisonment for known violations.