IOWA DEPARTMENT OF NATURAL RESOURCES
NPDES REPORTING SYSTEM - MONTLHY OPERATION REPORT
FACILITY INFORMATION

Facility Name: SIOUX CITY, CITY OF STP

NPDES #: 9778001

Month/Year: 12 2016

OUTFALL #(s): IC-00 - 001 - DISCHARGE FROM AN ACTIVATED SLUDGE WASTEWATER TREA

Operator Name: James Maynes

Certification #: 6232

Phone #: 712-279-6113

Lab Certification #: 323

Comments: No Influent TBOD result for 12/8/2016. Lab staff were experimenting with the BOD program and efficiency, and we lost this plant result.

* Note the Comments holds 255 characters. For longer Comments please attach them to the E-mail

Signature:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.