THERMA-FLOW, INC.
COIL HYDRO TEST 450 P.S.I.
WORKING PRESSURE 150 P.S.I.
Mfg Date: 01/10
232-5
MODEL NO.
5
G.P.M.
Watertown, MA 02472
OUT
Do Not Remove This Card
U.S. FOIA (b)(6)
CHAIR CITY OIL & HEATING
525 MAIN STREET
GARDNER, MA 01440
(978) 632-4600
Equipment Service Record
DATE
REMARKS
TECH.
1965 AmStD A3 232-5 Coil
1st Coil Replacement 3/6/05
2nd Coil Replacement 6/4/06
3rd Coil Replacement 1/21/09
4th Coil Replacement 3/11/10
5th Coil Replacement 2/7/11
REORDER FROM DEGREE DAY SYSTEMS, INC 1-800-2DEGREE or e-mail: info@degreeday.com