UGI DEVELOPMENT CO.

UGI Development Company
390 Route 11
P.O. Box 224
Hunlock Creek, PA 18621-0224

(570) 542-5369 Telephone

January 4, 2011

RECEIVED
JAN 6 - 2011
DEPARTMENT OF
ENVIRONMENTAL PROTECTION

CERTIFIED MAIL NO.

Mr. Norman E. Frederick
PA Department of Environmental Protection
Northeast Regional Office
2 Public Square
Wilkes-Barre, PA 18711-0790

RE: UGI DEVELOPMENT COMPANY
HUNLOCK CREEK ENERGY CENTER
2010 ANNUAL COMPLIANCE CERTIFICATION

Dear Mr. Frederick,

UGI Development Company, Hunlock Creek Energy Center is submitting the 2010 Annual Compliance Certification Form. Hunlock Creek Energy Center's coal-fired Boiler No. 6 shut down permanently on May 22, 2010.

If you should have any questions or need additional information, please call me at (570) 542-5369, ext. 232.

Sincerely,

Jeffrey T. Steeber

Jeffrey T. Steeber
Health, Safety and Environmental Engineer
Hunlock Creek Energy Center

JTS:chet

UGI DEVELOPMENT CO.

UGI Development Company
390 Route 11
P.O. Box 224
Hunlock Creek, PA 18621-0224

(570) 542-5369 Telephone

January 4, 2011

CERTIFIED MAIL NO.

Mr. Norman E. Frederick
PA Department of Environmental Protection
Northeast Regional Office
2 Public Square
Wilkes-Barre, PA 18711-0790

RE: UGI DEVELOPMENT COMPANY
HUNLOCK CREEK ENERGY CENTER
2010 ANNUAL COMPLIANCE CERTIFICATION

Dear Mr. Frederick,

UGI Development Company, Hunlock Creek Energy Center is submitting the 2010 Annual Compliance Certification Form. Hunlock Creek Energy Center's coal-fired Boiler No. 6 shut down permanently on May 22, 2010.

If you should have any questions or need additional information, please call me at (570) 542-5369, ext. 232.

Sincerely,

Jeffrey T. Steeber

Jeffrey T. Steeber
Health, Safety and Environmental Engineer
Hunlock Creek Energy Center

JTS:chet

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF AIR QUALITY
COMPLIANCE CERTIFICATION FORM
(25 Pa. Code § 127.513)

Plant Name:	UGI DEVELOPMENT CO/HUNLOCK POWER STA	**Owner/Operator:**	UGI CORP
Tax ID/Plant:	23-1650159-1	**DEP Facility ID:**	284013
Contact Person:	~~DAVID R STEATHER~~ PETER M. QUATTRINI	**Title:**	MANAGER - POWER PRODUCTIO
Operating Permit #:	40-00005	**Phone Number:**	(570)~~890-1270~~ 542-5369

For the period **01/01/2010 - 12/31/2010**, **UGI DEVELOPMENT CO/HUNLOCK POWER STA** CREEK ENERGY CENTER has been in continuous compliance with all applicable requirements of permit # **40-00005**, determined by the method(s) of compliance specified in said permit, except for the following deviations, exceedances and excursions:

Sect./Cond. #	Citation #	Source	Noncompliance	Monitoring Method(s)	Date	Duration	Corrective Action(s)
Title V Permit 40-00005 Section B/ #004 (a)	25 Pa. Code 123.41 & 127.444	Boiler No. 6	Yes (OPacity Excursions)	Continuous Emission Monitoring System (CEMS).	2nd Quarter 2010	24 Days	Settlement Agreement.

Certification of Truth, Accuracy and Completeness

Subject to the penalties of Title 18 Pa. C.S. Section 4904 and 35 P.S. Section 4009 (b) (2), I certify under penalty of law that, based on information and belief formed after reasonable inquiry, the statements and information contained in this form are true, accurate, and complete.

Name:	Pete Quattrini	**Title:**	Manager - Power Production
Signed:		**Date:**	January 5, 2011

This certification must be signed by a responsible official. Any certification submitted without a valid signature will be returned. The owner/operator shall identify any other material information needed in this certification to also comply with section 113(c)(2) of the Clean Air Act. If more spaces are needed, complete additional pages using the format shown in Addendum 1. This certification does not replace requirements pertaining to the submission of malfunction and CEM reports. DO NOT include that information on this form.

PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF AIR QUALITY
COMPLIANCE CERTIFICATION FORM
(25 Pa. Code § 127.513)

ADDENDUM 1

For the period **00/00/0000 - 00/00/0000**, **UGI DEVELOPMENT CO/HUNLOCK POWER STA** has been in continuous compliance with all applicable requirements of permit # **40-00005**, determined by the method(s) of compliance specified in said permit, except for the following deviations, exceedances and excursions:

Sect./Cond. #	Citation #	Source	Noncompliance	Monitoring Method(s)	Date	Duration	Corrective Action(s)

Certification - . Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
[25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446(e) & 127.503] (Permit Renewal)	Section B	(a) An application for the renewal of the Title V permit shall be submitted to the Department at least six (6) months, and not more than 18 months, before the expiration date of this permit. The renewal application is timely if a complete application is submitted to the Department's Regional Air M...	Renewal Permit was submitted to PADEP. Waiting for approval.	☒Continuous ☐Intermittent
[25 Pa. Code § 127.513, 35 P.S. § 4008 and § 114 of the CAA] (Inspection and Entry)	Section B	(a) Upon presentation of credentials and other documents as may be required by law for inspection and entry purposes, the permittee shall allow the Department of Environmental Protection or authorized representatives of the Department to perform the following: (1) Enter at reasonable times upo...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 127.25, 127.444, & 127.512(c)(1)] (Compliance Requirements)	Section B	(a) The permittee shall comply with the conditions of this permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one (1) or more of the following: (1) Enforcement action (2) Permit termination, revocation...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☐Continuous ☒Intermittent
[25 Pa. Code §§ 127.411(d) & 127.512(c)(5)] (Duty to Provide Information)	Section B	(a) The permittee shall furnish to the Department, within a reasonable time, information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. (b) Upon request, the ...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code § 127.541] (Significant Operating Permit Modifications)	Section B	When permit modifications during the term of this permit do not qualify as minor permit modifications or administrative amendments, the permittee shall submit an application for significant Title V permit modifications in accordance with 25 Pa. Code § 127.541.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 127.704, 127.705 & 127.707] (Fee Payment)	Section B	(a) The permittee shall pay fees to the Department in accordance with the applicable fee schedules in 25 Pa. Code Chapter 127, Subchapter I (relating to plan approval and operating permit fees).	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Certificatic . Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
		(b) Emission Fees. The permittee shall, on or before September 1st of each year, pay applicable annual...		
[25 Pa. Code §§ 127.14(b) & 127.449] (Authorization for De Minimis Emission Increases)	Section B	(a) This permit authorizes de minimis emission increases from a new or existing source in accordance with 25 Pa. Code §§ 127.14 and 127.449 without the need for a plan approval or prior issuance of a permit modification. The permittee shall provide the Department with seven (7) days prior written ...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 127.11a & 127.215] (Reactivation of Sources)	Section B	(a) The permittee may reactivate a source at the facility that has been out of operation or production for at least one year, but less than or equal to five (5) years, if the source is reactivated in accordance with the requirements of 25 Pa. Code §§ 127.11a and 127.215. The reactivated source wil...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 121.9 & 127.216] (Circumvention)	Section B	(a) The owner of this Title V facility, or any other person, may not circumvent the new source review requirements of 25 Pa. Code Chapter 127, Subchapter E by causing or allowing a pattern of ownership or development, including the phasing, staging, delaying or engaging in incremental construction,...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 127.402(d) & 127.513(1)] (Submissions)	Section B	(a) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the: Regional Air Program Manager PA Department of Environmental Protection (At the address given on the permit transmittal letter, or otherwise notified) (b) Any repor...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 127.441(c) & 127.463(e); Chapter 139; & 114(a)(3), 504(b) of the CAA] (Sampling, Testing and Monitoring Procedures)	Section B	(a) The permittee shall perform the emissions monitoring and analysis procedures or test methods for applicable requirements of this Title V permit. In addition to the sampling, testing and monitoring procedures specified in this permit, the Permittee shall comply with any additional applicable re...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 127.511 & Chapter 135] (Recordkeeping	Section B	(a) The permittee shall maintain and make available, upon request by the Department, records of required monitoring information that include the following:	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Certificatio. . Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
Requirements)		(1) The date, place (as defined in the permit) and time of sampling or measurements. (2) The dates the analyses were performed. ...		
[25 Pa. Code §§ 127.411(d), 127.442, 127.463(e) & 127.511(c)] (Reporting Requirements)	Section B	(a) The permittee shall comply with the reporting requirements for the applicable requirements specified in this Title V permit. In addition to the reporting requirements specified herein, the permittee shall comply with any additional applicable reporting requirements promulgated under the Clean ...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code § 127.513] (Compliance Certification)	Section B	(a) One year after the date of issuance of the Title V permit, and each year thereafter, unless specified elsewhere in the permit, the permittee shall submit to the Department and EPA Region III a certificate of compliance with the terms and conditions in this permit, for the previous year, includi...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §§ 127.441(d), 127.512(i) and 40 CFR Part 68] (Risk Management)	Section B	(a) If required by Section 112(r) of the Clean Air Act, the permittee shall develop and implement an accidental release program consistent with requirements of the Clean Air Act, 40 CFR Part 68 (relating to chemical accident prevention provisions) and the Federal Chemical Safety Information, Site S...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §123.1] (Prohibition of certain fugitive emissions)	Section C - I. Restrictions - Emission Restriction(s)	The permittee may not permit the emission into the outdoor atmosphere of a fugitive air contaminant from a source other than the following: (a) Construction or demolition of buildings or structures. (b) Grading, paving and maintenance of roads and streets. (c) Use of roads and streets. Emissions fr...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §123.2] (Fugitive particulate matter)	Section C - I. Restrictions - Emission Restriction(s)	The permittee may not permit fugitive particulate matter to be emitted into the outdoor atmosphere from a source specified in Site Level condition #001 (relating to prohibition of certain fugitive emissions) if such emissions are visible at the point the emissions pass outside the person's property.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §123.31] (Limitations)	Section C - I. Restrictions - Emission Restriction(s)	MALODOR EMISSIONS The permittee may not permit the emission into the outdoor atmosphere of any malodorous air contaminants from any	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Certification . Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
		source in such a manner that the malodors are detectable outside the property of the person on whose land the source is being operated.		
[25 Pa. Code §123.41] (Limitations)	Section C - I. Restrictions - Emission Restriction(s)	VISIBLE EMISSIONS (a) The permittee may not permit the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following: (1) Equal to or greater than 20% for a period or periods aggregating more than three minu...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☐Continuous ☒Intermittent
[25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section C - II. Testing Requirements	All sampling, testing and analyses performed in compliance with the requirements of any section of this permit shall be done in accordance with General Title V Requirement #021.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section C - III. Monitoring Requirements	If requested by the Department, the permittee shall perform a stack test, in accordance with the provisions of the most current publication of the DEP Source Testing Manual and Chapter 139 of the Rules and Regulations of the Department of Environmental Protection, within the time frame specified by ...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section C - III. Monitoring Requirements	FUGITIVE, VISIBLE, AND MALODOR EMISSIONS The permittee shall conduct weekly inspections of the Hunlock Generating Station, during daylight hours when the plant is in operation, to detect visible, fugitive, and malodorous emissions (from sources not handled by the CEMs) as follows: (a) Visible emis...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section C - IV. Recordkeeping Requirements	FUGITIVE, VISIBLE, AND MALODOR EMISSIONS (a) The permittee shall, at the conclusion of each weekly inspection, record all occurances of fugitive, visible, or malodorous emissions which deviate from the limitations, Site Level Conditions #002, #003 and #004, in a log book. (b) The permittee shall r...	Weekly inspections are done. Roads are kept clean via sweeper truck/water, calcium is placed on dirt roads and fresh gravel is placed on dirt roadways.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
[25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section C - IV. Recordkeeping Requirements	All records, reports and analyses results generated in compliance with the requirements of any section of this permit shall be maintained in accordance with General Title V Requirement #022, Section (b), and shall be made available to the Department upon written or verbal request at a reasonable tim...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section C - V. Reporting Requirements	FUGITIVE, VISIBLE, AND MALODOR EMISSIONS (a) On a semi-annual basis, the permittee shall compile a report of all logged instances of deviation of the fugitive, visible, or malodor emission limitations that occured and the actions taken in response to them. This report shall be submitted to the Dep...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §123.1] (Prohibition of certain fugitive emissions)	Section C - VI. Work Practice Standards	The permittee shall take all reasonable actions to prevent particulate matter from becoming airborne. These actions shall include, but not be limited to, the following: (a) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §123.43] (Measuring techniques)	Section C - VI. Work Practice Standards	VISIBLE EMISSIONS Visible emissions may be measured using either of the following: (a) A device approved by the Department and maintained to provide accurate opacity measurements. (b) Observers, trained and qualified to measure plume opacity with the naked eye or with the aid of any dev...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
[25 Pa. Code §129.14] (Open burning operations)	Section C - VI. Work Practice Standards	Outside of air basins. (a) The permittee may not permit the open burning of material in an area outside of air basins in a manner that: (1) The emissions are visible, at any time, at the point such emissions pass outside the property of the person on whose land the open burning is ...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
[25 Pa. Code §127.531] (Special conditions related to acid rain.)	Section C - VII. Additional Requirements	Source 031 at the Hunlock Generating Station is an affected unit subject to Phase II acid rain requirements under Title IV of the Clean Air Act and 25 Pa. Code Section 127.531. The Department of Environmental Protection hereby issues and incorporates by reference into this Title V operating permit ...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §123.11] (Combustion units)	Section D - I. Restrictions - Emission Restriction(s)	The concentration of particulate matter (expressed as Total Suspended Particulate) in the emissions from Source 031 shall not exceed 0.1000 Pounds per Million BTU of Total Suspended Particulate.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §123.22] (Combustion units)	Section D - I. Restrictions - Emission Restriction(s)	The concentration of Sulfur Oxides (expressed as SO2) in the emissions from Source 031 shall not exceed the following limitations: (a) On a 30-day running average, the emissions shall not exceed 3.7000 Pounds per Million BTU of Sulfur Dioxide; (b) As a daily average, not to be exceeded on mor...	Certified CEMS monitors SO2 on a continuous basis. All SO2 emissions are reported to PADEP and EPA quarterly.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - I. Restrictions - Emission Restriction(s)	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The concentration of Nitrogen Oxides (NOx) in the emissions from Source 031 shall not, as a 30-day running average, exceed 0.6900 Pounds per Million BTU of Nitrogen Oxides.	Certified CEMS monitors Nox on a continuous basis. All Nox emissions are reported to PADEP and EPA quarterly.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §123.22] (Combustion units)	Section D - I. Restrictions - Fuel Restriction(s)	The concentration of dissolved sulfur in the #2 Fuel Oil combusted by these sources shall not exceed 0.50% Sulfur, by weight.	Fuel Oil is tested and supplier provides data that shows fuel oil meets the sulfur limits. All fuel oil analysis is submitted to PADEP quarterly.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - I. Restrictions - Fuel Restriction(s)	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The metallic contents of the waste fuel oil combusted in Source 031 may not exceed the following limitations: a) Arsenic: Acceptable Conc.= Less than 5 ppm Analytical Tech.- ...	Waste oil is tested, results are submitted to PADEP.	☒Continuous ☐Intermittent

Certification of Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - I. Restrictions - Fuel Restriction(s)	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The percent (%) by weight ash content of the waste oil to be combusted in Source 031 shall not exceed the level determined by the following equation: % Ash = 0.4*X / ---------- , where ...	Waste oil is tested, results are submitted to PADEP.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.444] (Compliance requirements.)	Section D - I. Restrictions - Fuel Restriction(s)	With the exception of the RACT allowance for the combustion of waste oils generated at the facility, only anthracite coal, bituminous coal, petroleum coke or #2 fuel oil may be combusted by this source.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - I. Restrictions - Operating Hours Restriction(s)	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The permittee shall limit the operation schedule of the double-arch furnace boiler #6 (Source 031) such that its total annual operating time does not to exceed 8,600 hours/year.	CEMS logs all hours of operation. All hours are reported to PADEP Quarterly.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - II. Testing Requirements	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The permittee shall perform a monthly analysis of the waste oil to be disposed of in this combustion unit. A representative sample of the oil shall be obtained and tested. The fuel characteristics to be determined shall...	Waste Oil is sampled prior to burning. All results are submitted to PADEP.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and	Section D - II. Testing Requirements	To demonstrate compliance with Source Level Condition #001, the permittee shall, on a daily basis, obtain a representative sample of the coal burned by this boiler to be analyzed for determination of the percent (%) ash content, by weight. The ash analysis of the coal shall be done in accordance wit...	Coal is sampled daily by trained personnel. Coal sampling analysis system (CSAS) is used to analyze coal.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
reporting requirements.)				
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - II. Testing Requirements	To demonstrate compliance with Source Group Level Condition #002, the permittee shall comply with the following requirements: (a) The permittee shall perform an analysis of each shipment of No. 2 Fuel Oil delivered to the Hunlock Power Station. A representative sample shall be obtained and tested....	Fuel Oil is sampled and tested. Results are submitted to PADEP.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - II. Testing Requirements	(a) The permittee shall maintain the Opacity analyzer in accordance with the Quality Assuarance and Performance Testing procedures specified in the most current publication of the DEP Continuous Source Monitoring Manual, and 25 Pa. Code, Chapter 139, Subchapter C (relating to requirements for contin...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 Elective Restriction ()	Section D - II. Testing Requirements	(a) The permittee shall perform an analysis of the flyash from this boiler to determine the concentration of Hazardous Air Pollutants (HAPs) on a semi-annual basis. (b) The permittee shall perform the testing for the HAP content of flyash by Module 25 Analysis with additional parameters, in accorda...	Fly Ash is sampled and tested semi-annually.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §123.25] (Monitoring requirements)	Section D - III. Monitoring Requirements	The permittee shall operate a Continuous Emission Monitor (CEM) that shall record the emission of sulfur oxides (expressed as SO2) from Source 031 on a minute-by-minute basis. The SO2 emission data shall be recorded in units of parts per million (ppm) and pounds per million Btu (lbs/MMBtu). This d...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §123.46] (Monitoring requirements)	Section D - III. Monitoring Requirements	The permittee shall operate a Continuous Emissions Monitor (CEM) that shall record the opacity of emissions from Source 031 on a minute-by-minute basis. This opacity data shall be maintained by the Data Acquisition and Handling System (DAHS) associated with the facility's CEM systems.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Certificatio... Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §123.51] (Monitoring requirements)	Section D - III. Monitoring Requirements	The permittee shall operate a Continuous Emission Monitor (CEM) that shall record the emission of nitrogen oxides (NOx) from Source 031 on a minute-by-minute basis. The NOx emission data shall be recorded in units of parts per million (ppm) and pounds per million Btu (lbs/MMBtu). This data shall b...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - III. Monitoring Requirements	The permittee shall, on a daily basis, monitor the hours of operation of the #6 boiler.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	The permittee shall record the results of each completed fuel oil analysis and any fuel characteristic certifications. These records, and the quantity of oil consumed by the boilers, shall be used in the calculation of sulfur emissions from the facility.	All fuel Oil analysis is submitted to PADEP. All Fuel Oil burned is recorded for each boiler and submitted to PADEP.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	The permittee shall record the results of each ash content analysis of the coal, as required by Source Level Condition #008. These records, and the quantity of fuel consumed, shall be used in the calculation of particulate emissions from the combustion of coal by this source.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and	Section D - IV. Recordkeeping Requirements	The permittee shall record data concerning Opacity, NOx and SO2 emissions, and Volumetric Air Flow on a minute-by-minute basis, and the data shall be maintained at the Station by the Data Acquisition and Handling System (DAHS) associated with the continuous emission monitoring systems.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
related recordkeeping and reporting requirements.)				
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The company shall maintain records in accordance with the recordkeeping requirements of 25 Pa. Code Section 129.95 and shall include as a minimum the following: (a) Data which clearly demonstrate that the heat input fo...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The company shall maintain records in accordance with the recordkeeping requirements of 25 Pa. Code, Section 129.95, and shall include, as a minimum, the following: (a) Data which clearly demonstrate that Source 031 ne...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 Elective Restriction ()	Section D - IV. Recordkeeping Requirements	The results of each completed analysis of HAPs in the flyash from this boiler shall be recorded, and shall be made available to the Department upon written or verbal request, at a reasonable time.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - V. Reporting Requirements	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] To demonstrate compliance with Source Level Conditions #004 and #005, the permittee shall adhere to the following reporting requirements: (a) Submit, on a quarterly basis, a report of the results of each waste oil...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code	Section D - V. Reporting Requirements	The permittee shall, on a quarterly basis, compile a report of the results of all fuel analyses (if any) and fuel characteristic certifications for No. 2 Fuel Oil delivered to the facility during the previous 3 months, to be submitted to the Department within	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
§127.511] (Monitoring and related recordkeeping and reporting requirements.)		thirty days of the close of each calenda...		
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - V. Reporting Requirements	To demonstrate compliance with Source Level Condition #007, the permittee shall, on an annual basis, compile all daily records of the hours of operation of the #6 boiler, from the previous twelve (12) months, into an Annual Operations Report. This report shall be submitted to the Department within ...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - V. Reporting Requirements	(a) At the close of each calendar quarter, the permittee shall submit to the Department the following Continuous Emissions Monitor (CEM) reports: (1) The permittee shall compile a Sulfur Oxide (SO2) Emission Report, from the SO2 CEM emission data collected during the three (3) prece...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - VI. Work Practice Standards	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] (a) The permittee is hereby authorized to dispose of waste oils, which are generated on the premises of the Hunlock Creek Station, by means of incineration in the No. 6 boiler. This authorization is conditional to the w...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
031 - FOSTER WHEELER BOILER #6 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - VI. Work Practice Standards	[Authority for this condition is also derived from 25 Pa. Code, Section 129.93] To optimize combustion efficiency, the permittee shall operate and maintain these sources in accordance with the manufacturer's specifications and good air pollution control practices.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER	Section D - I.	The concentration of particulate matter (expressed as TSP) in	Company Policy to comply	☒Continuous

Certificati . Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
BROOKS BOILER #8 [25 Pa. Code §123.11] (Combustion units)	Restrictions - Emission Restriction(s)	the emissions from this boiler shall not exceed 0.4000 Pounds per Million BTU of Total Suspended Particulate.	with all environmental regulations affecting Hunlock Station.	☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §123.22] (Combustion units)	Section D - I. Restrictions - Emission Restriction(s)	The concentration of sulfur oxides (expressed as SO2) in the emissions from this boiler shall not exceed 4.0000 Pounds per Million BTU of Sulfur Dioxide.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §123.22] (Combustion units)	Section D - I. Restrictions - Fuel Restriction(s)	The concentration of dissolved sulfur in the #2 Fuel Oil combusted by these sources shall not exceed 0.50% Sulfur, by weight.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.444] (Compliance requirements.)	Section D - I. Restrictions - Fuel Restriction(s)	This combustion unit shall only combust #2 distillate fuel oil.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - II. Testing Requirements	To demonstrate compliance with Source Group Level Condition #002, the permittee shall comply with the following requirements: (a) The permittee shall perform an analysis of each shipment of No. 2 Fuel Oil delivered to the Hunlock Power Station. A representative sample shall be obtained and tested....	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting	Section D - III. Monitoring Requirements	The permittee shall, on a daily basis, monitor the hours of operation of this boiler.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
requirements.)				
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	[Authorization for this condition is also derived from 25 Pa. Code, Section 129.93] (a) The permittee shall record each adjustment conducted under the procedures in Source Level Condition #007 in a permanently bound log book or other method approved by the Department. This log shall contain, at a m...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	The permittee shall record the results of each completed fuel oil analysis and any fuel characteristic certifications. These records, and the quantity of oil consumed by the boilers, shall be used in the calculation of sulfur emissions from the facility.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	The permittee shall keep records of the hours of operation of this boiler. This, with the records of the heating value, ash content and sulfur content of the #2 fuel oil, shall be used with EPA's AP-42 emission factors to determine compliance with Source Level Conditions #001 and #002.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The company shall maintain records in accordance with the recordkeeping requirements of 25 Pa. Code Section 129.95 and shall include as a minimum the following: (a) Data which clearly demonstrate that the heat input fo...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER	Section D - V. Reporting	The permittee shall, on a quarterly basis, compile a report of the results of all fuel analyses (if any) and fuel characteristic	Company Policy to comply with all environmental	☒Continuous ☐Intermittent

Certificati . Continuous or Intermittent Compliance
<<Permit>> - <<PF_Name>>

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
#8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Requirements	certifications for No. 2 Fuel Oil delivered to the facility during the previous 3 months, to be submitted to the Department within thirty days of the close of each calenda...	regulations affecting Hunlock Station.	
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - V. Reporting Requirements	To demonstrate compliance with the emission limitations of Source Level Condition #001 & #002, the permittee shall, on a quarterly basis, compile a Sulfur Dioxide (SO2) & Particulate Matter (PM) Emissions Report for operations during the three (3) preceding months. Using the data recorded in compli...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - VI. Work Practice Standards	[Authorization for this condition is also derived from 25 Pa. Code, Section 129.93] The permittee shall develop and implement the following practices to comply with presumptive RACT: (a) The performance of an annual adjustment or tuneup on the combustion process. This adjustment shall include...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
033 - CLEAVER BROOKS BOILER #8 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - VI. Work Practice Standards	[Authority for this condition is also derived from 25 Pa. Code, Section 129.93] To optimize combustion efficiency, the permittee shall operate and maintain these sources in accordance with the manufacturer's specifications and good air pollution control practices.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §123.11] (Combustion units)	Section D - I. Restrictions - Emission Restriction(s)	The concentration of particulate matter (expressed as TSP) in the emissions from this boiler shall not exceed 0.4000 Pounds per Million BTU of Total Suspended Particulate.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER	Section D - I. Restrictions -	The concentration of sulfur oxides (expressed as SO2) in the emissions from this boiler shall not exceed 4.0000 Pounds per	Company Policy to comply with all environmental	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
#7 [25 Pa. Code §123.22] (Combustion units)	Emission Restriction(s)	Million BTU of Sulfur Dioxide.	regulations affecting Hunlock Station.	
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §123.22] (Combustion units)	Section D - I. Restrictions - Fuel Restriction(s)	The concentration of dissolved sulfur in the #2 Fuel Oil combusted by these sources shall not exceed 0.50% Sulfur, by weight.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.444] (Compliance requirements.)	Section D - I. Restrictions - Fuel Restriction(s)	This combustion unit shall only combust #2 distillate fuel oil.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - II. Testing Requirements	To demonstrate compliance with Source Group Level Condition #002, the permittee shall comply with the following requirements: (a) The permittee shall perform an analysis of each shipment of No. 2 Fuel Oil delivered to the Hunlock Power Station. A representative sample shall be obtained and tested....	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - III. Monitoring Requirements	The permittee shall, on a daily basis, monitor the hours of operation of this boiler.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and	Section D - IV. Recordkeeping Requirements	[Authorization for this condition is also derived from 25 Pa. Code, Section 129.93] (a) The permittee shall record each adjustment conducted under the procedures in Source Level Condition #007 in a permanently bound log book or other method approved by the Department.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
related recordkeeping and reporting requirements.)		This log shall contain, at a m...		
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	The permittee shall record the results of each completed fuel oil analysis and any fuel characteristic certifications. These records, and the quantity of oil consumed by the boilers, shall be used in the calculation of sulfur emissions from the facility.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	The permittee shall keep records of the hours of operation of this boiler. This, with the records of the heating value, ash content and sulfur content of the #2 fuel oil, shall be used with EPA's AP-42 emission factors to determine compliance with Source Level Conditions #001 and #002.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - IV. Recordkeeping Requirements	[Authority for this condition is also derived from 25 Pa. Code, Section 129.92] The company shall maintain records in accordance with the recordkeeping requirements of 25 Pa. Code Section 129.95 and shall include as a minimum the following: (a) Data which clearly demonstrate that the heat input fo...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting	Section D - V. Reporting Requirements	The permittee shall, on a quarterly basis, compile a report of the results of all fuel analyses (if any) and fuel characteristic certifications for No. 2 Fuel Oil delivered to the facility during the previous 3 months, to be submitted to the Department within thirty days of the close of each calenda...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
requirements.)				
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.511] (Monitoring and related recordkeeping and reporting requirements.)	Section D - V. Reporting Requirements	To demonstrate compliance with the emission limitations of Source Level Condition #001 & #002, the permittee shall, on a quarterly basis, compile a Sulfur Dioxide (SO2) & Particulate Matter (PM) Emissions Report for operations during the three (3) preceding months. Using the data recorded in compli...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - VI. Work Practice Standards	[Authorization for this condition is also derived from 25 Pa. Code, Section 129.93] The permittee shall develop and implement the following practices to comply with presumptive RACT: (a) The performance of an annual adjustment or tuneup on the combustion process. This adjustment shall include...	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
034 - CLEAVER BROOKS BOILER #7 [25 Pa. Code §127.441] (Operating permit terms and conditions.)	Section D - VI. Work Practice Standards	[Authority for this condition is also derived from 25 Pa. Code, Section 129.93] To optimize combustion efficiency, the permittee shall operate and maintain these sources in accordance with the manufacturer's specifications and good air pollution control practices.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
M01 - FUGITIVE DUST PAVED RDS [25 Pa. Code §123.1] (Prohibition of certain fugitive emissions)	Section D - VI. Work Practice Standards	The permittee shall comply with the requirements of Site Level Conditions #001 & #002 by sweeping and watering down paved roads when conditions merit.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent
M02 - FUGITIVE DUST UNPAVED RDS [25 Pa. Code §123.1] (Prohibition of certain fugitive emissions)	Section D - VI. Work Practice Standards	The permittee shall comply with the requirements of Site Level Conditions #001 & #002 by placing gravel and calcium on unpaved roads as dust suppressants when conditions merit.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent

Citation	Permit Section	Terms & Conditions Contained in the Permit	Means of Determining Compliance Status	Compliance with Terms & Conditions was:
M03 - FUGITIVE DUST MATL TRANSF [25 Pa. Code §123.1] (Prohibition of certain fugitive emissions)	Section D - VI. Work Practice Standards	To comply with Site Level Conditions #001 & #002, the permitttee shall maintain partial enclosures around the coal conveyor system to minimize fugitive dusts.	Company Policy to comply with all environmental regulations affecting Hunlock Station.	☒Continuous ☐Intermittent