4 **Table ##. Summary of Compliance with Delta Chloride Objectives (1995 – 2014)**

	Objective [1, 2]		Exceedances of Objective		
Location	Applicable Period (and narrative description)	Days/ year [3]	Years (#) With Objective Exceeded	Maximum Days Exceeded	Median Days Exceeded [4]
Municipal and Industrial Water Supply Objectives					
CCF	Jan 1-Dec 31 mid Cl <= 250 mg/L	365	0	0	0
DMC @ Tracy PP	Jan 1-Dec 31 mid Cl <= 250 mg/L	365	0	0	0
CCC at PP#1	Jan 1-Dec 31 mid Cl <= 250 mg/L	365	4	7	2.5
CCC PP#1 or SJR @ Antioch Intake	Jan 1-Dec 31 Chloride (days <150 mg/L Cl varies by WY).	Varies by WY Type	0	0	0

Notes:
CCF = Clifton Court Forebay; DMC= Delta Mendota Canal; PP=Pumping Plant; CCC = Contra Costa Canal; PMI = previous month's Eight River Index

[1] This table also includes objectives/standards set by Water Rights Orders 95-6 and 98-6.

[2] Only partial description of objective provided; refer to Bay-Delta WQCP for full text of objective.

[3] Total number of days in year that requirement is applicable.

[4] Median calculated using only years when exceedances occurred.