To: Rao, Kate[Rao.kate@epa.gov]
Cc: Rumrill, Nancy[Rumrill.Nancy@epa.gov];
Shari.Ring@cadmusgroup.com[Shari.Ring@cadmusgroup.com]
From: JAMES D WALKER
Sent: Fri 8/18/2017 5:56:33 PM
Subject: Summary of call with Nancy Rumrill regarding the Gunnison Project draft permit on August 15

;;
Hi Kate,

The following topics were discussed and resolved during or following the call:

- The references to Attachment P of the permit application requires some clarification in Part II.F.2.c and F.3.b, and Attachment P should be corrected for the omission of the discussion of monitoring at observation and closure verification wells.

- Part II.F. 8 should be modified to include the provision for water elevation monitoring at intermediate monitoring wells.

- Part II.E.5 should be revised to correct the planned and estimated maximum injection rates to be consistent with the rates presented in Attachment H in the revised permit application. The planned average and estimated maximum injection rates were revised as requested.

- Financial Responsibility Closure Cost Estimates: Plugging and abandonment costs estimates for the POC wells in Attachment R-3 can be omitted since those costs will be covered by the ADEQ bonding requirements. Post closure monitoring costs at the observation wells should be added to Tables R3-10 nd 11 in Attachment R-3.

Nancy: Please feel free to amend or add to this summary.

If you have any questions or comments, please advise.

Thanks,

Jim