INDUSTRIAL WASTE INSPECTION REQUEST

Requestor/Group PHILIP ROBENIDL Date: 10-5-00 Permit No.: 5093
Acct. No.: 1196030
Dist. No.: 01
Fiscal Yr.: 2000-01

TO	FOR	INITIAL	DATE	COPY
Surcharge	Check	[illegible]	10/5/00	✓
Plan Eval.	Check	[illegible]	10/5/00	✓
Inspection Supv.	Assign	ASI	10-5	

PRIORITY
ASAP ✓
Soon
Routine

Inspector Name D. Sanchez S. Carr 10/5/00

Inspec. Supv. Accept ASI 10/16

Company Name SHULTZ STEEL CO.

Address 5321 E. Firestone Blvd. South Gate 90280 Situs ZIP

Contact Mc McCullough - (909) 453-0511 Matt McCullough Position Phone 909-453-0975
OR Peter Nash - (323) 357-3277

REASON FOR REQUEST: Co. was given a One-Time discharge permit to discharge up to 21,000 gal of wastewater from pressure washing of concrete and asphalt surfaces. The wastewater are contained in a Tank and will be discharged to the 1st stage clarifier (4000 gal). Please observe discharge operations as company was given vol., flow rate, and time restrictions (Item 3) of the reqt. list. Discharge to the sewer shld not exceed 20gpm. Must have at least 30 minutes retention time in clarifier.

ATTACHMENTS: One-time discharge permit

INSPECTION (DATE/RESULTS): 10/6/00 No discharge until after 5pm. Andrew Hockstra observed 5pm and off that evening. Large Baker Tank adjacent to clarifier contained approx. 13,000 gallons of WW from bike path cleanup per pumper. Discharge was to continue throughout the weekend. With discharge to clarifier, 30 minute retention time was assured.

Completed **ORIGINAL** to Permit File
Completed **GREEN** copy to Requestor
Completed **GOLD** copy to Inspection Supv.

IW LACSD
000000024137

Rev. 021291(e)