NPDES ID	Permit Name	Single Event Violation Desc	Single Event Violation Code	Curr. Perm. RNC Stat. Auto Desc	Single Event Start Date	Single Event Agency Type Desc	Single Event Violation Comment
IN0000094	ARCELORMITTAL STEEL USA INC - INDIANA HARBOR EAST	Effluent Violations - Numeric effluent violation	A0012	Non-RNC Violations	12/14/2016	State	Effluent Limits Compliance area rated unsatisfactory due to the following self-reported violations of the limits detailed in Part I. A. of the NPDES Permit; Feb. 2016 two Chlorine, one Zinc; Mar. 2016 one Chlorine, one Zinc; May 2016 two Chlorine.
IN0000205	ARCELORMITTAL INDIANA HARBOR LLC - INDIANA HARBOR WEST	Effluent Violations - Unapproved Bypass	A0011	RNC Violations Only	12/29/2014	State	Overflow/Bypasses was rated unsatisfactory due to ten bypasses reported from December 2014 through November 2014.
IN0000205	ARCELORMITTAL INDIANA HARBOR LLC - INDIANA HARBOR WEST	Monitoring Violations - Failure to Monitor for Toxicity Requirements	C0021	RNC Violations Only	06/30/2013	State	AreclorMittal failed to conduct whole effluent toxicity tests during the second quarter od 2013 as required by the NPDES permit
IN0000205	ARCELORMITTAL INDIANA HARBOR LLC - INDIANA HARBOR WEST	Reporting Violations - Failure to submit required report (non-DMR non-pretreatment)	E0016	RNC Violations Only	12/29/2014	State	The Effluent Limits Compliance area was rated unsatisfactory self-reported violations of the limits detailed in Part I of the NPDES permit.
2		Count:					