Exhibit 10

ND Dept. of Health Emission Inventory Summary Year: **2014**

| | | | |
|---|---|---|---|
| Company: | **Otter Tail Power Company** | AIRS/AFS Source Code: | 38-057-00012 |
| PTO Number: | T5-F84011 | Annual Permit Fee Billing: | YES |
| Unit or Station | Coyote Station | Reviewed By: | JDM |

**Individual Emission Sources**

| EUI | Source Unit | Fuel | PM | PM10 | PM2.5 | CPM | SO2 | NOX | CO | VOC |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Unit 1 Boiler | Coal | 192.8 | 183.1 | 13.5 | 322.0 | 12777.1 | 11370.2 | 674.5 | 78.7 |
| | | Oil #2 | 0.4 | 0.4 | | | 0.0 | 4.3 | 0.9 | 0.0 |
| | | Used Oil | 0.0 | 0.0 | | | 0.0 | 0.2 | 0.0 | 0.0 |
| 2 | Auxiliary Boiler | Oil #2 | 0.2 | 0.2 | | | 0.0 | 2.2 | 0.5 | 0.0 |
| 4 | Waukesha Diesel 1440 Hp - Generator | Diesel | | | | | | 0.2 | | |
| 5 | Cummins Diesel 225 Hp - Fire Pump | Diesel | | | | | | 0.1 | | |
| 6 | Kohler Diesel 1375 Hp - Scrubber Generator | Diesel | | | | | | 0.3 | 0.1 | |
| M2-M8 | Miscellaneous | N/A | 33.8 | 33.8 | 33.8 | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | | | | | | | | | |
| | | - | | | | | | | | |
| | Total Facility Emissions (Less HAPS) | | 227.2 | 217.5 | 47.3 | 322.0 | 12777.2 | 11377.4 | 676.0 | 78.8 |

| Hazardous Air Pollutants (Tons) | | | | |
|---|---|---|---|---|
| Pollutant/Chemical Name | Boiler | | | Total |
| HCL | 0.9 | | | 0.9 |
| HF | 5.4 | | | 5.4 |
| Pb | 0.02 | | | 0.02 |
| | | | | |
| Plant Totals | | | | 6.31 |

| Fuel Combusted & Process/Production Qty | |
|---|---|
| Coal (Tons) | 2248483 |
| Natural Gas (MMScf) | |
| LPG/Propane (Gal) | |
| Bio-gas (MMScf) | |
| Low Sulfur Diesel (Gal)-generators | 2223 |
| Distillate Oil (Gal)- boilers | 540938 |
| Residual Oil (Gal) | |
| Other Fuel(used oil) | 1790 |

| Special Pollutants* Emission Process | Hg (Tons) | NH3 (Tons) |
|---|---|---|
| Unit 1 Boiler | 0.080 | 33.7 |
| | | |
| | | |

| Gross MW Hours** |
|---|
| 2,916,151 |
| |
| |

* Applicable to power plants, beet plants and DGC

**Applicable to utility electric power plants

| Action | Date | Initial |
|---|---|---|
| Scanned | | |
| Checked | | |
| Database Entry | 5-27-15 | |

Scanned: ✓
Added to AQDB: ✓

BK

ND Dept. of Health Emission Inventory Summary Year: **2016**

| | | | |
|---|---|---|---|
| Company: | **Otter Tail Power Company** | AIRS/AFS Source Code: | 38-057-00012 |
| PTO Number: | T5-F84011 | Annual Permit Fee Billing: | **YES** |
| Unit or Station | Coyote Station | Reviewed By: | JDM |

**Individual Emission Sources**

| EUI | Source Unit | Fuel | PM | PM10 | PM2.5 | CPM | SO2 | NOX | CO | VOC |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Unit 1 Boiler | Coal | 41.3 | 39.3 | 2.9 | 227.4 | 8786.0 | 8817.0 | 497.8 | 58.1 |
| | | Oil #2 | 0.2 | 0.1 | 0.0 | 0.2 | 0.0 | 2.8 | 0.6 | 0.0 |
| | | Used Oil | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 2 | Auxiliary Boiler | Oil #2 | 0.2 | 0.2 | | 0.1 | 0.0 | 1.8 | 0.4 | 0.0 |
| 4 | Waukesha Diesel 1440 Hp - Generator | Diesel | | | | | | 0.3 | | |
| 5 | Cummins Diesel 225 Hp - Fire Pump | Diesel | | | | | | 0.0 | | |
| 6 | Kohler Diesel 1375 Hp - Scrubber Generator | Diesel | | | | | | 0.0 | 0.0 | |
| M2-M8 | Miscellaneous | N/A | 33.8 | 33.8 | 33.8 | | | | | |
| | Total Facility Emissions (Less HAPS) | | 75.5 | 73.4 | 36.7 | 227.7 | 8786.1 | 8822.0 | 498.8 | 58.2 |

| Hazardous Air Pollutants (Tons) | | | | |
|---|---|---|---|---|
| Pollutant/Chemical Name | Boiler | | | Total |
| HCL | 0.7 | | | 0.7 |
| HF | 3.8 | | | 3.8 |
| Pb | 0.01 | | | 0.01 |
| | | | | |
| Plant Totals | | | | 4.48 |

| Fuel Combusted & Process/Production Qty | |
|---|---|
| Coal (Tons) | 1659351 |
| Natural Gas (MMScf) | |
| LPG/Propane (Gal) | |
| Bio-gas (MMScf) | |
| Low Sulfur Diesel (Gal)-generators | 1613.8 |
| Distillate Oil (Gal)- boilers | 388553 |
| Residual Oil (Gal) | |
| Other Fuel(used oil) | 3977 |

| Special Pollutants* Emission Process | Hg (Tons) | NH3 (Tons) |
|---|---|---|
| Unit 1 Boiler | 0.050 | 0.0 |
| | | |
| | | |

| Gross MW Hours** |
|---|
| 2,060,099 |
| |
| |

* Applicable to power plants, beet plants and DGC
**Applicable to utility electric power plants

| Action | Date | Initial |
|---|---|---|
| Scanned | | |
| Checked | | |
| Database Entry | 5-25-16 | [illegible] |

PG092

ND Dept. of Health Emission Inventory Summary Year: **2016**

| | | | |
|---|---|---|---|
| Company: | **Otter Tail Power Company** | AIRS/AFS Source Code: | 38-057-00012 |
| PTO Number: | T5-F84011 | Annual Permit Fee Billing: | **YES** |
| Unit or Station | Coyote Station | Reviewed By: | JDM |

**Individual Emission Sources**

| EUI | Source Unit | Fuel | PM | PM10 | PM2.5 | CPM | SO2 | NOX | CO | VOC |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Unit 1 Boiler | Coal | 39.9 | 38.1 | 2.8 | 452.3 | 11872.9 | 7766.3 | 603.6 | 70.4 |
| | | Oil #2 | 0.5 | 0.2 | 0.1 | 0.3 | 0.1 | 5.6 | 1.2 | 0.1 |
| | | Used Oil | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 2 | Auxiliary Boiler | Oil #2 | 0.1 | 0.1 | | 0.1 | 0.0 | 1.4 | 0.3 | 0.0 |
| 4 | Waukesha Diesel 1440 Hp - Generator | Diesel | | | | | | 0.2 | 0.1 | |
| 5 | Cummins Diesel 225 Hp - Fire Pump | Diesel | | | | | | 0.0 | | |
| 6 | Kohler Diesel 1375 Hp - Scrubber Generator | Diesel | | | | | | 0.0 | | |
| M2-M8 | Miscellaneous | N/A | 33.8 | 33.8 | 33.8 | | | | | |
| | Total Facility Emissions (Less HAPS) | | 74.3 | 72.3 | 36.7 | 452.7 | 11873.0 | 7773.6 | 605.1 | 70.5 |

| Hazardous Air Pollutants (Tons) | | | | |
|---|---|---|---|---|
| Pollutant/Chemical Name | Boiler | | | Total |
| HCL | 1.8 | | | 1.8 |
| HF | 4.6 | | | 4.6 |
| Pb | 0.01 | | | 0.01 |
| | | | | |
| Plant Totals | | | | 6.44 |

| Fuel Combusted & Process/Production Qty | |
|---|---|
| Coal (Tons) | 2011974 |
| Natural Gas (MMScf) | |
| LPG/Propane (Gal) | |
| Bio-gas (MMScf) | |
| Low Sulfur Diesel (Gal)-generators | 1100.8 |
| Distillate Oil (Gal)- boilers | 582347 |
| Residual Oil (Gal) | |
| Other Fuel(used oil) | 3718 |

| Special Pollutants* Emission Process | Hg (Tons) | NH3 (Tons) |
|---|---|---|
| Unit 1 Boiler | 0.02 | 0.02 |
| | | |
| | | |

| Gross MW Hours** |
|---|
| 2,587,585 |
| |
| |

| Action | Date | Initial |
|---|---|---|
| Scanned | | |
| Checked | | ✓ |
| Database Entry | | |

* Applicable to power plants, beet plants and DGC

**Applicable to utility electric power plants

ND Dept. of Health Emission Inventory Summary Year: **2017**

| | | | |
|---|---|---|---|
| Company: | **Otter Tail Power Company** | AIRS/AFS Source Code: | 38-057-00012 |
| PTO Number: | T5-F84011 | Annual Permit Fee Billing: | **YES** |
| Unit or Station | Coyote Station | Reviewed By: | MJB |

BK

**Individual Emission Sources**

| EUI | Source Unit | Fuel | PM | $PM_{10}$ | $PM_{2.5}$ | CPM | $SO_2$ | NOx | CO | VOC |
|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Unit 1 Boiler | Coal | 47.0 | 45.2 | 3.3 | 497.7 | 13,443.9 | 6,363.7 | 646.5 | 75.4 |
| | | Oil #2 | 1.2 | 0.6 | 0.1 | 0.8 | 0.1 | 13.8 | 2.9 | 0.1 |
| | | Used Oil | | | | | | 0.1 | | |
| 2 | Auxiliary Boiler | Oil #2 | 0.2 | 0.2 | | 0.1 | | 2.6 | 0.6 | |
| 4 | Waukesha Diesel Generator - 1,440 bhp | Diesel | | | | | | 0.3 | 0.1 | |
| 5 | Cummins Diesel Fire Pump - 225 bhp | Diesel | | | | | | | | |
| 6 | Kohler Diesel Scrubber Generator - 1,375 bhp | Diesel | | | | | | 0.1 | | |
| M2-M8 | Miscellaneous | N/A | 33.8 | 33.8 | 33.8 | | | | | |
| | | | | | | | | | | |
| | **Total Facility Emissions (Less HAPS)** | **2017** | **82.2** | **79.8** | **37.2** | **498.6** | **13,444.0** | **6,380.6** | **650.1** | **75.5** |
| | | 2016 | 74.3 | 72.3 | 36.7 | 452.7 | 11,873.0 | 7,773.6 | 605.1 | 70.5 |
| | | 2015 | 75.5 | 73.4 | 36.7 | 227.7 | 8,786.1 | 8,822.0 | 498.8 | 58.2 |

**Hazardous Air Pollutants (Tons)**

| Pollutant/Chemical Name | | EUI 1 Boiler |
|---|---|---|
| Hydrochloric Acid (HCl) | | 4.6 |
| Hydrofluoric Acid (HF) | | 5.0 |
| Lead (Pb) | | 0.0 |
| | | |
| **Plant Totals** | **2017** | **9.6** |
| | 2016 | 6.4 |
| | 2015 | 4.5 |

**Fuel Combusted/Burned (Optional)**

| | |
|---|---|
| Coal (Tons) | 2,154,856 |
| Natural Gas (MMscf) | 168 |
| LPG/Propane (Gal) | |
| Bio-gas (MMscf) | |
| Low Sulfur Diesel (Gal) - Generators | 1,801 |
| Distillate Oil (Gal) - Boilers | 1,372,253 |
| Residual Oil (Gal) | |
| Used Oil (Gal) | 4,893 |

**Special Pollutants***

| Pollutant/Chemical Name | | EUI 1 Boiler |
|---|---|---|
| Mercury (Hg) | | 0.04 |
| Ammonia ($NH_3$) | | 0.03 |
| **Plant Totals** | | **0.07** |

* Applicable to power plants, beet plants, and DGC

** Applicable to utility electric power plants

| Gross Electricity Generated (MWh)** |
|---|
| 2,778,798 |

| Action | Date | Initial |
|---|---|---|
| Scanned | | |
| Checked | | |
| Database Entry | | |