

All known PCB Ballasts Remove 11/26/14

Cleaned 4 Fixtures
3 new Ballast

Room 2

OK 9/26/14

M.F.



Pod

Cleaned 3 Fixtures

Replaced 3 Ballasts

Room 3
OK 8/29/14
M.F.



Cleaned 2
Fixtures
1 New Ballast

Room 4
OK 8/27/14
M. Ti



4 Cleaned
Fixtures
2 New Ballasts



OK
8/27/14
MF

Room 5

Cleaned 6 Fixtures
Replace 4 Ballast
Replace 1 Plate





OK 8/27/14 Room 6
MF

cleaned 3
Replaced 2 Ballasts
Replace 1 Plate



Room 7

East

door

OK 8/27/14
MF



Clean 1 Fixtur
changeg 1 Ballast

door

OK 8/27/14
JMF

Room 8

Replace 1 Ballast
Clean 1 Fixture



South Pod

Cleaned All
16 Fixtures
10 New
Ballasts



North Pod

All New Type
Ballasts – No PCBs



EAST POD

No Exceptions Reported



OK 8/27/14
MF

Room 9

Cleaned 4 Fixture
Replaced 4 Ballasts



OK 8/27/14
MT

Room 10

cleaned 5 Fixtures
Replaced 5 Ballasts



OK 8/27/14 Room 11
MF

Cleaned 2 Fixtures
Replaced 2 Ballasts





OK 8/27/19
MJF

Room 12

3 cleaned
3 Ballast Replaced



Sky Valley Education Center

EVACUATION LOCATIONS

EMERGENCY EVACUATION ROUTES



ED_004522_00093617-00016

Room 13 North

OK 8/28/14

M.F.

door





ok 8/28/14
MF

Room 114

Cleaned 2 Fixtures
Replaced 2 Ballasts



OK 8/25/14
MF

ROOM 15

Cleaned 2 Fixtures
Replaced 2 Ballasts



OK 8/28/14
MT

Room 16

Cleared 1 Fixtures
Replaced 1 Ballast



Room 17

M Flannery
10/6/14



M. Flanning
10/6/14

Room 18

Cleaned 1 Fixture
Replaced 1 Ballast



M Flanary
10/8/14

Room 19

Clean 2 Fixtures
Replace 2 Ballasts



OK
10/17/14
MIKE FLANNERY

Room
20

Cleaned 2 Fixtures
Replaced 1 Plate



6 Fixtures cleaned
5 New ballasts
2 new Plates

10/10/14

Library
Main







Cleaned 2 Fixtures
Replaced 2 Ballasts

M Flamary
10/17/14

Library
South
END



FASCE

No PCB Ballast
in Main Room
Replace 1 Plate
Clean 1 Fixture



Door

N

CHECKED OK
11/13/14

N

Room A

Cleaned 1 Fixture

All Ballasts NO PCBS
IN This Room



5

CHECKED OK
11/13/14
Room 3



ED_004522_00093617-00029

.... CHECKED OK
11/13/14

Room D
Cleaned 4 Fixtures
Replaced 1 Ballast





CHECKED OK
11/13/14

Prop Area
Between
Room A+C
Cleaned 4
Fixtures

N



S

CHECKED OK
11/13/14

Room C



CHECKED OK
11/18/14

Kelsey → N

Room F

Replaced 2 Plates

Cleared 2 Fixtures



11/13/14
CHECKED OK

CBP
ROOM

Cleaned 6 Fixtures
Replaced 1 Plate



Master pg 3

Music Room Storage + Music Room

Clean 6 Fixtures
Replace 2 Ballasts
Replace 2 Plates



Music Room

Master pg 2