DAVY LABORATORIES
A Division of Davy Engineering Co., Inc.
115 6th Street South
La Crosse, WI 54601
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com

Division of Davy Engineering Co.

LABORATORY ANALYSIS REPORT

[redacted]
Attn: [redacted]
[redacted]
[redacted]

Date: November 21, 2017
Client No: [redacted]

Sample No: [redacted]
Sample Site: Kitchen Sink

Sample Collected: 15-Nov-17 00:00

Sample Received: 16-Nov-17 09:38

Parameter	Result	Units	LOD	LOQ/RL	Dilution	Prepared	Analyzed	Method	MCL	Qualifier
SDWA Inorganic Analysis										
Nitrate as N	33.6	mg/L	0.100	0.500	100	16-Nov-17 18:07	16-Nov-17 18:07	EPA 300.0	10	>MCL
Microbiological Analysis										
Coliform, total	Absent	------			1	16-Nov-17 09:50	16-Nov-17 09:50	SM 9223 B (Colilert)-97		H1
E. Coli	Absent	------			1	16-Nov-17 09:50	16-Nov-17 09:50	SM 9223 B (Colilert)-97		H1

Submitted by:
Davy Laboratories

Jennifer M. Buchholz
Jennifer M. Buchholz, Laboratory Director

The laboratory analyses reported were determined in accordance with methods from approved authoritative sources. Approved authoritative sources are defined and listed within the respective state certification codes. The results are representative of the samples only; conditions can be expected to vary at different times and under different sampling conditions. This report may not be reproduced, except in full, without the written approval of the laboratory. WI Certification 632021390 and WI DATCP 105-216, MN NELAC Certification 055-999-151, IA Certification 304. Revision #1 - 3/8/2016

DAVY LABORATORIES
A Division of Davy Engineering Co., Inc.
115 6th Street South
La Crosse, WI 54601
(608) 782-3130
FAX (608) 784-6611
www.davyinc.com

Division of Davy Engineering Co.

LABORATORY ANALYSIS REPORT

(b)(6) [redacted]
Attn: (b)(6) [redacted]
[redacted]
[redacted]

Date: November 21, 2017
Client No: 11683

Notes and Definitions

H1	H1-Sample received past analysis holding time.
>MCL	Exceeds Maximum Contaminant Level (MCL)
_A	Absent
LOD	Limit of Detection, adjusted for the dilution factor
LOQ/RL	Limit of Quantitation/Reporting Limit, adjusted for the dilution factor
MCL	Maximum Contaminant Level

Total metals are equivalent to total recoverable metals.

Cooler Information

Temperature 2.10 C

COC/Labels Agree	Yes
COC/Labels Do Not Agree	No
Ice Present	Yes
Preservation Confirmed, <2 H2SO4	No
Preservation Confirmed, <2 HCl	No
Preservation Confirmed, <2 HNO3	No
Preservation Confirmed, <2 NaOH	No
Confirmed, Residual Chlorine Absent	No
Confirmed, Sulfide Absent	No

Case Narrative

Sample is from private homeowner well. Not for SDWA compliance under NR809.