930 PORT ST.
EASTON MD.21601

SEP 6, 2016 12:01 PM

INVENTORY REPORT

T 1:ULEADED 4000
VOLUME = 1039 GALS
ULLAGE = 2996 GALS
90% ULLAGE= 2692 GALS
TC VOLUME = 1028 GALS
HEIGHT = 25.57 INCHES
WATER VOL = 62 GALS
WATER = 3.66 INCHES
TEMP = 73.8 DEG F

T 2:OFF ROAD DIESEL
VOLUME = 745 GALS
ULLAGE = 3290 GALS
90% ULLAGE= 2886 GALS
TC VOLUME = 739 GALS
HEIGHT = 20.16 INCHES
WATER VOL = 9 GALS
WATER = 1.04 INCHES
TEMP = 74.9 DEG F

T 3:CLEAR DIESEL
VOLUME = 1460 GALS
ULLAGE = 6580 GALS
90% ULLAGE= 5774 GALS
TC VOLUME = 1460 GALS
HEIGHT = 20.08 INCHES
WATER VOL = 16 GALS
WATER = 0.95 INCHES
TEMP = 78.0 DEG F

T 4:PLUS
VOLUME = 1056 GALS
ULLAGE = 7004 GALS
90% ULLAGE= 6198 GALS
TC VOLUME = 1042 GALS
HEIGHT = 15.85 INCHES
WATER VOL = 17 GALS
WATER = 1.00 INCHES
TEMP = 77.6 DEG F

T 5:UNLEADED 8000
VOLUME = 2241 GALS
ULLAGE = 5819 GALS
90% ULLAGE= 5013 GALS
TC VOLUME = 2213 GALS
HEIGHT = 27.03 INCHES
WATER VOL = 10 GALS
WATER = 0.71 INCHES
TEMP = 77.3 DEG F

* * * * * END * * * * *

900 PORT ST.
EASTON MD.21601

SEP 6, 2016 8:00 AM

CSLD TEST RESULTS
- - - - - - - - - - - - -
SEP 6, 2016 8:00 AM

T 1:ULEADED 4000
PROBE SERIAL NUM 229515

0.2 GAL/HR TEST
PER: SEP 6, 2016 PASS

T 2:OFF ROAD DIESEL
PROBE SERIAL NUM 229517

0.2 GAL/HR TEST
PER: SEP 6, 2016 PASS

T 3:CLEAR DIESEL
PROBE SERIAL NUM 229514

0.2 GAL/HR TEST
PER: SEP 6, 2016 PASS

T 4:PLUS
PROBE SERIAL NUM 229516

0.2 GAL/HR TEST
PER: SEP 6, 2016 PASS

T 5:UNLEADED 8000
PROBE SERIAL NUM 229511

0.2 GAL/HR TEST
PER: SEP 6, 2016 PASS