STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 7, 2017 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 7, 2017 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 7, 2017 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2856.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *