Not on Chart *

Somewhat Confusing because 1 Tank #, it's Probably Was Reprogrammed

PAC PRIDE
930 PORT ST.
EASTON MD.21601

JUL 12, 2016 8:00 AM

CSLD TEST RESULTS

JUL 12, 2016 8:00 AM

T 1:ULEADED 4000
PROBE SERIAL NUM 229515

0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517

0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 3:SUPER
PROBE SERIAL NUM 229514

0.2 GAL/HR TEST
PER: JUL 12, 2016 PASS

T 4:PLUS
PROBE SERIAL NUM 229516

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

T 5:UNLEADED 8000
PROBE SERIAL NUM 229511

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

PAC PRIDE
930 PORT ST.
EASTON MD.21601

JUL 10, 2016 8:00 AM

CSLD TEST RESULTS

JUL 10, 2016 8:00 AM

T 1:ULEADED 4000
PROBE SERIAL NUM 229515

0.2 GAL/HR TEST
PER: JUL 10, 2016 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517

0.2 GAL/HR TEST
PER: JUL 10, 2016 PASS

T 3:SUPER
PROBE SERIAL NUM 229514

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

T 4:PLUS
PROBE SERIAL NUM 229516

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

T 5:UNLEADED 8000
PROBE SERIAL NUM 229511

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

PAC PRIDE
930 PORT ST.
EASTON MD.21601

JUL 13, 2016 8:00 AM

CSLD TEST RESULTS

JUL 13, 2016 8:00 AM

T 1:ULEADED 4000
PROBE SERIAL NUM 229515

0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 2:DIESEL
PROBE SERIAL NUM 229517

0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 3:SUPER
PROBE SERIAL NUM 229514

0.2 GAL/HR TEST
PER: JUL 13, 2016 PASS

T 4:PLUS
PROBE SERIAL NUM 229516

SYSTEM ALARM
PAPER OUT
AUG 19, 2016 12:07 PM

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABL

T 5:UNLEADED 8000
PROBE SERIAL NUM 229511

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABL

SYSTEM ALARM

ED_004938_00029056-00001

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
JAN 7, 2019 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 7, 2019 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
JAN 7, 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1236.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
DEC 24, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 24, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
DEC 24, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1504.1 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
NOV 19, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 19, 2018 2:05 AM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
NOV 19, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1171.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
AUG 20, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 20, 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
AUG 20, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2595.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
JUL 2, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUL 2, 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
JUL 2, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3152.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
JUN 18, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

JUN 18, 2018 2:05 AM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
JUN 18, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3002.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1386.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4632.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3179.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2773.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

TOP IN-TANK LEAK TEST
5:87 OCTANE 8000
CT 29, 2018 2:05 AM

30 PORT ST
ASTON MD 21601

CT 29, 2018 2:05 AM

EAK TEST REPORT

5:87 OCTANE 8000
ROBE SERIAL NUM 229511

EST STARTING TIME:
CT 29, 2018 12:05 AM

ST LENGTH = 2.0 HRS
RT VOLUME = 2920.2 GAL

AK TEST RESULTS
1.20 GAL/HR TEST PASS

* * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
NOV 12, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 12, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
NOV 12, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2704.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
DEC 31, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 31, 2018 2:05 AM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
DEC 31, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2330.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
JAN 7, 2019 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 7, 2019 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
JAN 7, 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2541.8 GAL

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
DEC 17, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 17, 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
DEC 17, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1698.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
NOV 19, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 19, 2018 2:05 AM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
NOV 19, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1840.5 GAL

LEAK TEST RESULTS

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
JAN 7, 2019 2:05 AM

930 PORT ST
EASTON MD 21601

JAN 7, 2019 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
JAN 7, 2019 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2426.2 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
DEC 31, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

DEC 31, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
DEC 31, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2535.8 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
NOV 5, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

NOV 5, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
NOV 5, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2439.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
OCT 29, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

OCT 29, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
OCT 29, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2824.2 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
SEP 10, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

SEP 10, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
SEP 10, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2212.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
AUG 27, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

AUG 27, 2018 2:05 AM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
AUG 27, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3285.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 2:OFF ROAD DIESEL 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 2:OFF ROAD DIESEL 4000
PROBE SERIAL NUM 229517

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1386.4 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 5:87 OCTANE 8000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 5:87 OCTANE 8000
PROBE SERIAL NUM 229511

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 4632.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 1:93 OCTANE 4000
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 1:93 OCTANE 4000
PROBE SERIAL NUM 229515

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2130.9 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END *

STOP IN-TANK LEAK TEST
T 4:NON ETHANOL 91 OCTAN
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 4:NON ETHANOL 91 OCTAN
PROBE SERIAL NUM 229516

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3179.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

STOP IN-TANK LEAK TEST
T 3:DIESEL ON ROAD
APR 23, 2018 2:05 AM

930 PORT ST
EASTON MD 21601

APR 27, 2018 4:27 PM

LEAK TEST REPORT

T 3:DIESEL ON ROAD
PROBE SERIAL NUM 229514

TEST STARTING TIME:
APR 23, 2018 12:05 AM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2773.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

* * * * * END * * * * *