WATER SUPPLY BRANCH
Blue Hen Mall Office
Box 1401
Dover, Delaware 19901

DOCUMENT 40-08/78/01/

PLEASE RETURN TO:

10" Production Well #2

WELL COMPLETION REPORT

Permit Number: 4 0 0 2 5
Owner of well: Town of Blades

Use of water: Domestic [X] Public [X]
Industrial [ ] Agricultural [ ] Irrigation [ ]
Commercial Other

Method of Drilling: Jet [ ] Dug [ ]
Driven [ ] Rotary: Mud [X] Rev. [ ] Air [ ]
Other

Test Well [ ] Observation [ ] Production [X]

Total Well Depth: 96 feet
Date Completed 6/28/78
Month Day Year

If this is a replacement well, how was previous well abandoned?
N/A

Casing Material: Steel [X] PVC [ ] Concrete [ ]
Diameter 10 in. From 0 to 66 feet

Screen Material: Steel [X] PVC [ ] Concrete [ ]
Diameter 8 inches
Setting from 66 to 96 feet

Grout Type: Cement [X] Bentonite Clay [ ]
Other
From 0 to 50 feet

Non-grout Backfill of Well Annulus
Type Natural From 0 to 0 feet

11. Gravel pack: Type Marie 2 & 3
From 50 to 96 feet

12. Static Water Level: Date 6/28/78
20' 3" Ft. (Below, Above) Ground Surface

13. Pumping Water Level: 2 1/2" Ft. below grade
after 5 1/2 hours at 35 gpm

14. Well Head Completion:
Type: Pitless Adapter [ ] Other
inches above grade

15. Type of Permanent Pump Installed:
Pump Manuf.
Rated capacity
Pump intake setting Ft. below grade

16. The completed well is .....

	YES	NO
a. at least 5' from any overhang	X	
b. at least 50' from any septic tank	X	
c. at least 10' from town sewer line	X	
d. at least 100' from the nearest edge of any tilefield (if well is cased less than 50')	X	
e. at least 50' from the edge of any tilefield if casing (not including screen) is more than 50' in depth	X	

17. The nearest neighbors (circle one) septic tank tile field, cesspool, or privy is 120+ from completed well.

18. Is completed well located as shown on application form? [X]

If no, describe location change.....

Company Name Delmarva Drilling Co. Inc.

Ex. 4 CBI

actor Date 4/17/79