UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX
75 Hawthorne Street
San Francisco, CA 94105-3901

Wednesday, July 08, 2015

Sandy Whitehair, CSA
Shungopavi Village
P.O. Box 444
Second Mesa, AZ 86043-

REPORT OF VIOLATIONS OF THE SAFE DRINKING WATER ACT

Dear Ms. Whitehair:

This letter is to notify you of violations of the Safe Drinking Water Act (SDWA) and what must be done to correct the violations for the public water system (PWS) shown below:

Shungopavi, PWS ID#0400259

The violations reported by EPA Region 9 to EPA HQ for the period ending on 3/31/2015 can be found on the attached table.

Public Notification Requirements

The public must be notified any time there is a violation of the SDWA. Depending on the severity of the violation, the type of Public Notice required will fall into one of three "tiers." The final column of the table labeled "Public Notice Tier" indicated the type of Public Notice required for the associated violation. If this PWS is required to distribute an annual Consumer Confidence Report, the Tier 3 notifications can be included in that report. Public Notice templates and handbook can be obtained by request from EPA or can be found at:

http://water.epa.gov/lawsregs/rulesregs/sdwa/publicnotification/compliancehelp.cfm

Tier 1 violations require notification within 24 hours.
Tier 2 violations allow 30 days for notification.
Tier 3 violations require annual notification.

Failure to comply with the public notice requirement will result in further violations.

Return to Compliance

EPA determines that the drinking water system has returned to compliance when the system reports the required sample results, or corrects the violation appropriately. An official Return to Compliance (RTC) will be entered into our records at that point. All violations and RTCs are reported to the EPA website, see: http://www.epa-echo.gov/echo/compliance_report_sdwa.html

Violations of the SDWA that are not corrected lead to a PWS being designated as an 'Enforcement Priority', as identified on EPA's national Enforcement Targeting Tool list. Drinking water systems that acquire this designation are targeted priorities for possible enforcement action by EPA. Furthermore, Enforcement Priority status precludes eligibility for funding under our infrastructure program, unless the proposed project will bring the system into compliance.

If your system has returned to compliance including the requirement to provide public notice, no further action is necessary. If you have questions regarding this matter, please contact Bessie Lee of my staff at (415) 972-3776.

Sincerely,

David Albright, Manager
Drinking Water Protection Section

cc: Herman Honanie, Chairman
Vern Mansfield, Water Operator
Christine Tawahongva, Administration
Lionel Puhuyesva, Director, WRP

Shungopavi, PWS ID#0400259

Table of Violations reported by EPA Region 9 to EPA Headquarters for period ending 3/31/2015

Violation Type: Failure to post/submit offical Public Notification as required by SDWA.

Contaminant	Violation Period*	Sample Date	Result	Violation Comment +	Public Notice Tier
Public Notice Rule	10/1/2014			Failure to post or submit Tier 2 Public Notice for Violation type: MCL, Average - EP001: Running annual average violation calculated from the last sample submitted and the group of results from the previous 4 quarters.: Arsenic: 10/1/2014	3

The Water System must do the following: Post and submit required Public Notice.

Violation Type: Major monitoring/reporting violation for routine chemical monitoring.

Contaminant	Violation Period*	Sample Date	Result	Violation Comment +	Public Notice Tier
Arsenic	1/1/2015 3/31/2015	N/A	N/A	Failed to monitor and/or report required monitoring results due quarterly.	3

The Water System must do the following: Report monitoring results as required.

Violation Type: Maximum Contaminant Level violation for chemical contaminant (running average, 4 qtrs.)

Contaminant	Violation Period*	Sample Date	Result	Violation Comment +	Public Notice Tier
Arsenic	10/1/2014 12/31/2014	N/A	0.014	EP001: Running annual average violation calculated from the last sample submitted and the group of results from the previous 4 quarters.	2
Arsenic	1/1/2015 3/31/2015	N/A	.014	EP001: Running annual average violation calculated from the last sample submitted and the group of results from the previous 4 quarters.	2

The Water System must do the following: Report quarterly monitoring for contaminant in violation, until running annual average is below MCL for 6 months.

* Depending on the contaminant and your public water system's monitoring schedule, violations are reported in the quarter following the due date.

+ The comment field indicates the reason for the violation and may indicate whether the system has corrected the violation, issued public notice, or remains out of compliance.