Message

From: Rapicavoli, Emmanuelle [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=FF3604A98B624BB7A1A9A236EC176998-ERAPICAV]
Sent: 6/26/2017 10:48:42 PM
To: FIRST MESA FMVC [sgfmcv@hopitelecom.net]
Subject: RE: see attach Polacca water system Signaficant Deficiencies
Attachments: Def. #2 Priority 1 Target Cable Guide Seal.JPG

Thank you Sharon,

Below are my responses to the proposed corrections.

1) The fix sounds good. Please provide a picture when you have completed this. Please provide a date by which you will complete this.
2) That sounds good. Please provide a photo showing the sealed flap gate and stainless steel screen and the date it was completed.
3) A finer mesh screen should be installed on the tank vent. The current screen is too large to prevent insects from entering the tank. EPA recommends a non-corrodible 24-mesh insect screen be installed. If FMCV cannot do this work in house, they will need to contract this work out. Please provide a projected completion date.
4) If the steel wool does not work, I would recommend a pvc cap such as the one in the attached picture could be glued to the cable guide. This requires removing the cable temporarily and threading it back through. Please send pictures and a projected completion date.

Thank you ,

Emmanuelle

Emmanuelle Rapicavoli
Drinking Water Protection Section (WTR 3-2)
Environmental Protection Agency, Region 9
75 Hawthorne Street
San Francisco, Ca 94105
(415) 972-3969 (phone)
(415) 947-3545 (fax)

Please: All data submittals to our office should be sent by email to datamanager@epa.gov with a copy to me (or your project manager in the Drinking Water Office). Data reports are due no later than the 10th of the month following the month that you receive results, or the 10th of the month following the compliance period, whichever comes first. Please include the whole lab report and copy of the Chain of Custody. Label with PWS name and number; & source or distribution system location codes or names for data collection points.

From: FIRST MESA FMVC [mailto:sgfmcv@hopitelecom.net]
Sent: Friday, June 23, 2017 3:57 PM
To: Rapicavoli, Emmanuelle <Rapicavoli.Emmanuelle@epa.gov>
Subject: see attach Polacca water system Signaficant Deficiencies

06/23/2017

Good P.m.

See attach the Sanitary Survey for Polacca Water System Deficiencies (PWSI#04001060) with plan attach from the FMCV Water Alfonso and Cody.

Thank you,

Sharon-FMCV Water