California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA0600008	Colusa Co. W.D. #1 - Grimes	Colusa	500	24.0	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers.
CA0707602	Beacon West	Contra Costa	45	27	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA0707615	Doubletree Ranch HOA	Contra Costa	49	21.5	Under enforceable compliance order. Anticipated return to compliance by July 2017.
CA0900102	Gold Beach Park	El Dorado	100	12	Under enforceable compliance order. Anticipated return to compliance date is unknown. System not complying with compliance order.
CA0900210	Millers Hill School	El Dorado	120	8.9	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers. System is currently serving MCL-compliant water.
CA1000053	Lanare CSD	Fresno	400	13; 19.3	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water

Commented [BE1]: I don't understand why there are two RAAs here? I noticed this for other systems as well.

Commented [CC2]: Wherever I have multiple numbers it is because CA DDW listed results for multiple sampling points, such as at two different wells. Compliance is determined at each entry point into the distribution system.

[1] A PWS has returned to compliance when it has maintained a Running Annual Average (RAA) below the arsenic MCL of 10 ppb for four consecutive quarters.

ED_005173_00000130-00001

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					is being provided to customers.
CA1000071	Lakeview Improvement Assoc.	Fresno	64	27.5; 19.3	Under enforceable compliance order. Anticipated return to compliance by July 2017.
CA1000072	Shaver Lake Pt. No. 2	Fresno	210	4.5; 38; 28.8	Not under enforceable compliance order. Anticipated return to compliance by ~~July~~ December 2016.
CA1000369	Zonneveld Dairy	Fresno	141	17.6; 9.1	Not under enforceable compliance order. Anticipated return to compliance by September 2016. Bottled water or hauled water is being provided to customers.
CA1000584	True Organic Products	Fresno	42	15.5	Under enforceable compliance order. Anticipated return to compliance by December 2016.
CA1000602	Baker Commodities	Fresno	60	6.3	Not under enforceable compliance order. Anticipated return to compliance by December 2016. System is currently serving MCL-compliant water.
CA1000604	Johann Dairy	Fresno	60	29	Under enforceable compliance order. Anticipated return to compliance by April 2019.
CA1009051	Cantua Creek Vineyards	Fresno	50	31.3	Under enforceable compliance order. Anticipated return to compliance by July 2017. Bottled water or

Formatted: Highlight

Formatted: Highlight

Commented [BE3]: Do we know if they have come into compliance.

Commented [CC4]: See updated anticipated RTC date.

Formatted: Highlight

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					hauled water is being provided to customers.
CA1010039	Caruthers CSD	Fresno	2103	10; 10.7	Not under enforceable compliance order. Anticipated return to compliance by March 2018.
CA1400036	Keeler CSD	Inyo	180	65	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA1500378	Maher Mutual Water Company	Kern	192	16	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA1500424	Land of Promise Mutual Water Association	Kern	190	17	Under enforceable compliance order. Anticipated return to compliance by May 2018.
CA1500426	Rosa Villa Apartments	Kern	47	10	Not under enforceable compliance order. Anticipated return to compliance date is unknown. System is currently serving MCL-compliant water.
CA1500436	Hungry Gulch Water System	Kern	33	77	Under enforceable compliance order. Anticipated return to compliance by April 2018.
CA1500442	Sunset Apartment Water System	Kern	37	42	Under enforceable compliance order. Anticipated return to compliance by August 2018.
CA1500449	Fourth Street Water System	Kern	56	18	Not under enforceable compliance order. Anticipated return to

Formatted: Highlight

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					compliance by December 2016.
CA1500455	William Fisher Memorial Water Company	Kern	53	22	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA1500458	RS Mutual Water Company	Kern	67	10	Not under enforceable compliance order. Anticipated return to compliance date is unknown. System is currently serving MCL-compliant water.
CA1500461	Fountain Trailer Park Water	Kern	68	89	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers.
CA1500485	Antelope Valley Mobile Estates	Kern	49	8	Not under enforceable compliance order. Anticipated return to compliance date is unknown. System is currently serving MCL-compliant water.
CA1500493	El Adobe Property Owners Association, Inc.	Kern	200	20	Not under enforceable compliance order. Anticipated return to compliance by June 2018.
CA1500521	Boulder Canyon Water Association	Kern	28	19	Under enforceable compliance order. Anticipated return to compliance by April 2018.
CA1500525	Lakeview Ranchos Mutual Water	Kern	120	43	Under enforceable compliance order. Anticipated return to compliance by March 2018.

ED_005173_00000130-00004

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA1500571	Lucky 18 on Rosamond, LLC	Kern	147	30	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA1500585	Oasis Prop Owner Assoc.	Kern	100	11	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA1502154	Lakeside School	Kern	800	17	Not under enforceable compliance order. Anticipated return to compliance by December 2017. Bottled water or hauled water is being provided to customers.
CA1502231	Rosamond School Water System	Kern	900	11	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers.
CA1502383	Nord Road Water Association	Kern	39	13	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA1502569	First Mutual Water System	Kern	35	30	Under enforceable compliance order. Anticipated return to compliance by May 2018.
CA1502620	Pond MWC	Kern	48	14	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA1502724	Quail Valley Water District-Eastside System	Kern	60	88	Under enforceable compliance order. Anticipated return to

ED_005173_00000130-00005

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					compliance by April 2018.
CA1502744	60th Street Association Water System	Kern	44	11	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA1510001	Arvin CSD	Kern	11847	31	Under enforceable EPA compliance order. Anticipated return to compliance by March 2019. Bottled water or hauled water is being provided to customers.
CA1510002	Boron Community Services District	Kern	2500	38	Under enforceable compliance order. Anticipated return to compliance by March 2018.
CA1510012	Lamont PUD	Kern	13296	10.1	Not under enforceable compliance order. Anticipated return to compliance by December 2016. System is currently serving MCL-compliant water.
CA1510016	Rand Communities Water District	Kern	450	19	Under enforceable compliance order. Anticipated return to compliance by March 2018.
CA1510024	Greenfield CWD	Kern	6500	11	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA1510052	North Edwards Water District	Kern	600	32	Not under enforceable compliance order. Anticipated return to compliance by May 2018.

Commented [CC5]: Confirmed

Commented [BE6]: Please review my edits for accuracy

Commented [BE7]: Is this compliant because we round down to 10?

Commented [CC8]: Yes, anything less than 10.5 ug/L is considered compliant.

We round in this manner to the nearest whole ug/L because 40 CFR 141 Section 23(i)(4) says "Arsenic sampling results will be reported to the nearest 0.001 mg/L".

ED_005173_00000130-00006

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA1600008	Central Union School	Kings	320	13; 11	Under enforceable compliance order. Anticipated return to compliance by July 2019.
~~CA1600048~~	~~Kettleman City Elementary~~	~~Kings~~	~~350~~	~~12.25~~	~~School on bottled water. Will consolidate with Kettleman CSD and return to compliance with Kettleman City.~~
CA1600050	Central Valley Meat	Kings	280	36	Under enforceable compliance order. Anticipated return to compliance by January 2019. Bottled water or hauled water is being provided to customers.
CA1600601	Kings Waste Recycling Authority	Kings	45	91	Under enforceable compliance order. Anticipated return to compliance by January 2019. Bottled water or hauled water is being provided to customers.
CA1600605	Baker Commodities	Kings	47	28	Under enforceable compliance order. Anticipated return to compliance by January 2018. Bottled water or hauled water is being provided to customers.
~~CA1610001~~	~~Armona CSD~~	~~Kings~~	~~3239~~	~~8~~	~~Not under enforceable compliance order. Anticipated return to compliance date is unknown. System is currently serving MCL-compliant water.~~
CA1610009	Kettleman City CSD	Kings	1499	15	Not under enforceable compliance order. Anticipated return to compliance date is unknown.

Formatted: Highlight

Commented [CC9]: According to Liliana Stransky via telephone call 10/24/16, the RAA is 12.25

Commented [BE10]: Is this system on the list because the RAA has to be below the MCL for 4 quarters?

Commented [CC11]: I don't believe the RAA has to be below the MCL for 4 quarters. It is my understanding that the RAA has to be below the MCL and the primacy agency has to agree that the system is likely to stay in compliance for the system to be RTC'd.

I found out that we took on this case in 2008. It was RTC'd and according to Tracker, we sent a termination letter in 5/2016.

I've deleted this row from the table. This will also change the overall numbers that I gave you since one more system has been RTC'd.

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA1900038	Lancaster Park Mobile Home Park	Los Angeles	53	15	Not under enforceable compliance order. Anticipated return to compliance by October 2016.
CA1900100	Mettler Valley Mutual	Los Angeles	100	13	Not under enforceable compliance order. Anticipated return to compliance by October 2016.
CA1900520	The Village Mobile Home Park	Los Angeles	70	45	Not under enforceable compliance order. Anticipated return to compliance by October 2016.
CA1900785	Mitchell's Avenue Mobile Home Park	Los Angeles	26	21	Not under enforceable compliance order. Anticipated return to compliance by July 2017.
CA1900961	Winterhaven Mobile Estates	Los Angeles	40	51	Not under enforceable compliance order. Anticipated return to compliance by October 2016.
CA1910246	Land Projects Mutual Water Company	Los Angeles	1500	12.5; 14.5; 10.82	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Referred to EPA for enforcement escalation.
CA2000150	Liberty High School	Madera	1340	42	Under enforceable compliance order. Anticipated return to compliance by August 2018.
CA2000506	Sierra Linda	Madera	180	27	Under enforceable compliance order. Anticipated return to compliance by June 2018.

Formatted: Highlight

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA2000527	Yosemite Forks Estates	Madera	110	17	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2000534	Leisure Acres	Madera	45	8.7	Under enforceable compliance order. Anticipated return to compliance by June 2018. System is currently serving MCL-compliant water.
CA2000538	Cedar Valley Mutual	Madera	137	17	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2000550	MD 6 Lake Shore	Madera	130	79; 97	Under enforceable compliance order. Anticipated return to compliance by June 2018. Bottled water or hauled water is being provided to year-round customers.
CA2000551	MD 7 Marina View Heights	Madera	200	13	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2000552	MD 24 Teaford Meadows	Madera	150	16	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2000561	MD 8 North Fork	Madera	264	13	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2000612	North Fork Union School	Madera	350	13	Under enforceable compliance order. Anticipated return to

Formatted: Highlight

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					compliance by June 2018.
CA2000619	Cold Spring Granite	Madera	43	11; 16.2	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2000737	MD 42 Still Meadows	Madera	100	18; 14	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2000785	Valley Teen Ranch	Madera	50	54	Under enforceable compliance order. Anticipated return to compliance by June 2018. Bottled water or hauled water is being provided to customers.
CA2000866	Agriland Farming	Madera	190	11.5	Under enforceable compliance order. Anticipated return to compliance by June 2018.
CA2010007	Hillview Water Company-Oakhurst/Sierra Lakes	Madera	3006	12.5	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA2010012	Hillview Water Company-Raymond	Madera	290	21.0	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA2010801	Valley State Prison	Madera	4000	9.95; 7.8; 7.2; 3.35	Not under enforceable compliance order. Anticipated return to compliance date is unknown. System is currently serving MCL-compliant water.
CA2210937	Mariposa County Public Works Dept	Mariposa	135	17.0	Under enforceable compliance order.

Formatted: Highlight

Formatted: Highlight

Formatted: Highlight

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					Anticipated return to compliance by November 2016. Bottled water or hauled water is being provided to customers.
CA2400165	Foster Farms Delhi Feedmill	Merced	200	15.75	Under enforceable compliance order. Anticipated return to compliance by February 2018.
CA2400170	Hilmar Cheese Company	Merced	1000	4.7	Under enforceable compliance order. Anticipated return to compliance by December 2016. System is currently serving MCL-compliant water.
CA2600622	Sierra East MHP	Mono	50	42; 81	Not under enforceable compliance order. Anticipated return to compliance by July 2018.
CA2610003	Bridgeport PUD	Mono	3000	34	Under enforceable compliance order. Anticipated return to compliance by April 2018.
CA2700612	Laguna Seca WC	Monterey	162	10.5	Under enforceable compliance order. Anticipated return to compliance by March 2018.
CA2700702	Prunedale MWC	Monterey	252	10	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA2700799	Vista Del Toro WS	Monterey	87	20	Under enforceable compliance order. Anticipated return to compliance by March 2018.

Formatted: Highlight

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA2701221	Washington School	Monterey	250	25	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers.
CA2701296	Moro Rd. #9 WS	Monterey	210	19	Under enforceable compliance order. Anticipated return to compliance by March 2018.
CA2701959	Tierra Vista MWC	Monterey	57	11	Under enforceable compliance order. Anticipated return to compliance by March 2018.
CA2702009	Laguna Seca Rec WS	Monterey	500	16	Under enforceable compliance order. Anticipated return to compliance by March 2018.
CA2702030	Cypress Community Church WS	Monterey	200	16	Under enforceable compliance order. Anticipated return to compliance by March 2018. Bottled water or hauled water is being provided to customers.
CA2702051	Corral de Tierra Estates WS	Monterey	45	76	Under enforceable compliance order. Anticipated return to compliance by March 2018.
CA2702550	Grange Hall WS	Monterey	25	57	Under enforceable compliance order. Anticipated return to compliance by March 2018. Bottled water or hauled water is being provided to customers.
CA3210011	Plumas Eureka CSD	Plumas	339	10.4	Under enforceable compliance order.

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					Anticipated return to compliance by November 2017.
CA3301380	Saint Anthony Trailer Park	Riverside	300	21	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA3303092	Mecca Arco Travel Center	Riverside	47	27	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA3303100	Oasis Gardens Water Company	Riverside	314	11	Under enforceable compliance order. Anticipated return to compliance by January 2018.
CA3400103	B & W Resort	Sacramento	100	33	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA3400130	Courtland Group	Sacramento	40	10	Under enforceable compliance order. Anticipated return to compliance by July 2018. System is currently serving MCL-compliant water.
CA3400138	Locke Waterworks	Sacramento	65	28	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA3400149	Rancho Marina MHP	Sacramento	75	33	Under enforceable compliance order. Anticipated return to compliance by July 2018. Bottled water or hauled water is being provided to customers.

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA3400164	Vieira's Resort	Sacramento	150	25.75; 28.5	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA3400332	Oxbow Marina	Sacramento	90	27	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA3400433	Edgewater MHP	Sacramento	35	36	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA3600025	Bar-Len MWC	San Bernardino	200	17.25	Under enforceable compliance order. Anticipated return to compliance by December 2019.
CA3600036	Calico Ghost Town	San Bernardino	1000	22.25	Under enforceable compliance order. Anticipated return to compliance by December 2019.
CA3600062	Cailier Water System	San Bernardino	100	48	Under enforceable compliance order. Anticipated return to compliance by December 2019.
CA3600196	CSA 70 W-4 Pioneertown	San Bernardino	410	112.5	Under enforceable EPA compliance order. Anticipated return to compliance by ~~date is unknown~~~~January~~ June 2017. Bottled water or hauled water is being provided to customers.
CA3600504	Knoll Enterprises	San Bernardino	500	28.25	Not under enforceable compliance order. Anticipated return to compliance by December 2019.

Formatted: Highlight

Commented [BE12]: Isn't this system under an EPA AOC?

Commented [CC13]: Yes, status confirmed with Chris Chen

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA3601015	Ironwood Camp	San Bernardino	1000	31.75	Under enforceable compliance order. Anticipated return to compliance by December 2019.
CA3610705	US Army Fort Irwin National Training Center	San Bernardino	16000	32	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA3701010	Warner Unified School District	San Diego	250	10.6	Under enforceable compliance order. Anticipated return to compliance by March 2017. Bottled water or hauled water is being provided to customers.
CA3900579	Century Mobile Home Park	San Joaquin	50	14; 14	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA3901169	MSUD-Nile Garden School	San Joaquin	804	23; 23	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA3901213	Avalos, Silvia	San Joaquin	30	13; 13	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers.
CA3901334	BJJ Company LLC	San Joaquin	40	17; 17	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA4000637	Country Hills Estates	San Luis Obispo	81	27	Under enforceable compliance order. Anticipated return to

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					compliance by July 2018.
CA4000774	Pleasant Valley Elementary	San Luis Obispo	150	16	Not under enforceable compliance order. Anticipated return to compliance by July 2017. Bottled water or hauled water is being provided to customers.
CA4600019	Sierra Co. W.W.D #1 Calpine	Sierra	225	21.5	Under enforceable compliance order. Anticipated return to compliance by November 2016.
CA4800561	Snug Harbor Resort	Solano	32	16	Under enforceable compliance order. Anticipated return to compliance by April 2018.
CA4900575	Loch Haven Mutual Water Company	Sonoma	50	12.5	Under enforceable compliance order. Anticipated return to compliance by July 2017.
CA4900643	Mount Weske Estates Mutual Water Company	Sonoma	62	50.5	Under enforceable compliance order. Anticipated return to compliance by July 2017.
CA4900676	Sequoia Gardens Mobile Home Park	Sonoma	300	6.2	Not under enforceable compliance order. Anticipated return to compliance by December 2016. Bottled water or hauled water is being provided to customers. System is currently serving MCL-compliant water.
CA5000033	Coble's Corner	Stanislaus	50	13	Not under enforceable compliance order. Anticipated return to

ED_005173_00000130-00016

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					compliance date is unknown.
CA5000051	Mobile Plaza Park	Stanislaus	125	12	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA5000077	Ceres West MHP	Stanislaus	161	20	Under enforceable compliance order. Anticipated return to compliance by April 2018.
CA5000085	Green Run Mobile Estates	Stanislaus	100	14	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA5000086	Countryside MH Estates	Stanislaus	60	11	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA5000218	Country Villa Apts.	Stanislaus	30	22	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA5000273	Gratton School	Stanislaus	110	13	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA5000308	B&H Manufacturing	Stanislaus	90	8	Under enforceable compliance order. Anticipated return to compliance by March 2017. Bottled water or hauled water is being provided to customers. System is currently serving MCL-compliant water.

ED_005173_00000130-00017

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA5000389	Monterey Park Tract CSD	Stanislaus	186	32	Not under enforceable compliance order. Anticipated return to compliance by September 2016. Bottled water or hauled water is being provided to customers.
CA5000465	Duarte Nursery	Stanislaus	75	6	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA5000484	United Pallet	Stanislaus	45	12	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers.
CA5000498	Patchetts Ford Mercury	Stanislaus	35	10	Not under enforceable compliance order. Anticipated return to compliance date is unknown.
CA5000570	Valley Peterbilt	Stanislaus	25	11	Under enforceable compliance order. Anticipated return to compliance by January 2018. Bottled water or hauled water is being provided to customers.
CA5010008	City of Hughson	Stanislaus	6082	11.0	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA5010009	Keyes CSD	Stanislaus	4891	15.0	Not under enforceable compliance order. Anticipated return to compliance by December 2016.

ED_005173_00000130-00018

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
CA5100107	Sutter County WWD#1 (Robbins)	Sutter	350	16.5	Under enforceable compliance order. Anticipated return to compliance by December 2018.
CA5100145	Winship Elementary School	Sutter	38	15.5	Not under enforceable compliance order. Anticipated return to compliance date is unknown. Bottled water or hauled water is being provided to customers.
CA5100149	Barry Elementary School	Sutter	560	14.9	Under enforceable compliance order. Anticipated return to compliance by May 2018. Bottled water or hauled water is being provided to customers.
CA5200550	New Orchard MHP	Tehama	100	20.75	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA5201137	Millstream MHP	Tehama	118	20.75	Not under enforceable compliance order. Anticipated return to compliance by December 2016.
CA5210003	Los Molinos Comm. Services District	Tehama	1500	10.5	Under enforceable compliance order. Anticipated return to compliance by July 2018.
CA5403054	PFFJ, LLC	Tulare	87	75; 58	Under enforceable compliance order. Anticipated return to compliance by March 2018. Bottled water or hauled water is being provided to customers.
CA5410009	Pixley PUD	Tulare	2793	19	Under enforceable compliance order.

California Water Systems in Noncompliance with Arsenic					
PWS ID	**PWS Name**	**County**	**Pop**	**Arsenic RAA[1] (ug/L)**	**Status**
					Anticipated return to compliance by June 2018.
CA5410024	Richgrove Community Services	Tulare	3330	7	Not under enforceable compliance order. Anticipated return to compliance date is unknown. System is currently serving MCL-compliant water.
CA5410050	Alpaugh JPA	Tulare	1091	7	Under enforceable compliance order. Anticipated return to compliance by May 2018. System is currently serving MCL-compliant water.
CA5700514	Bogle Winery	Yolo	40	12.5	Not under enforceable compliance order. Anticipated return to compliance by January 2017. Bottled water or hauled water is being provided to customers. LPA planning to issue new compliance order by July 2016.
CA5700652	Yolo Fliers Club	Yolo	410	10.0	Not under enforceable compliance order. Anticipated return to compliance date is unknown. System is currently serving MCL-compliant water.
CA5700778	Yolo County Central Landfill	Yolo	40	11.0	Not under enforceable compliance order. Anticipated return to compliance by September 2016.
CA5800805	Lake Francis Mutual Water Company	Yuba	27	10.8	Not under enforceable compliance order. Anticipated return to compliance date is unknown.