Report of Analysis

Client Sample ID:	BPOW5-1		
Lab Sample ID:	JD6452-1	Date Sampled:	04/23/20
Matrix:	AQ - Ground Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123257.D	1	04/28/20 20:52	BK	n/a	n/a	V1B5970
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-1		
Lab Sample ID:	JD6452-1	Date Sampled:	04/23/20
Matrix:	AQ - Ground Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

4.1

4

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	101%		70-130%
460-00-4	4-Bromofluorobenzene	88%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-2		
Lab Sample ID:	JD6452-2	Date Sampled:	04/23/20
Matrix:	AQ - Ground Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123258.D	1	04/28/20 21:23	BK	n/a	n/a	V1B5970
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-2		
Lab Sample ID:	JD6452-2	Date Sampled:	04/23/20
Matrix:	AQ - Ground Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	96%		70-130%
460-00-4	4-Bromofluorobenzene	88%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-3		
Lab Sample ID:	JD6452-3	Date Sampled:	04/23/20
Matrix:	AQ - Ground Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123259.D	1	04/28/20 21:54	BK	n/a	n/a	V1B5970
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-3		
Lab Sample ID:	JD6452-3	Date Sampled:	04/23/20
Matrix:	AQ - Ground Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	97%		70-130%
460-00-4	4-Bromofluorobenzene	88%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042320MW1		
Lab Sample ID:	JD6452-4	Date Sampled:	04/23/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123248.D	1	04/28/20 16:11	BK	n/a	n/a	V1B5970
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042320MW1		
Lab Sample ID:	JD6452-4	Date Sampled:	04/23/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	95%		70-130%
460-00-4	4-Bromofluorobenzene	90%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	FB042320SV1		
Lab Sample ID:	JD6452-10	Date Sampled:	04/23/20
Matrix:	AQ - Field Blank Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123250.D	1	04/28/20 17:13	BK	n/a	n/a	V1B5970
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	FB042320SV1		
Lab Sample ID:	JD6452-10	Date Sampled:	04/23/20
Matrix:	AQ - Field Blank Water	Date Received:	04/24/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	92%		70-130%
460-00-4	4-Bromofluorobenzene	90%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6452X**	**Date Collected:**	**04/23/2020 11:10**	**Matrix:**	**WATER**
Lab Sample ID:	**510215001**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW5-1**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1995282**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/09/2020 03:46**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/08/2020 07:30**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s050820.B\s6e0854.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane		0.470	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6452X**	**Date Collected:**	**04/23/2020 11:40**	**Matrix:**	**WATER**
Lab Sample ID:	**510215002**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW5-2**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1995282**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/09/2020 04:09**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/08/2020 07:30**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s050820.B\s6e0855.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6452X**	**Date Collected:**	**04/23/2020 13:50**	**Matrix:**	**WATER**
Lab Sample ID:	**510215003**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW5-3**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1995282**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/09/2020 04:33**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/08/2020 07:30**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s050820.B\s6e0856.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane		1.70	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6452X**	**Date Collected:**	**04/23/2020 18:00**	**Matrix:**	**WATER**
Lab Sample ID:	**510215008**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**FB042320SV1**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1995282**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/09/2020 09:42**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/08/2020 07:30**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s050820.B\s6e0864.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Report of Analysis

Client Sample ID:	TB042420ARH1		
Lab Sample ID:	JD6499-1	Date Sampled:	04/24/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123273.D	1	04/29/20 15:52	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042420ARH1		
Lab Sample ID:	JD6499-1	Date Sampled:	04/24/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	89%		70-130%
460-00-4	4-Bromofluorobenzene	84%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	REP042420ARH1		
Lab Sample ID:	JD6499-2	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123270.D	1	04/29/20 14:18	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit J = Indicates an estimated value
RL = Reporting Limit B = Indicates analyte found in associated method blank
E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	REP042420ARH1		
Lab Sample ID:	JD6499-2	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	89%		70-130%
460-00-4	4-Bromofluorobenzene	86%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-7		
Lab Sample ID:	JD6499-3	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123266.D	1	04/29/20 12:13	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	J
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	J
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	J
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	J
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	J
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	J
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	J
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit J = Indicates an estimated value
RL = Reporting Limit B = Indicates analyte found in associated method blank
E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-7		
Lab Sample ID:	JD6499-3	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

4.3

4

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	92%		70-130%
460-00-4	4-Bromofluorobenzene	87%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-4		
Lab Sample ID:	JD6499-4	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123267.D	1	04/29/20 12:45	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit J = Indicates an estimated value
RL = Reporting Limit B = Indicates analyte found in associated method blank
E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-4		
Lab Sample ID:	JD6499-4	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	93%		70-130%
460-00-4	4-Bromofluorobenzene	86%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042420BW1		
Lab Sample ID:	JD6499-5	Date Sampled:	04/24/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123274.D	1	04/29/20 16:23	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042420BW1		
Lab Sample ID:	JD6499-5	Date Sampled:	04/24/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

4.5

4

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	90%		70-130%
460-00-4	4-Bromofluorobenzene	86%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-5		
Lab Sample ID:	JD6499-6	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123268.D	1	04/29/20 13:16	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-5		
Lab Sample ID:	JD6499-6	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	92%		70-130%
460-00-4	4-Bromofluorobenzene	85%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-6		
Lab Sample ID:	JD6499-7	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123269.D	1	04/29/20 13:47	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW5-6		
Lab Sample ID:	JD6499-7	Date Sampled:	04/24/20
Matrix:	AQ - Water	Date Received:	04/25/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	91%		70-130%
460-00-4	4-Bromofluorobenzene	86%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6499X**	**Date Collected:**	**04/24/2020 12:00**	**Matrix:**	**WATER**
Lab Sample ID:	**510212001**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**REP042420ARH1**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 16:40**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1112.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6499X**	**Date Collected:**	**04/24/2020 11:05**	**Matrix:**	**WATER**
Lab Sample ID:	**510212002**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW5-7**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 17:06**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1113.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6499X**	**Date Collected:**	**04/24/2020 14:10**	**Matrix:**	**WATER**
Lab Sample ID:	**510212003**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW5-4**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 18:45**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1117.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane		0.798	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6499X**	**Date Collected:**	**04/24/2020 11:07**	**Matrix:**	**WATER**
Lab Sample ID:	**510212004**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW5-5**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 19:09**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1118.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane		1.06	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6499X**	**Date Collected:**	**04/24/2020 10:50**	**Matrix:**	**WATER**
Lab Sample ID:	**510212005**	**Date Received:**	**04/28/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW5-6**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 19:33**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1119.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane		0.867	ug/L	0.0400	0.0800	0.200

Report of Analysis

Client Sample ID:	TB042270MW1		
Lab Sample ID:	JD6520-1	Date Sampled:	04/27/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123276.D	1	04/29/20 17:25	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit J = Indicates an estimated value
RL = Reporting Limit B = Indicates analyte found in associated method blank
E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042270MW1		
Lab Sample ID:	JD6520-1	Date Sampled:	04/27/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

4.1

4

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	95%		70-130%
460-00-4	4-Bromofluorobenzene	84%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
1066-40-6	Silanol, trimethyl-	9.15	1.7	ug/l	JN
	Total TIC, Volatile		1.7	ug/l	J N

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042270BW1		
Lab Sample ID:	JD6520-2	Date Sampled:	04/27/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123277.D	1	04/29/20 17:56	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042270BW1		
Lab Sample ID:	JD6520-2	Date Sampled:	04/27/20
Matrix:	AQ - Trip Blank Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	90%		70-130%
460-00-4	4-Bromofluorobenzene	82%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
1066-40-6	Silanol, trimethyl-	9.14	4.8	ug/l	JN
	Total TIC, Volatile		4.8	ug/l	J N

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-1		
Lab Sample ID:	JD6520-3	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123278.D	1	04/29/20 18:27	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-1		
Lab Sample ID:	JD6520-3	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	95%		70-130%
460-00-4	4-Bromofluorobenzene	82%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-2		
Lab Sample ID:	JD6520-4	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123279.D	1	04/29/20 18:58	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-2		
Lab Sample ID:	JD6520-4	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	92%		70-130%
460-00-4	4-Bromofluorobenzene	85%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-3		
Lab Sample ID:	JD6520-5	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123280.D	1	04/29/20 19:30	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit J = Indicates an estimated value
RL = Reporting Limit B = Indicates analyte found in associated method blank
E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-3		
Lab Sample ID:	JD6520-5	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	93%		70-130%
460-00-4	4-Bromofluorobenzene	85%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-4		
Lab Sample ID:	JD6520-6	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123281.D	1	04/29/20 20:01	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-4		
Lab Sample ID:	JD6520-6	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	98%		70-130%
460-00-4	4-Bromofluorobenzene	87%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-5		
Lab Sample ID:	JD6520-7	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123282.D	1	04/29/20 20:32	BK	n/a	n/a	V1B5971
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit J = Indicates an estimated value
RL = Reporting Limit B = Indicates analyte found in associated method blank
E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-5		
Lab Sample ID:	JD6520-7	Date Sampled:	04/27/20
Matrix:	AQ - Water	Date Received:	04/28/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	93%		70-130%
460-00-4	4-Bromofluorobenzene	84%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6520X**	**Date Collected:**	**04/27/2020 10:35**	**Matrix:**	**WATER**
Lab Sample ID:	**510374001**	**Date Received:**	**04/30/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW6-1**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 19:57**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1120.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6520X**	**Date Collected:**	**04/27/2020 11:15**	**Matrix:**	**WATER**
Lab Sample ID:	**510374002**	**Date Received:**	**04/30/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW6-2**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 21:13**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1123.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6520X**	**Date Collected:**	**04/27/2020 10:45**	**Matrix:**	**WATER**
Lab Sample ID:	**510374003**	**Date Received:**	**04/30/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW6-3**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 21:39**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1124.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6520X**	**Date Collected:**	**04/27/2020 10:37**	**Matrix:**	**WATER**
Lab Sample ID:	**510374004**	**Date Received:**	**04/30/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW6-4**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 22:04**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1125.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	J	0.199	ug/L	0.0400	0.0800	0.200

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6520X**	**Date Collected:**	**04/27/2020 13:25**	**Matrix:**	**WATER**
Lab Sample ID:	**510374005**	**Date Received:**	**04/30/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW6-5**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 22:29**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1126.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200

Report of Analysis

Client Sample ID:	BPOW6-6		
Lab Sample ID:	JD6573-1	Date Sampled:	04/28/20
Matrix:	AQ - Water	Date Received:	04/29/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123291.D	1	04/30/20 11:57	BK	n/a	n/a	V1B5972
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane [b]	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	BPOW6-6		
Lab Sample ID:	JD6573-1	Date Sampled:	04/28/20
Matrix:	AQ - Water	Date Received:	04/29/20
Method:	EPA 524.2 REV 4.1	Percent Solids:	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	95%		70-130%
460-00-4	4-Bromofluorobenzene	85%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

(a) EPA 524.2 is not a certified method for non-potable water samples.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042820DC1		
Lab Sample ID:	JD6573-4	**Date Sampled:**	04/28/20
Matrix:	AQ - Trip Blank Water	**Date Received:**	04/29/20
Method:	EPA 524.2 REV 4.1	**Percent Solids:**	n/a
Project:	Navy Wells OU2, Bethpage, NY		

	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1 [a]	1B123295.D	1	04/30/20 14:02	BK	n/a	n/a	V1B5972
Run #2							

	Purge Volume
Run #1	5.0 ml
Run #2	

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
67-64-1	Acetone	ND	5.0	2.5	ug/l	
78-93-3	2-Butanone	ND	5.0	0.43	ug/l	
71-43-2	Benzene	ND	0.50	0.16	ug/l	
75-27-4	Bromodichloromethane	ND	0.50	0.13	ug/l	
75-25-2	Bromoform	ND	0.50	0.27	ug/l	
74-83-9	Bromomethane	ND	0.50	0.18	ug/l	
75-15-0	Carbon disulfide	ND	0.50	0.18	ug/l	
108-90-7	Chlorobenzene	ND	0.50	0.093	ug/l	
75-00-3	Chloroethane [b]	ND	0.50	0.080	ug/l	
67-66-3	Chloroform	ND	0.50	0.17	ug/l	
74-87-3	Chloromethane	ND	0.50	0.13	ug/l	
56-23-5	Carbon tetrachloride	ND	0.50	0.24	ug/l	
75-34-3	1,1-Dichloroethane	ND	0.50	0.22	ug/l	
75-35-4	1,1-Dichloroethylene	ND	0.50	0.19	ug/l	
107-06-2	1,2-Dichloroethane	ND	0.50	0.18	ug/l	
78-87-5	1,2-Dichloropropane	ND	0.50	0.19	ug/l	
124-48-1	Dibromochloromethane	ND	0.50	0.14	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	0.50	0.21	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	0.50	0.14	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND	0.50	0.18	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND	0.50	0.16	ug/l	
100-41-4	Ethylbenzene	ND	0.50	0.076	ug/l	
76-13-1	Freon 113	ND	1.0	0.34	ug/l	
591-78-6	2-Hexanone	ND	2.0	0.24	ug/l	
75-09-2	Methylene chloride	ND	0.50	0.37	ug/l	
108-10-1	4-Methyl-2-pentanone	ND	2.0	0.22	ug/l	
100-42-5	Styrene	ND	0.50	0.069	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	0.50	0.22	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND	0.50	0.13	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	0.50	0.19	ug/l	
127-18-4	Tetrachloroethylene	ND	0.50	0.23	ug/l	
108-88-3	Toluene	ND	0.50	0.11	ug/l	

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range
J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TB042820DC1		
Lab Sample ID:	JD6573-4	**Date Sampled:**	04/28/20
Matrix:	AQ - Trip Blank Water	**Date Received:**	04/29/20
Method:	EPA 524.2 REV 4.1	**Percent Solids:**	n/a
Project:	Navy Wells OU2, Bethpage, NY		

VOA OU2 Outpost List

CAS No.	Compound	Result	RL	MDL	Units	Q
79-01-6	Trichloroethylene	ND	0.50	0.20	ug/l	
75-01-4	Vinyl chloride	ND	0.50	0.15	ug/l	
	m,p-Xylene	ND	0.50	0.14	ug/l	
95-47-6	o-Xylene	ND	0.50	0.076	ug/l	

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	89%		70-130%
460-00-4	4-Bromofluorobenzene	85%		70-130%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
1066-40-6	Silanol, trimethyl-	9.16	7.1	ug/l	JN
	Total TIC, Volatile		7.1	ug/l	J N

(a) EPA 524.2 is not a certified method for non-potable water samples.
(b) Associated CCV outside of control limits high, sample was ND.

ND = Not detected MDL = Method Detection Limit
RL = Reporting Limit
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Semi-Volatile
Certificate of Analysis
Sample Summary

SDG Number:	**JD6573X**	**Date Collected:**	**04/28/2020 11:10**	**Matrix:**	**WATER**
Lab Sample ID:	**510377001**	**Date Received:**	**04/30/2020 08:45**		
		Client:	**ACTL003**	**Project:**	**ACTL00316**
Client ID:	**BPOW6-6**	**Method:**	**EPA 522**	**SOP Ref:**	**GL-OA-E-073**
Batch ID:	**1994125**	**Inst:**	**MSD6.I**	**Dilution:**	**1**
Run Date:	**05/11/2020 22:54**	**Analyst:**	**JMB3**	**Inj. Vol:**	**1 uL**
Prep Date:	**05/11/2020 09:00**	**Aliquot:**	**100 mL**	**Final Volume:**	**2 mL**
Data File:	**s051120.B\s6e1127.D**		**Rtx-624**		

CAS No.	Parmname	Qualifier	Result	Units	MDL	LOD	LOQ
123-91-1	1,4-Dioxane	U	0.0800	ug/L	0.0400	0.0800	0.200