Attachment 3

Non-Contact Cooling Water Chlorine Residual Results

ATTACHMENT 3
PLATFORM ELLY
NON-CONTACT COOLING WATER CHLORINE RESULTS
October 1, 2017 through December 31, 2017

Discharge	Measurement Frequency	Average Monthly Limit [1] Post Dilution (mg/l)	Maximum Daily Limit [1] Post Dilution (mg/l)	Result Post Dilution (mg/l)	End-of-Pipe Concentration (mg/l) EPA Method 330.5	EPA Plumes Dilution
009 Non-contact Cooling Water Sample Date: 10/27/2017	Once/Quarter	0.00585	0.0102	0.0022	0.6	277:1

[1] Limits are post-dilution as listed in the permit, Appendix C.