Message

From: Doug Fritsch [dfritsch@greenleaf-power.com]
Sent: 8/17/2022 8:39:23 PM
To: Brahmbhatt, Roshni (she/her) [brahmbhatt.Roshni@epa.gov]
Subject: Excess Emissions Exceedance Report
Attachments: 20220817162738388.pdf

Roshni,

We experienced a CO lbs/hr exceedance during a boiler start up. Because we were in a start up our O2 was high and combustion wasn't stable. Once we started burning biomass our O2s dropped causing the CO lbs/hr to drop as well. Attached is the Form 500-N

Thank you,
Doug

Doug Fritsch
Operations Manager
Desert View Plant
Greenleaf Power, LLC
(760) 262-1682 office
(979) 702-9428 cell
Dfritsch@greenleaf-power.com
Greenleaf POWER

Doug Fritsch
Operations Manager
Desert View Plant
Greenleaf Power, LLC
(760) 262-1682 office
(979) 702-9428 cell
Dfritsch@greenleaf-power.com
Greenleaf POWER