Desert View Power, Inc. an affiliate of

Greenleaf POWER

March 31, 2016
DVP-160007

Mr. David Jones
Air Pollution Control Officer
South Coast Air Quality Management District
21865 East Copley Drive
Diamond Bar, California 91765-4182

Subject: Monthly Report of Excess Emissions for February 2016

SCAQMD FILE # 100154

Dear Mr. Jones:

Excess emissions summaries for each boiler for January 2016 are attached.

Emission concentration limits (ppm) do not apply during the normal start up and shut down conditions for each boiler. Thus, exceedences within the permit limits during start up and shut down, as defined in the amendment, are not applicable and as such not reportable.

Please call if you have any questions or comments. I can be reached at (760) 262-1653.

Sincerely,

James Russell Huffman

Vice President of CA operations / Plant Manager

rfk/

62-300 Gene Welmas Dr. | Mecca, CA 92254
(760)396-2554
www.greenleaf-power.com

Page 2

encl

cc:

Chief, Stationary Source Division

California Air Resources Board

P.O. Box 2815

Sacramento, CA 95814

Director, Air Management Division

Attention: Air-5

U.S. Environmental Protection Agency

75 Hawthorne Street

San Francisco, CA 94105-3901

COLMAC ENERGY MECCA POWER PLANT
EXCESS EMISSIONS REPORT
BOILER #1
February 2015

Hours Operated: 521.304 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	
CEMS			**CEMS**			**CEMS**
2/7/2016	Nox ppm @ 3% O2	19				Start up boiler.
2/7/2016	Nox lb/mmbtu	19				Start up boiler.
2/7/2016	So2 ppm @ 3% O2	19				Start up boiler.
2/7/2016	So2 lb/mmbtu	19				Start up boiler.
2/7/2016	CO ppm @ 3% O2	19				Start up boiler.
2/7/2016	Nox lb/hr	17				Start up boiler.
2/7/2016	So2 lb/hr	17				Start up boiler.
2/7/2016	CO lb/hr	17				Start up boiler.
2/8/2016	Nox ppm @ 3% O2	13				Start up boiler.
2/8/2016	Nox lb/mmbtu	13				Start up boiler.
2/8/2016	So2 ppm @ 3% O2	13				Start up boiler.
2/8/2016	So2 lb/mmbtu	13				Start up boiler.
2/8/2016	CO ppm @ 3% O2	13				Start up boiler.
2/8/2016	Nox lb/hr	17				Start up boiler.
2/8/2016	So2 lb/hr	17				Start up boiler.
2/8/2016	CO lb/hr	17				Start up boiler.
2/8/2016	CO ppm @ 3% O2	1				Start up boiler.
2/9/2016	Nox lb/hr	7				Start up boiler.
2/9/2016	So2 lb/hr	7				Start up boiler.
2/9/2016	CO lb/hr	8				Start up boiler.
2/9/2016	CO ppm @ 3% O2	2				Start up boiler.
2/9/2016	CO ppm @ 3% O2	1				Start up boiler.
2/11/2016	Nox ppm @ 3% O2	1				CEM taken out of service for maintenance.
2/11/2016	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
2/11/2016	So2 ppm @ 3% O2	1				CEM taken out of service for maintenance.
2/11/2016	So2 lb/mmbtu	1				CEM taken out of service for maintenance.
2/11/2016	CO ppm @ 3% O2	1				CEM taken out of service for maintenance.
2/11/2016	CO ppm @ 3% O2	1				CEM taken out of service for maintenance.
2/11/2016	CO lb/hr	1				CEM taken out of service for maintenance.
2/12/2016	ALL	3				Start up boiler.
2/13/2016	CO ppm @ 3% O2	2				Start up boiler.

ED_013709B_00000023-00003

COLMAC ENERGY MECCA POWER PLANT
EXCESS EMISSIONS REPORT
BOILER #1
February 2015

Hours Operated: 521.304 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	
2/13/2016	Nox lb/hr	7				Start up boiler.
2/13/2016	So2 lb/hr	7				Start up boiler.
2/13/2016	CO lb/hr	7				Start up boiler.
2/22/2016	Nox ppm @ 3% O2	1				CEM taken out of service for maintenance.
2/22/2016	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
2/22/2016	So2 ppm @ 3% O2	1				CEM taken out of service for maintenance.
2/22/2016	So2 lb/mmbtu	1				CEM taken out of service for maintenance.
2/22/2016	CO ppm @ 3% O2	1				CEM taken out of service for maintenance.

NOTE: 1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

ED_013709B_00000023-00004

COLMAC ENERGY MECCA POWER PLANT
EXCESS EMISSIONS REPORT

BOILER #2
February 2015

Hours Operated: 658.416 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	
CEMS			**CEMS**			**CEMS**
2/1/2016	Nox lb/hr	4				CEM taken out fo servive for maintenance.
2/1/2016	So2 lb/hr	4				CEM taken out fo servive for maintenance.
2/1/2016	CO lb/hr	4				CEM taken out fo servive for maintenance.
2/10/2016	ALL	2				CEM taken out fo servive for maintenance.
2/18/2016	Nox lb/hr	1				CEM taken out fo servive for maintenance.
2/18/2016	So2 lb/hr	1				CEM taken out fo servive for maintenance.
2/18/2016	CO lb/hr	1				CEM taken out fo servive for maintenance.
2/22/2016	Nox ppm @ 3% O2	1				CEM taken out fo servive for maintenance.
2/22/2016	Nox lb/mmbtu	1				CEM taken out fo servive for maintenance.
2/22/2016	Nox lb/hr	1				CEM taken out fo servive for maintenance.
2/22/2016	So2 ppm @ 3% O2	1				CEM taken out fo servive for maintenance.
2/22/2016	So2 lb/mmbtu	1				CEM taken out fo servive for maintenance.
2/22/2016	So2 lb/hr	1				CEM taken out fo servive for maintenance.
2/22/2016	CO ppm @ 3% O2	1				CEM taken out fo servive for maintenance.
2/25/2016	ALL	1				CEM taken out fo servive for maintenance.
2/29/2016	Nox ppm @ 3% O2	7				Start up boiler.
2/29/2016	Nox lb/mmbtu	7				Start up boiler.
2/29/2016	So2 ppm @ 3% O2	7				Start up boiler.
2/29/2016	So2 lb/mmbtu	7				Start up boiler.
2/29/2016	CO ppm @ 3% O2	7				Start up boiler.
2/29/2016	Nox lb/hr	1				Start up boiler.
2/29/2016	So2 lb/hr	1				Start up boiler.
2/29/2016	CO lb/hr	1				Start up boiler.
2/29/2016	CO ppm @ 3% O2	1				Start up boiler.
2/29/2016	CO lb/hr	1				Start up boiler.

ED_013709B_00000023-00005

COLMAC ENERGY MECCA POWER PLANT
EXCESS EMISSIONS REPORT
BOILER #2
February 2015

Hours Operated: 658.416 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	

NOTE: 1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

ED_013709B_00000023-00006

COLMAC ENERGY MECCA POWER PLANT
EXCESS EMISSIONS REPORT
STACK
February 2015

Hours Operated: 696.000 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	
CEMS			**CEMS**			**CEMS**

COLMAC ENERGY MECCA POWER PLANT
EXCESS EMISSIONS REPORT
STACK
February 2015

Hours Operated: 696.000 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	

NOTE: 1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

ED_013709B_00000023-00008