Desert View Power, Inc. an affiliate of

Greenleaf POWER

December 30, 2016
DVP-160025

Mr. David Jones
Air Pollution Control Officer
South Coast Air Quality Management District
21865 East Copley Drive
Diamond Bar, California 91765-4182

Subject: Monthly Report of Excess Emissions for November 2016

SCAQMD FILE # 100154

Dear Mr. Jones:

Excess emissions summaries for each boiler for November 2016 are attached.

Emission concentration limits (ppm) do not apply during the normal start up and shut down conditions for each boiler. Thus, exceedences within the permit limits during start up and shut down, as defined in the amendment, are not applicable and as such not reportable.

Please call if you have any questions or comments. I can be reached at (760) 262-1653.

Sincerely,

James Russell Huffman

Vice President of CA operations / Plant Manager

rfk/

62-300 Gene Welmas Dr. | Mecca, CA 92254
(760) 396-2554

encl

cc:

Chief, Stationary Source Division

California Air Resources Board

P.O. Box 2815

Sacramento, CA 95814

Director, Air Management Division

Attention: Air-5

U.S. Environmental Protection Agency

75 Hawthorne Street

San Francisco, CA 94105-3901

DESERT VIEW POWER PLANT
EXCESS EMISSIONS REPORT

BOILER #1
November 2016

Hours Operated: 645.120 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	
CEMS			**CEMS**			**CEMS**
11/5/2016	ALL	3				CEM taken out of service for maintenance.
11/6/2016	ALL	4				CEM taken out of service for maintenance.
11/9/2016	ALL	1				CEM taken out of service for maintenance.
11/10/2016	ALL	1				CEM taken out of service for maintenance.
11/11/2016	SO2 ppm@3%O2	1				CEM taken out of service for maintenance.
11/11/2016	SO2 lb/mmbtu	1				CEM taken out of service for maintenance.
11/11/2016	SO2 lb/hr	1				CEM taken out of service for maintenance.
11/11/2016	ALL	1				CEM taken out of service for 4th quarter CGA.
11/18/2016	Nox ppm@3%O2	1				CEM taken out of service for maintenance.
11/18/2016	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
11/18/2016	SO2 ppm@3%O2	1				CEM taken out of service for maintenance.
11/18/2016	SO2 lb/mmbtu	1				CEM taken out of service for maintenance.
11/18/2016	CO ppm@3%O2	1				CEM taken out of service for maintenance.

ED_013709B_00000034-00003

DESERT VIEW POWER PLANT
EXCESS EMISSIONS REPORT

BOILER #1
November 2016

Hours Operated: 645.120 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	

NOTE: 1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

ED_013709B_00000034-00004

DESERT VIEW POWER PLANT
EXCESS EMISSIONS REPORT
BOILER #2
November 2016

Hours Operated: 720.000 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	
CEMS			CEMS			CEMS
11/8/2016	Nox ppm@3%O2	1				CEM taken out of service for maintenance.
11/8/2016	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
11/8/2016	SO2 ppm@3%O2	1				CEM taken out of service for maintenance.
11/8/2016	SO2 lb/mmbtu	1				CEM taken out of service for maintenance.
11/8/2016	CO ppm@3%O2	1				CEM taken out of service for maintenance.
11/8/2016	Nox ppm@3%O2	1				CEM taken out of service for maintenance.
11/8/2016	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
11/8/2016	SO2 ppm@3%O2	1				CEM taken out of service for maintenance.
11/8/2016	SO2 lb/mmbtu	1				CEM taken out of service for maintenance.
11/8/2016	CO ppm@3%O2	1				CEM taken out of service for maintenance.
11/10/2016	ALL	1				CEM taken out of service for maintenance.
11/11/2016	ALL	1				CEM taken out of service for 4th quarter CGA.
11/18/2016	Nox ppm@3%O2	2				CEM taken out of service for maintenance.
11/18/2016	Nox lb/mmbtu	2				CEM taken out of service for maintenance.
11/18/2016	SO2 ppm@3%O2	2				CEM taken out of service for maintenance.
11/18/2016	SO2 lb/mmbtu	2				CEM taken out of service for maintenance.
11/18/2016	CO ppm@3%O2	2				CEM taken out of service for maintenance.
11/25/2016	Nox lb/hr	2				CEM taken out of service for maintenance.
11/25/2016	SO2 lb/hr	2				CEM taken out of service for maintenance.
11/25/2016	CO lb/hr	2				CEM taken out of service for maintenance.
11/26/2016	Nox lb/hr	2				CEM taken out of service for maintenance.
11/26/2016	SO2 lb/hr	2				CEM taken out of service for maintenance.
11/26/2016	CO lb/hr	2				CEM taken out of service for maintenance.
11/26/2016	Nox lb/hr	2				CEM taken out of service for maintenance.
11/26/2016	SO2 lb/hr	2				CEM taken out of service for maintenance.
11/26/2016	CO lb/hr	2				CEM taken out of service for maintenance.

ED_013709B_00000034-00005

DESERT VIEW POWER PLANT
EXCESS EMISSIONS REPORT

BOILER #2
November 2016

Hours Operated: 720.000 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	

NOTE: 1. The term ALL is used in the Limit Exceeded column to indicate the following: (Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

ED_013709B_00000034-00006

DESERT VIEW POWER PLANT
EXCESS EMISSIONS REPORT
STACK
November 2016

Hours Operated: 720.000 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	
CEMS			CEMS			CEMS

DESERT VIEW POWER PLANT
EXCESS EMISSIONS REPORT

STACK

November 2016

Hours Operated: 720.000 hrs

Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
			Average Value	Maximum Value	Permit Limit	

NOTE: 1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

ED_013709B_00000034-00008