To: Nonresponsive based on revised scope @erllc.com)[g.sulon@erllc.com]; McCauley, Joanna[McCauley.Joanna@epa.gov]
From: Wagner, Christine[/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=12068C1889924ECF96F692831F0C77D4-CWAGNE02]
Sent: Thur 11/1/2018 12:40:24 PM (UTC)
Subject: Shiloh Church Road -- CONTAINS INFORMATION PROTECTED BY THE PRIVACY ACT. DO NOT FORWARD
DWO-11-1-18_20181101_0001(0).pdf

Hi Nonresponsive based on revised scope

As we discussed on Tuesday, the GAC unit at Ex. 6 Personal Privacy (PP) are giving off a sulfur odor. Based on my discussions with the Health Dept, this is due to a bacteria buildup on the GAC from naturally occurring iron in the area.

and I spoke with the resident. As an immediate mitigation measure, I authorize replacing the canisters at this residence, provided there is enough funding available. Joanna, can you please work with on this and check my overall budget?

However, this problem will likely arise again if the sulfur is being caused by iron and not something else in the system (the resident believes she may have received "bad canisters", but I'm not convinced).

Therefore, the new unit will buy us some time to look into enhancements. UV and/or a water softener may help. The resident is ADAMANT that she does not want a chlorine drip, and I agree. Please talk to some of your folks, and I will do the same.

Because of this, we are going back to delivering bottled water to both residents. Please DO NOT KNOCK but just leave the water. Also, any onsite appointments with Culligan should be coordinated with me and I will coordinate with the resident.

Please call with any questions
Thank you
Chris