JI1315 **23RD AVE AND** **NY Spills** **S106013103**
NNW **81ST ST** **N/A**
> 1 **BROOKLYN, NY**
1.679 mi.
8864 ft. **Site 2 of 2 in cluster JI**

Relative:
Higher

Actual:
19 ft.

SPILLS:

Name:	23RD AVE AND
Address:	81ST ST
City,State,Zip:	BROOKLYN, NY
Spill Number/Closed Date:	0300449 / 2003-04-14
Facility ID:	0300449
Facility Type:	ER
DER Facility ID:	129437
Site ID:	152483
DEC Region:	2
Spill Cause:	Other
Spill Class:	D4
SWIS:	2401
Spill Date:	2003-04-13
Investigator:	MXTIPPLE
Referred To:	Not reported
Reported to Dept:	2003-04-13
CID:	405
Water Affected:	GRAVES END BAY
Spill Source:	Commercial/Industrial
Spill Notifier:	Responsible Party
Cleanup Ceased:	Not reported
Cleanup Meets Std:	False
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	2003-04-13
Spill Record Last Update:	2003-04-14
Spiller Name:	CALLER
Spiller Company:	NYC DEP
Spiller Address:	9605 HORACE HARDING EXWAY
Spiller Company:	001
Contact Name:	RICHARD DESFOSSE
DEC Memo:	"Prior to Sept, 2004 data translation this spill Lead_DEC Field was TIPPLE 4/14/2003 MT Sewage bypass from DEP facility referred to Water's Mr. Southwell for distriburion."
Remarks:	"caller states spilling due to a blockage in one of the regulators - still activley spilling at this time - this is at the owlshead ten regulator station - working on cleaning the blockage out"

All Materials:

Site ID:	152483
Operable Unit ID:	868747
Operable Unit:	01
Material ID:	508527
Material Code:	0062A
Material Name:	raw sewage
Case No.:	Not reported
Material FA:	Other
Quantity:	.00
Units:	G
Recovered:	.00
Oxygenate:	Not reported