RECEIVED
MAY 07 2013
SAP20

# Initial Notification of Applicability[b]

National Emission Standards for Hazardous Air Pollutants:

Stationary Reciprocating Internal Combustion Engines

**40 CFR Part 63 Subpart ZZZZ**

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 488320

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

**Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:**

- Existing non-emergency compression ignition (CI) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: Elizabeth River Terminals, LLC.

Facility name (if different): Elizabeth River Terminal

Facility (physical location) address: 4100 Buell Street, Chesapeake, VA 23324

My facility is a (please choose one): ☐ Major source ☒ Area source

Owner name/title: Elizabeth River Terminals, LLC

Owner/company address: Same as above

[a] This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

[b] Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Owner telephone number: 757-543-0335

Owner email address (if available): _____

If the Operator information is different from the Owner, please provide the following:

Operator name/title: _____

Operator telephone number: _____

Operator email address (if available): _____

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine: Stationary CI RICE– 480 HP (Clyde Crane)

I hereby certify that the information presented herein is correct to the best of my knowledge.

(Signature) 5/2/13 (Date)

Gary Pullem / Terminal Manager (Name/title) ( 757 ) 543-0335 (Telephone No.)